



Marine & Offshore

Certificate number: 23444/B2 BV

File number: AP 4153

Product code: 2592I

This certificate is not valid when presented without the full attached schedule composed of 7 sections

www.veristar.com

TYPE APPROVAL CERTIFICATE

This certificate is issued to

Danfoss LLC

Loves Park, IL - UNITED STATES OF AMERICA

for the type of product

FREQUENCY CONVERTERS (Power 50kW and over)

FC-302 VLT Automation Series, FC-202 VLT Aqua Series and FC-102 VLT HVAC Series, AAF Advanced Active Filters.

Requirements:

Bureau Veritas Rules for the Classification of Steel Ships.

This certificate is issued to attest that Bureau Veritas Marine & Offshore did undertake the relevant approval procedures for the product identified above which was found to comply with the relevant requirements mentioned above.

This certificate will expire on: 07 Jan 2021

For Bureau Veritas Marine & Offshore,

At BV PORT EVERGLADES CENTRE, on 13 Sep 2017,

Flavio Rosas



This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with Bureau Veritas Marine & Offshore. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. This certificate is issued within the scope of the General Conditions of Bureau Veritas Marine & Offshore available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas Marine & Offshore for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

The electronic version is available at: <http://www.veristarnb.com/veristarnb/jsp/viewPublicPdfTypepec.jsp?id=xawofeqml3>

BV Mod. Ad.E 530 June 2017

This certificate consists of 14 page(s)

THE SCHEDULE OF APPROVAL

1. PRODUCT DESCRIPTION:

- Product model or type designation:

FC-102, FC-202, FC-302, AAF006 series

- Product description:

Frequency Converters

1.1 Frequency Converters

1.1.1 FC-102 VLT HVAC Drive Series:

FC-102 380-480V (T4)

Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
110	D3h	NA	D1h/D5h/D6h	D1h/D5h/D6h
132				
160				
200	D4h	NA	D2h/D7h/D8h	D2h/D7h/D8h
250				
315				
355	E3h	E2	E1/E1h	E1/E1h
400				
450				
500	E4h	NA	F1/F3/E2h	F1/F3/E2h
560	E4h	NA	F1/F3/E2h	F1/F3/E2h
630	NA	NA	F1/F3	F1/F3
710	NA	NA	F1/F3	F1/F3
800	NA	NA	F2/F4	F2/F4
1M0				

FC-102 525-690V (T7)

Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
75	D3h	NA	D1h/D5h/D6h	D1h/D5h/D6h
90				
110				
132				
160				
200	D4h	NA	D2h/D7h/D8h	D2h/D7h/D8h
250				
315				
400				
450				
	E3h	E2	E1/E1h	E1/E1h

1.1.1 FC-102 VLT HVAC Drive Series (continued):

FC-102 525-690V (T7)

Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
500 560 630	E3h	E2	E1/E1h	E1/E1h
710 800 900	E4h E4h NA	NA	F1/F3/E2h F1/F3/E2h F1/F3	F1/F3/E2h F1/F3/E2h F1/F3
1M0 1M2 1M4	NA	NA	F2/F4	F2/F4

FC-102 380-480V (T4) 12-Pulse Drives

Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
315 355 400 450	NA	F8/F9	F8/F9
500 560 630 710	NA	F10/F11	F10/F11
800 1M0	NA	F12/F13	F12/F13

FC-102 525-690V (T7)

Power rating [kW]	Enclosure type		
	IP00(*1)	IP21 (*2)	IP54 (*3)
450 500 560 630	NA	F8/F9	F8/F9
710 800 900	NA	F10/F11	F10/F11
1M0 1M2 1M4	NA	F12/F13	F12/F13

FC-102 380-480V (T4) Low Harmonic Drives

Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
160 200 250	NA	D1n D2n	D1n D2n
315 355 400 450	NA	E9	E9
500 560 630 710	NA	F18	F18

1.1.2 FC-202 VLT AQUA Drive Series:

FC-202 380-480V (T4)

Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
110	D3h	NA	D1h/D5h/D6h	D1h/D5h/D6h
132				
160				
200				
250	D4h	NA	D2h/D7h/D8h	D2h/D7h/D8h
315				
355				
400	E3h	E2	E1/E1h	E1/E1h
450				
500	E4h	NA	F1/F3/E2h	F1/F3/E2h
560	E4h		F1/F3/E2h	F1/F3/E2h
630	NA		F1/F3	F1/F3
710	NA		F1/F3	F1/F3
800	NA	NA	F2/F4	F2/F4
1M0				

FC-202 525-690V (T7)

Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
75	D3h	NA	D1h/D5h/D6h	D1h/D5h/D6h
90				
110				
132				
160				
200	D4h	NA	D2h/D7h/D8h	D2h/D7h/D8h
250				
315				
400				
450	E3h	E2	E1/E1h	E1/E1h
500				
560				
630				

1.1.2 FC-202 VLT AQUA Drive Series (continued):

FC-202 525-690V (T7)

Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
710	E4h	NA	F1/F3/E2h	F1/F3/E2h
800	E4h		F1/F3/E2h	F1/F3/E2h
900	NA		F1/F3	F1/F3
1M0	NA	NA	F2/F4	F2/F4
1M2				
1M4				

FC-202 380-480V (T4) 12-Pulse Drives

Power rating [kW]	Enclosure type		
	IP00(*1)	IP21 (*2)	IP54 (*3)
315			
355			
400	NA	F8/F9	F8/F9
450			
500			
560			
630	NA	F10/F11	F10/F11
710			
800	NA	F12/F13	F12/F13
1M0			

FC-202 525-690V (T7)

Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
450			
500			
560	NA	F8/F9	F8/F9
630			
710			
800	NA	F10/F11	F10/F11
900			
1M0			
1M2	NA	F12/F13	F12/F13
1M4			

FC-202 380-480V (T4) Low Harmonic Drives

Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
160	NA	D1n	D1n
200	NA	D2n	D2n
250			
315			
355			
400	NA	E9	E9
450			
500			
560			
630	NA	F18	F18
710			

1.1.3 FC-302 VLT Automation Drive Series:

FC-302: 380-500V (T5)

Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
90	D3h	NA	D1h/D5h/D6h	D1h/D5h/D6h
110				
132				
160	D4h	NA	D2h/D7h/D8h	D2h/D7h/D8h
200				
250				
315	E3h	E2	E1/E1h	E1/E1h
355				
400				
450	E4h	NA	F1/F3/E2h	F1/F3/E2h
500	E4h		F1/F3/E2h	F1/F3/E2h
560	NA		F1/F3	F1/F3
630	NA		F1/F3	F1/F3
710	NA	NA	F2/F4	F2/F4
800				

FC-302 525-690V (T7)

Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
55	D3h	NA	D1h/D5h/D6h	D1h/D5h/D6h
75				
90				
110				
132				
160	D4h	NA	D2h/D7h/D8h	D2h/D7h/D8h
200				
250				
315	E3h	E2	E1/E1h	E1/E1h
355				
400				
500				
560				

1.1.3 FC-302 VLT Automation Drive Series (continued):

FC-302 525-690V (T7)				
Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
630	E4h	NA	F1/F3/E2h	F1/F3/E2h
710	E4h	NA	F1/F3/E2h	F1/F3/E2h
800	NA	NA	F1/F3	F1/F3
900	NA	NA	F2/F4	F2/F4
1M0	NA	NA	F2/F4	F2/F4
1M2	NA	NA	F2/F4	F2/F4
FC-302 380-500V (T5)				
12-Pulse Drives				
Power rating [kW]	Enclosure type			
	IP00(*1)	IP21 (*2)	IP54 (*3)	
250	NA	F8/F9	F8/F9	
315	NA	F8/F9	F8/F9	
355	NA	F8/F9	F8/F9	
400	NA	F8/F9	F8/F9	
450	NA	F10/F11	F10/F11	
500	NA	F10/F11	F10/F11	
560	NA	F10/F11	F10/F11	
630	NA	F10/F11	F10/F11	
710	NA	F12/F13	F12/F13	
800	NA	F12/F13	F12/F13	
FC-302 525-690V (T7)				
Power rating [kW]	Enclosure type			
	IP00(*1)	IP21 (*2)	IP54 (*3)	
355	NA	F8/F9	F8/F9	
400	NA	F8/F9	F8/F9	
500	NA	F8/F9	F8/F9	
560	NA	F8/F9	F8/F9	
630	NA	F10/F11	F10/F11	
710	NA	F10/F11	F10/F11	
800	NA	F10/F11	F10/F11	
900	NA	F12/F13	F12/F13	
1M0	NA	F12/F13	F12/F13	
1M2	NA	F12/F13	F12/F13	
FC-302 380-500V (T5)				
Low Harmonic Drives				
Power rating [kW]	Enclosure type			
	IP00 (*1)	IP21 (*2)	IP54 (*3)	
132	NA	D1n	D1n	
160	NA	D2n	D2n	
200	NA	D2n	D2n	
250	NA	E9	E9	
315	NA	E9	E9	
355	NA	E9	E9	
400	NA	E9	E9	
450	NA	F18	F18	
500	NA	F18	F18	
560	NA	F18	F18	
630	NA	F18	F18	

- (*1) IP 00/IP20: Panel mount.
- (*2) IP 21: NEMA Type 1
- (*3) IP 54: NEMA Type 12

Limitations: Converters which exceed the limits for radiated and conducted emissions of IACS E10 can be installed in "special power distribution zone" according to IEC 60533. For installations in "general distribution zone" measures must be taken to attenuate the effects on the distribution system. Planned EMC measures according to IEC 60533 shall be assessed prior to installation on board.

Ruggedized boards selection "R" in character 20 must be selected where applicable.

Selection types for Type Codes for FC-102 / FC-202 / FC-302

----- (character 24 – 39 software + options)
 1 4 7 10 11 23

Basic string definitions:

- *Product Group (character 1-3)*

FC-: Adjustable Frequency Converters

- *VLT series (character 4-6)*

102: VLT HVAC Drive – Advanced version

202: VLT AQUA Drive – Advanced version

302: VLT Automation Drive – Advanced version

- *Power size (character 7-10)*

P: Power (standard design)

P110: 110 kW / 150 HP

N110: 110 kW / 150 HP

- *Voltage: (character 11-12)*

T4: Three phase 380-480 VAC

T5: Three phase 380-500 VAC

T7: Three Phase 525-690 VAC

- *Enclosure (character 13-15)*

“C” units with corrosion resistant back channel:

C00: IP00 / Chassis

C20: IP20 / Chassis

C21: IP21 / (NEMA) Type 1

C2H: IP21 / (NEMA) Type 1 + heater

C54: IP54 / (NEMA) Type 12

C5H: IP54 / (NEMA) Type 12 + heater

C2M: IP21 / (NEMA) Type 1 + Mains Shield

C5M: IP54 / (NEMA) Type 12 + Mains Shield

“E” & “H” units denote standard sized variants:

E00: IP00 / Chassis

E20: IP20 / Chassis

E21: IP21 / (NEMA) Type 1

E54: IP54 / (NEMA) Type 12

E5S: IP54 / (NEMA) Type 12 Stainless Steel screws + heater

E2M: IP21 / (NEMA) Type 1 + mains shield

E5M: IP54 / (NEMA) Type 12 + mains shield

H21: IP21 / (NEMA) Type 1 + heater

H54: IP54 / (NEMA) Type 12 + heater

-
- *Hardware (character 16-23)*
Hardware, RFI filter (character 16-17)
 - H2: 6 Pulse Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)
 - H4: 6 Pulse Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)
 - B2: 12 Pulse Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)
 - B2: 12 Pulse Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)
 - N2: Low Harmonic Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)
 - N4: Low Harmonic Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

Hardware, Brake & Stop, (character 18)

Hardware, Display (character 19)

Hardware, Coating (character 20)

Hardware, Mains options (character 21)

Hardware, adaptation A (character 22)

Hardware, adaptation B (character 23)

- *Software (character 24-28)*

Options – A (character 29-30)

Options – B (character 31-32)

Options – C (character 33-37)

Options – D (character 38-39)

- *Brand labelling and customer specific definitions:*

Brand labelling and customer specific drives are following the type codes except the characters 1-6 for product group and VLT series. Character 1-6 are used for customer specific definitions.

Basic string definitions for brand labelling and customer specific drives:

Product Group and VLT series (character 1-6)

- AF-600:	Equal to FC-102
- AKD102:	Equal to FC-102
- ADS102:	Equal to FC-102
- IVS102:	Equal to FC-102
- TR-200:	Equal to FC-102
- ITT102:	Equal to FC-102
- CUE202:	Equal to FC-202
- FC-322:	Equal to FC-202
- LD-302:	Equal to FC-302
- IR-302:	Equal to FC-302
- IRV302:	Equal to FC-302
- CD-302:	Equal to FC-302
- MWU302:	Equal to FC-302
- CDS302:	Equal to FC-302
- DV-302:	Equal to FC-302
- 3G3DV:	Equal to FC-302
- LB-302:	Equal to FC-302
- AFE302:	Equal to FC-302
- AF-650:	Equal to FC-302
- FCK302:	Equal to FC-302
- FC-312:	Equal to FC-302
- FC-103:	Equal to FC-102

1.2 Active Filter : Model VLT Active Filter AAF006

AAA006: 380-480 (T4)					
Current rating (Amps)	Enclosure type				RFI filter Type (*4)
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)	
190	NA	NA	D14	D14	HX**
250	NA	NA	E1	E1	
310					
400					

(*1) IP 00/IP20: Panel mount.

(*2) IP 21: NEMA Type 1

(*3) IP 54: NEMA Type 12

(*4) HX: Active Filter RFI for Maritime complies with IACS E10 requirements except radiated and conducted emissions.

***Limitations:* Filters which exceed the limits for radiated and conducted emissions of IACS E10 can be installed in "special power distribution zone" according to IEC 60533. For installations in "general distribution zone" measures must be taken to attenuate the effects on the distribution system. Planned EMC measures according to IEC 60533 shall be assessed prior to installation on board.

Selection types for Type Codes for AAF006 Active Filters

_____ (character 24 – 39 software + options)
 1 4 7 10 11 23

Basic string definitions:

- *Product Group (character 1-3)*

AAF: Active Filters

- *VLT series (character 4-6)*

006: VLT Active Filter - Series 6

- *Current rating (character 7-10)*

A190: 190 Amp

- *Voltage: (character 11-12)*

T4: Three phase 380-480 VAC

- *Enclosure (character 13-15)*

E21: IP 21 / Type 1

E54: IP 54 / Type 12

E2M: IP21/Type 1 with mains shield

E5M : IP54/ Type 12 with mains shield

- *Hardware (character 16-23)*

Hardware, RFI filter (character 16-17)

- *Software (character 24-28)*

Options – A (character 29-30)

Options – B (character 31-32)

Options – C (character 33-37)

Options – D (character 38-39)

For B2 Version

VLT® HVAC Drive FC-102 (FC-102N355T4 – FC-102N560T4; FC-102N450T7 – FC-102N800T7)

VLT® AQUA Drive FC-202 (FC-202N355T4 – FC-202N560T4; FC-202N450T7 – FC-202N800T7)

VLT® Automation Drive FC-302 (FC-302N315T5 – FC-302N500T5; FC-302N355T7 – FC-302N710T7)

1.3 Enclosure Power Ratings and Dimensions for standard configurations

Enclosure size	E1h	E2h	E3h	E4h
Rated Power at 380-480 V [(kW (hp))]	355-450 (500-600)	500-560 (650-750)	355-450 (500-600)	500-560 (650-750)
Rated Power at 525-690 V [(kW (hp))]	450-630 (450-650)	710-800 (750-950)	450-630 (450-650)	710-800 (750-950)
Enclosure protection rating	IP21/Type 1 IP54/Type 12	IP21/Type 1 IP54/Type 12	IP20/ Chassis	IP20/ Chassis
Unit dimensions				
Height [mm (in)]	2043 (80.4)	2043 (80.4)	1578 (62.1)	1578 (62.1)
Width [mm (in)]	602 (23.7)	698 (27.5)	506 (19.6)	604 (23.89)
Depth [mm (in)]	513 (20.2)	513 (20.2)	482 (19.0)	482 (19.0)
Weight [kg (lb)]	295 (650)	318 (700)	272 (600)	295 (650)
Shipping dimensions				
Height [mm (in)]	768 (30.2)	768 (30.2)	746 (29.4)	746 (29.4)
Width [mm (in)]	2191 (86.3)	2191 (86.3)	1759 (69.3)	1759 (69.3)
Depth [mm (in)]	870 (34.3)	870 (34.3)	794 (31.3)	794 (31.3)
Weight [kg (lb)]	-	-	-	-
Enclosure size	E1h	E2h	E3h	E4h
Rated Power at 380-500 V [(kW (hp))]	315-400 (450-550)	450-500 (600-650)	315-400 (450-550)	450-500 (600-650)
Rated Power at 525-690 V [(kW (hp))]	355-560 (400-600)	630-710 (650-950)	355-560 (400-600)	630-710 (650-950)
Enclosure protection rating	IP21/Type 1 IP54/Type 12	IP21/Type 1 IP54/Type 12	IP20/ Chassis	IP20/ Chassis
Unit dimensions				
Height [mm (in)]	2043 (80.4)	2043 (80.4)	1578 (62.1)	1578 (62.1)
Width [mm (in)]	602 (23.7)	698 (27.5)	506 (19.6)	604 (23.89)
Depth [mm (in)]	513 (20.2)	513 (20.2)	482 (19.0)	482 (19.0)
Weight [kg (lb)]	295 (650)	318 (700)	272 (600)	295 (650)
Shipping dimensions				
Height [mm (in)]	768 (30.2)	768 (30.2)	746 (29.4)	746 (29.4)
Width [mm (in)]	2191 (86.3)	2191 (86.3)	1759 (69.3)	1759 (69.3)
Depth [mm (in)]	870 (34.3)	870 (34.3)	794 (31.3)	794 (31.3)
Weight [kg (lb)]	-	-	-	-

2. DOCUMENTS AND DRAWINGS:

Documentation, drawings and schematics stored in AP 4153.

List of updated drawings :

- Block diagram HP12027 N°177R0040 Rev.4, dated 02/10/2012
- Block diagram HP12027 N°177R0043 Rev.5, dated 02/10/2012
- Block diagram HP12027 N°177R0044 Rev.5, dated 02/10/2012
- Block diagram HP12027 N°177R0041 Rev.4, dated 02/10/2012
- Block diagram HP12027 N°177R0045 Rev.5, dated 02/10/2012
- Mounting Def. HP10064 N°175R5959 Rev.4, dated 07/29/2012
- Terminal def. HP09039 N°175R5960 Rev.A, dated 04/09/2009, sheets 1/2, 2/2
- Block diagram HP10081 N°177R0042 Rev.B, dated 12/02/2010
- Block diagram HP10081 N°177R0046 Rev.C, dated 12/02/2010
- Block diagram HP12229 N°177R0048 Rev.12, dated 11/12/2015
- Block diagram HP12007 N°177R0162 Rev.3, dated 01/16/2012
- Block diagram HP12229 N°177R0197 Rev.5, dated 11/12/2015
- Rect. Terminal Def. HP11258 N°177R0034 Rev.3, dated 12/21/2011
- Rect. Terminal Def. HP11258 N°177R0035 Rev.4, dated 07/16/2015
- Opt. Terminal Def. HP11258 N°177R0036 Rev.3, dated 12/22/2011
- Terminal def. HP11258 N°177R0037 Rev.4, dated 07/14/2015

List of updated drawings 23444/A2:

- DWG, REF, SHIELDS, EMC, OPT, DI, P454 N°177R0491 Rev.001, dated 06/15/12
- Installation drawing, D8H, IP21/54 N°177R0493 Rev.001, dated 06/18/12

List of updated drawings 23444/A3:

- Mounting def. HP11054 N°177R0029 Rev.7, dated 06/27/2013

List of updated drawings 23444/B0:

- Mounting def. HP10119 No.175R5955 Rev.5, dated 03/10/2014
- Terminal def. HP09079 No.175R5961 Rev.3, dated 10/18/2013
- Installation drawing, D1H, IP21/54 No.177R0374 Rev.004, dated 11/27/2012
- Installation drawing, D2H, IP21/54 No.177R0375 Rev.003, dated 10/07/2013
- Installation drawing, D3H, IP20/CHASSIS No.177R0339 Rev.003, dated 01/21/2014
- Installation drawing, D4H, IP20/CHASSIS No.177R0340 Rev.002, dated 11/21/2012
- Installation drawing, D5H, IP21/54 No.177R0490 Rev.004, dated 02/05/2015
- Installation drawing, D7H, IP21/54 No.177R0492 Rev.005, dated 01/06/2015
- INST, MTG, SERIES 6, AAF190, D FRAME No.177R0349 Rev.002, dated 03/14/2014
- INST, MTG, SERIES 6, LHD120, D FRAME No.177R0350 Rev.003, dated 09/05/2014
- INST, MTG, SERIES 6, AAF310 E FRAME No.177R0351 Rev.002, dated 03/13/2014
- INST, MTG, SERIES 6, LHD210 E FRAME No.177R0352 Rev.005, dated 01/29/2015
- INST, MTG, SERIES 6, LHD330 F FRAME No.177R0354 Rev.005, dated 07/16/2015
- Block diagram D-FRAME No. 177R0433 Rev.5, dated Aug 25, 2014
- Block diagram D-FRAME INVERTER ONLY No. 177R0489 Rev.1, dated Oct 21, 2013

For modification B2 version:

- Drawing No: 177R0659, dated 15 Sep 2017
- Drawing No: 177R0676, dated 25 Jan 2017
- Drawing No: 177R0673, dated 25 Jan 2017
- Drawing No: 177R0674, dated 25 Jan 2017
- Drawing No: 177R0675, dated 25 Jan 2017
- Operating Guide VLT HVAC Drive FC 102, 355-800kW, dated Jan 2017
- Operating Guide VLT AQUA Drive FC 202, 355-800kW, dated Jan 2017
- Operating Guide VLT Automation Drive FC 302, 315-710kW, dated Jan 2017
- Danfoss Product overview complete Marine approval, dated 23 Mar 2017

3. TEST REPORTS:

- Laboratory Data Package Performance Test Report ULS-005008C-NMMS-2002 dated 24/01/2001
- NTS Vibration Test Report A9182 dated 9/12/2009
- Delta EMC test report DANAK 19K0441 dated 02/03/2007
- Danfoss LLC EMC Test Report P407-151_R0126T01v100b dated 09/03/2007
- Danfoss LLC EMC Test Report P407-151_R0126T02v100a dated 09/03/2007
- Danfoss LLC EMC Test Report P407-154_R0126T05v100a dated 09/03/2007
- Danfoss LLC EMC Test Report P408-83_R0134T04v200a dated 15/11/2007
- Danfoss LLC EMC Test Report P408-90_R0134T02v200a dated 03/05/2007
- Danfoss LLC EMC Test Report P408-89_R0134T01v200a dated 07/05/2007
- Danfoss LLC EMC Test Report P408-88_R0131T01v100b dated 10/04/2007
- Danfoss LLC EMC Test Report P408-85_R0134T09v100 dated 01/05/2007
- Danfoss LLC EMC Test Report P408-84_R0134T05v210a dated 02/05/2007
- Danfoss LLC EMC Test Report P408-82_R0134T05v100b dated 17/04/2007
- Danfoss LLC EMC Test Report P408-81_R0132T03v100c dated 29/05/2007
- Danfoss LLC EMC Test Report P408-80_R0132T02v100a dated 16/04/2007
- Danfoss LLC EMC Test Report P408-79_R0132T01v100b dated 16/04/2007
- Danfoss LLC EMC Test Report P408-90_R0134T02v200a dated 03/05/2007
- Danfoss LLC EMC Test Report P408-78_R0131T02v100a dated 29/05/2007

List of updated Test Reports 23444/A2:

- Danfoss LLC Damp Heat Test Report No.00705181 Rev.A3, dated 2011-11-12.
- Danfoss LLC EMC F302-N132T5 Test Report No.00705683 Rev.A14, dated 2012-09-27.
- Danfoss LLC EMC F302-N132T7 Test Report No.00708506 Rev.A7, dated 2012-09-27.
- Danfoss LLC EMC F302-N250T5 Test Report No.00705781 Rev.A9, dated 2012-09-27.
- Danfoss LLC EMC F302-N315T7 Test Report No.00708507 Rev.A6, dated 2012-09-27.
- Danfoss LLC EMC F302-N132T5 Test Report "Power Quality Tests-D1 v1_0.docx" Rev.A14, dated 2011-12-07.
- Danfoss LLC EMC F302-N132T7 Test Report "Power Quality Tests-D1T7 v1_0.docx" Rev.A14, dated 2012-06-06.
- Danfoss LLC EMC F302-N250T5 Test Report "Power Quality Tests-D2 v1_0.docx" Rev.A14, dated 2011-12-07.
- Danfoss LLC EMC F302-N315T7 Test Report "Power Quality Tests-D2T7 v1_0.docx" Rev.A14, dated 2012-06-06.
- DATASYST Vibration Test Report D15-14976, dated 2012-02-20.
- Danfoss LLC Vibration Test Report No.00707038 Rev.A3, dated 2012-10-24.

For modification B1 version:

- P7020 LHD-D Frame, Visual inspection for Power Drive Systems No.00724479 Rev.2.20, dated Jan 18, 2010
- LAB DATA PACKAGE - Performance Test No.4786469180, dated Sep 4, 2014
- LAB DATA PACKAGE - Performance Test No.11NK14834, dated Nov 10, 2011
- Danfoss - Performance Test No.tr7020_PTP_Input_THD_LHD_N200, dated Jul 30, 2014
- Danfoss - AC Line loss Test No. tr7020 PTP ACLoss N200T5, dated Nov 9, 2014
- Danfoss - Measure Inrush Current Test No. tr7020 PTP Inrush Switch ON Mains N200T5, dated Oct 6, 2014
- Danfoss - P200T5 Unit Initialization Time Test No. tr7020_PTP_Unit_Initialization_Time_P200T5, dated Feb 6, 2014
- Danfoss - N132T5 Four Quadrant Operation Test No. tr454 PTP 4 Quadrant Operation N132T5, dated Feb 11, 2011
- Danfoss - N250T5 Four Quadrant Operation Test No. tr454 PTP 4 Quadrant Operation N250T5, dated Oct 31, 2011
- Danfoss - N132T5 Torque Speed Curves and Starting Torque Test No. tr454 PTP Torque Speed Curve N132T5, dated Aug 25, 2011
- Danfoss - P250T5 Torque Speed Curves and Starting Torque Test No. tr454 PTP Torque Speed Curve N250T5, dated Aug 23, 2011
- Danfoss - P250T5 P7020 LHD120N200 test No. tr7020_PTP_Input_THD_LHD_N200, dated Jul 30, 2014
- Danfoss - Marine Dry Heat Test Report for 132-200kW LHD-120 No. 00720712, dated Jul 8, 2015
- UL India Lab - Damp Heat Test Report for LHD-120 No. 4786962025-S1-2, dated Jul 9, 2015
- Danfoss - Marine Damp Heat Test Report for 132-200kW LHD-120 No. 00726257, dated Jul 10, 2015
- Elite - Environmental Tests on P7020 LHD120 Drive No. 1401064-01, Rev. A, dated Jun 17, 2014
- Danfoss - Vibration Test Report for P7020 LHD120 No. 00720571, dated Jul 8, 2015
- UL India Lab - Cold Test Report for LHD-120 No. 4786962025-S1-1, dated Jul 9, 2015
- Danfoss - Cold Test Report for P7020 LHD120 No. 00726256, dated Jul 10, 2015
- Elite - EMC Tests on LHD120 Drive System No. 1401200-01 Rev. C, dated Jan 12, 2015
- Elite - EMC Tests on LHD120 Drive System No. 1402112-01 Rev. B, dated Nov 12, 2014
- Danfoss - EMC Engineering Test Report for Product "P454-2, D1 frame." No. Power Quality Tests -D1 v1_0, dated Jan 2012
- Danfoss - EMC Engineering Test Report for Product "P454-2, D2 frame." No. Power Quality Tests -D2 v1_0, dated Jan 2012
- NTS ROCKFORD- EMC Tests on LHDP200 No. CTR-II-0125 Rev. B, dated Aug 24, 2011

For modification B2 version:

- Danfoss - Marine 45 Temperature Rise data Report No: 00735840, dated 27 Mar 2017
- Danfoss - VLT Laboratory Report N710T7 , dated 18 Dec 2016
- P4001 Operating Guide Next Gen E-Frame- Visual inspection for power drive systems, dated 18 Jan 2017
- Danfoss Laboratory report N710T7 Four Quadrant Operation, dated 18 Dec 2016
- Danfoss Laboratory report N400T5 Four Quadrant Operation, dated 06 Sep 2016
- Danfoss Laboratory report N500T5_N710T7 Insulation Resistance Test, dated 09 Dec 2016
- DATASYST Engineering & Testing Services, Inc. Vibration Testing of E2 and E4 drives No: D15-17445, dated 17 Aug 2016

4. APPLICATION / LIMITATION:

- 4.1 - According to BV Rules for the Classification of Steel Ships
- 4.2 Approval valid for ships intended to be granted with the following additional class notations: **AUT-UMS, AUT-CCS, AUT-PORT and AUT-IMS.**
- 4.3 - The equipment, once installed on board ship, is to be tested in accordance with the above referred Regulations under the supervision of a Society's Surveyor.
- 4.4 - Converters with conducted and radiated emission above the BV required limits can be installed in "special distribution zone" and "general power distribution zone", in accordance with IEC 60533 provided measures are taken to attenuate these effects on the distribution system, so safe operation is assured. Planned EMC measures shall be submitted for approval prior installation onboard.

5. PRODUCTION SURVEY REQUIREMENTS:

- 5.1 - The above products are to be supplied by **DANFOSS LLC** in compliance with the type and the requirements described in this certificate.
- 5.2 - This type of product is within the category IBV of Bureau Veritas Rule Note NR320.
- 5.3 - BV product certificate is required.

6. MARKING OF PRODUCT:

- Maker's name or trade mark.
- Serial number of the units.
- Equipment type number or model identification under which it was type-tested.
- @ or \ conformity marking, as relevant

7. OTHERS:

- 7.1 - It is **DANFOSS LLC, Loves Park, IL USA's** responsibility to inform shipbuilders or their sub-contractors of the proper methods of fitting, use and general maintenance of the approved equipment and the conditions of this approval.
- 7.2 - This Certificate supersedes the Type Approval Certificate No.23444/B1 BV issued on 02 Sep 2016 by the Society.

*** END OF CERTIFICATE ***