



7000

tonnes per year
less CO₂ emission
after transition to
electric-driven
ferries

ENGINEERING
TOMORROW

Danfoss

Case story | VACON® NXP Grid Converter

Where smart ferry charging begins with a smart grid

The situation

NORWAY: The Hareid-Sulesund ferry operator has reduced CO₂ emissions by 7000 tonnes annually with the introduction of electric vessels. In transitioning ferries from diesel to pure electric power, powerful onshore support is essential, in the form of reliable infrastructure for rapid charging capacity and stable grid supply. The systems on board and on shore act as a single system – a sophisticated and competitive system developed by Norwegian Electric Systems (NES) using Danfoss technology.

Norwegian Electric Systems AS is a total supplier of low-emission, sustainable energy design and smart control for a wide range of vessels for the global marine market. NES designs optimal propulsion systems for vessels and control systems to ensure safety via smart and easy operation.

The challenge

Calculations at both ferry terminals showed that the existing power grid required extra power to achieve the necessary charging power to rapidly charge the vessel in the 6 minutes turnaround time available. NES strengthened the power grid on both sides, and retrofitted vessels with batteries and the newest converter and power control technology, for the optimal electric-powered solution.

The solution

Håvard Wolden from Danfoss explains: "The electric ferry charges 350 kWh of power in just 6 minutes. This scale of charging places stringent demands upon the smart grid onshore in Hareid and Sulesund, which supports reliable power supply for the electric vessel rapid charging system.

NES supplemented the onshore power supply with battery storage systems powered by Danfoss grid converters, to ensure adequate charging capacity and speed. The electricity used to supply the system is supplied from renewable sources, to minimize losses and optimize operating costs."

During charging, the vessel accumulates 5 MW power, comprising 3 MW from the local AC grid and 2 MW from the combined power of onshore batteries.

The outcome

By actively controlling, monitoring, and supporting the grid from local batteries on shore side, the system supplies the high peak power crucial to rapid charging, with no need to scale up grid infrastructure. Instead of extra capital investment, the system relies on peak shaving functionality.

In total, the charging stations on this ferry route perform about 32,000 charging operations and transfer approximately 11200 MWh of electric power per year.

"The charging system reduces peak power consumption by drawing on shore battery power instead of energy from the grid... for example, when the electricity price is high."

Torbjørn Haugland, Vice-President of Energy Design at Norwegian Electric Systems

Any information, including, but not limited to information on selection of product, its application or use, product design, weight, dimensions, capacity or any other technical data in product manuals, catalogues descriptions, advertisements, etc. and whether made available in writing, orally, electronically, online or via download, shall be considered informative, and is only binding if and to the extent, explicit reference is made in a quotation or order confirmation. Danfoss cannot accept any responsibility for possible errors in catalogues, brochures, videos and other material. Danfoss reserves the right to alter its products without notice. This also applies to products ordered but not delivered provided that such alterations can be made without changes to form, fit or function of the product. All trademarks in this material are property of Danfoss A/S or Danfoss group companies. Danfoss and the Danfoss logo are trademarks of Danfoss A/S. All rights reserved.

