



Lloyd's
Register

Type Approval Certificate Extension


This is to certify that Certificate No. 10/70021(E1) for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER	Danfoss Power Electronics A/S	
PLACE OF PRODUCTION	Danfoss Power Electronics A/S Ulsnæs 1 DK-6300 Graasten Denmark	Danfoss LLC 4401 N Bell School Rd Loves Park, IL USA 61111
DESCRIPTION	Frequency converters for speed control of squirrel cage motors - 3-phase, 50/60 Hz - at line voltages 200V-690V - in power range of 0.25 kW-1.4MW with options for Low Harmonic Drives and extended options cabinet EOC.	
TYPE	FC-102: Adjustable Frequency Converter VLT® HVAC Drive FC-202: Adjustable Frequency Converter, VLT® AQUA Drive FC-302: Adjustable Frequency Converter, VLT® Automation Drive AAF006: Stand-alone Advanced Active Filter series 006	
APPLICATION	Marine, Offshore and Industrial applications in environmental categories ENV1, ENV2, defined in LR Test Specification No.1: 2002 where the Test Specification is applicable for the service.	
STANDARD	LR Rules and Regulations for the Classification of Ship: 2010, Part 6, Ch2 IEC60533 IEC60529	

Certificate No.	10/70010(E2)
Issue Date	23 July 2014
Expiry Date	22 July 2019
Sheet	1 of 4

Lloyd's Register EMEA
Strandvejen 104A, DK-2900 - Hellerup


Jacob Munk Plum
Copenhagen Tech. Support Office

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

RATINGS

Power sizes	1.1kW – 1.4MW
Volt 3-ph, 50-60Hz	T2: 200-240V - T4: 380-480V - T5: 380-500V - T7: 525-690V
Enclosure Types	See SPECIFICATION – Specification key below
Hardware, RFI Filter	See SPECIFICATION – Specification key below

SPECIFICATION

Specification key for FC-102 Drives:

FC - 1 0 2 -----
1 4 7 11 13 16 24 39

Specification Key for FC 202 Drives

FC - 2 0 2 -----
1 4 7 11 13 16 24 39

Specification Key for FC 302 Drives:

FC - 3 0 2 -----
1 4 7 11 13 16 24 39

Specification Key for AAF 006 Advanced Active Filter:

AAF 0 0 6 -----
1 4 7 11 13 16 24 39

Char no	Specification	Options
1-3	Frq Converter	FC-
4-6	Advanced Active Filter VLT series	AAF- 102 for VLT HVAC Drive Advanced version 202 for VLT AQUA Drive Advanced version 302 for VLT Automation Drive Advanced version
7	Advanced Active Filter VLT Versions	006 N, or P
8-10	Advanced Active Filter VLT Power Size AAF Power Size	A 0.25 kW-1.4 MW 190, 250, 310, 400 (indicates the current)
11-12	VLT Voltage range	T2: 200-240 - T4: 380-480 - T5: 380-500 - T7: 525-690
13-15	Advanced Active Filter VLT enclosures	T4: 380-480V E00:IP00/Chassis E20: IP20/Chassis E2S:IP/Chassis /medium power D-Frame) E21: IP21/Type 1 E2D: IP21/Type 1 (medium power D-Frame) H21:IP21/Type 1 with heater E54: IP54/Type 12 H54/Type 12 with heater E5H: for Hybrid IP54 E2M: IP20/Type 1 with mains shield E5M:IP54/Type 12 with mains shield ESD: IP54/Type 12 (medium power D-Frame) E21: IP21/Type 1

Certificate No.

10/70010(E2)

Issue Date


23 July 2014

Expiry Date

22 July 2019

Sheet

2 of 4



Jacob Munk Plum
Copenhagen Tech. Support Office

Lloyd's Register EMEA
Strandvejen 104A, DK-2900 - Hellerup

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

		E2M: IP21/Type 1 with mains shield
Char no	Specification	Options
13-15		E54: IP54
		E5M: IP54 with mains shield
16-17	VLT RFI Filter	H2/H4: 6-Pulse Drive RFI for Maritime comply with Test Spec No1:2002 except for rad. and conducted emission (see OTHER CONDITIONS)
		B2: 12-Pulse Drive w RFI for Maritime, comply with Test Spec No1:2002 except for rad. and conducted emission. (see OTHER CONDITIONS)
		L2: Low Harmonics Drive w/ RFI for Maritime complies with Test Spec No1:2002 except for rad. and conducted emission (see OTHER CONDITIONS)
		N2: Low Harmonics Drive w/ RFI for Maritime complies with Test Spec No1:2002 except for rad. and conducted emission. (see OTHER CONDITIONS)
	Advanced Active Filter	HX: Active filter comply LR TA Spec No.1 except for radiated and conducted emissions. (see OTHER CONDITIONS)
18	VLT hardware	B: Brake chopper
	Advanced Active Filter	X (none)
19	VLT hardware	Display
	Advanced Active Filter	G: graphical display
20	VLT hardware	Coating: C: Coating; R: Ruggedized boards (required for D1h-D8h enclosures)
	Advanced Active Filter	C: Coated boards
21	VLT hardware	1: Mains disconnect -2: Mains contactor -3: Mains disconnect+fuses-4: Mains contactor +fuse
		E: Mains disconnect, contactor and fuse
		J: Mains circuit breaker and fuse
	Advanced Active Filter	X: None - 3: Disconnectors + fuses - 7: Fuses
22	VLT hardware	Adaptation for power terminals
	RFI	Reserved
23	VLT hardware	Options for 24Vdc input for control voltage
24-28	Software Options	
29-30	VLT options	A: Options for field bus
31-32	VLT options	B: I-O options
33-37	VLT options	C: Motion control options
38-39	VLT options	D: External control power input
	Advanced Active Filter	DX: no D option - DO: 24V backup

For types FC-102 & FC-202 stated shaft power is defined @ 110% normal overload/variable torque.


For type FC-302 the stated shaft power is defined at 160% high overload/constant torque.

Certificate No. 10/70010(E2)

Issue Date 23 July 2014

Expiry Date 22 July 2019

Sheet 3 of 4



Jacob Munk Plum
Copenhagen Tech. Support Office

Lloyd's Register EMEA
Strandvejen 104A, DK-2900 - Hellerup

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

At high overload 160% torque, de-rate output current with 1%/°C, at ambient temperatures 45-55°.

At normal overload 110% torque, de-rate output current by 1.5%/°C @ ambient temperature 45-55°.

Overview of possible combinations of converter type & rating/enclosure types/ please consult the Danfoss literature.

OTHER CONDITIONS


- Screened cables are to be applied between Motor and Converter.
 - Test of software is limited to demonstration of correct function during Type Approval testing.
 - Converters for installation in LR Classed vessels shall comply with the requirements of Part 6, Chapter 2, section 10 of the Ships Rules.
 - Converters used for "essential services" on board LR Classed Ships and rated above 100kW shall be surveyed and tested at the manufacturers according to Ships Rules Part 6, Chapter 2, section 1.4.
 - Converters which exceed the limits for radiated and conducted emission of IACS E10 can be installed in "special power distribution zone" according to IEC60533. For installations in "general power distribution zone" measures must be taken to attenuate the effects on the distribution system according to IEC 60533. Planned EMC measures shall be assessed prior to installation on board.
- In LR classed vessels the harmonics content at AC switch boards and section boards shall be limited to values specified in Part 6, Chapter 2, section 1.8.3 of the Ships Rules.

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The attached Design Appraisal Document No.TA10/70021(E2) and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No.10/70021(E1) to which this extension should be attached.

Certificate No.	10/70010(E2)
Issue Date	23 July 2014
Expiry Date	22 July 2019
Sheet	4 of 4



Jacob Munk Plum
Copenhagen Tech. Support Office

Lloyd's Register EMEA
Strandvejen 104A, DK-2900 - Hellerup

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

1 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

LLOYD'S REGISTER TYPE APPROVAL SYSTEM, 2002.

Issued to:

DANFOSS POWER ELECTRONICS A/S Graasten - Denmark and

DANFOSS LLC Loves Park, IL - USA

for:

Frequency Converters for motor drives, types FC102, FC202 and FC301/302 series

limited for drives with Modules A3, B4 and C3

TYPE APPROVAL CERTIFICATE No. 10/70021(E2)

The undernoted documents have been reviewed for compliance with the requirements of the Lloyd's Register Type Approval System, 2002 and this Design Appraisal Document forms part of the Certificate.

APPROVAL DOCUMENTATION

Application form for extension of 10/70021(E1)

09.10.2013

Danfoss US. Letter- pre-scope

00.10.2013

TEST REPORTS

Danfoss Test Report P462 Test Report Summary

--

Danfoss Drives A/S: P462-690V IP20 Visual Inspection for Power Drive Systems

07.02.2012

Danfoss Drives A/S: P462-690V IP20, A3 frame Visual Inspection for Power Drive Systems

18.01.2010

Danfoss Drives P462 A3 Performance Test Report - ID 00709825 Proj: P462-690V IP20

03.09.2013

Danfoss Drives P462-120 LVD General Performance Test

20.11.2013

Danfoss Drives P462 329 LVD General Performance Test

01.06.2012

Danfoss Drives P462 395 LVD General Performance Test

04.06.2013

Danfoss Drives P462-473_R0122T01V110a Power Supply Variations and Interruptions

18.09.2013

IP20 690V FC-302

Danfoss Drives P462-451_R0124T02v100a IP20 690V FC-302 Wide Band Random

03.01.2013

Danfoss Drives P462-467_R0124T02v100a IP20 690V FC-302 Wide Band Random

05.07.2013

Danfoss Drives P462-469_R0124T02v100a IP20 690V FC-302 Wide Band Random

06.04.2013

Danfoss Drives A/S - ID P420-367_R0123T03v110a- Damp Heat Cyclic on EUT:

20.12.2007

FC302P75KT5E20H1 -IP20

Danfoss Drives A/S - ID P462-321_R0123T03v110a - Damp Heat Cyclic on EUT: FC302 690V IP20

30.04.2013

Danfoss Drives A/S - ID P462-454_R0123T03v110a- Damp Heat Cyclic on EUT: FC302 690V IP20

08.05.2013

Danfoss Drives A/S P462-122_R0102T01v300b Dry Heat ID P462-362_R0102T01v300b on EUT:

27.11.2012

FC302P45KT7E20-C3-IP20

Danfoss Drives A/S ID P462-362_R0102T01v300b -Dry Heat on EUT: FC302P75KT5E20H1-A3-IP20

06.11.2012

Danfoss Drives A/S ID P462-391_R0102T01v300b -Dry Heat on EUT: FC302P30T7E20-B4

19.02.2013

U=690V-IP20.

Danfoss Drives A/S - ID P420-368_R0123T04v110a-Cold Test on EUT: FC302P75KT5E20H1 -IP20

13.12.2007

Danfoss Drives A/S-ID P420-541_R0123T04v110a-Cold Test on EUT: FC302P18KT5 -IP20

19.12.2007

Danfoss Drives P462 C3 EMC Summary Report - ID 00708685 Proj: P462-690V IP20

09.07.2012

Danfoss Drives P462 B4 EMC Summary Report - ID 00714890 Proj: P462-690V IP20

03.09.2013

Danfoss Drives P462 A3 EMC Summary Report - ID 00709825 Proj: P462-690V IP20

03.09.2013

Danfoss Drives A/S: P462-305_R0131T01v100e- EUT FC320P37KT7E20H4BG - U4410 - 3x525-

28.06.2012

690V IP20. Conducted Emission 150kHz-30MHz /9kHz BW (.originates PWM)

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

2 of 38

Document number

TA10/70021(E2)

Issue number


02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Danfoss Drives P462-91_R0132T02v200c- Burst Test on FC-302 P462-A3 5.5 kW -U=690V-IP20.	03.01.2012
Danfoss Drives P462-308_R0132T02v200c - Burst Fast/ Transient Test on unit no U4410 no. FC320P37KT7E20H4BG ; U=3x525-690V-IP20.	25.06.2012
Danfoss Drives P462 -456_R0132T02v200c - Burst/Fast Transient on unit no U4410 no. FC302P30KT7E20HB -B4	25.06.2012
Danfoss Drives P462-164_R0134T05v210a Voltage Harm Distortion EUT FC302P45KT7E20H4BG - 3x525-690V IP 20	08.02.2012
Danfoss Drives P462-355_R0134T05v210a on EUT FC302P7K5T7E20 - 3x525-690V IP20	09.08.2012
Danfoss Drives P462-459_R0134T05v300a on EUT FC302P30KT7E20H1B 3x690V IP20 .	21.03.2013
Danfoss Drives P462 A3 Visual Inspection EMC Summary Report - ID 00709825 Proj: P462-690V IP20	03.09.2013
CTR-12-0125 Radiated Emissions, Radiated Immunity, Conducted Immunity, ESD EUT:C3SP2-P3 37kW	11.05.2012
CTR-12-0130 Radiated Emissions, Radiated Immunity, Conducted Immunity, ESD EUT1: FC-302P7K5T7, EUT2: FC-302P3K0T7	30.05.2012
CTR-13-0120 Radiated Emissions, ESD; Radiated Immunity, Surge Immunity, Conducted Immunity, Conducted Emissions EUT: FC-302P30KT5E20H1BGCD	17.05.2013
CTR-13-0155 Conducted Emissions EUT1: FC-302P11KT7E20H4BGCD, EUT2: FC-302P30KT7E20H4BGCD	26.08.2013

All other documents remain as listed in the DAD associated with previous certificate nos.
10/70021, 10/70021(E1).


Jacob Munk Plum
Surveyor, Electrical Section

Supplementary Type Approval Terms and Conditions

Type Approval certifies that a representative sample of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein. It does not mean or imply approval for any other use, nor approval of any product(s) designed or manufactured otherwise than in strict conformity with the said representative sample.

Type Approval is based on the understanding that the manufacturer's recommendations and instructions and any relevant requirements of the Rules and Regulations are complied with.

Type Approval does not eliminate the need for normal inspection and survey procedures required by the Rules and Regulations.

Lloyd's Register EMEA reserves the right to cancel or withdraw this Type Approval Certificate in accordance with the Lloyd's Register Type Approval System Procedure.

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page
3 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

SPECIFICATION OF TYPE/ENCLOSURE/FRAME/POWER

Product: Frequency Converters

Model: VLT® HVAC Drive Series FC-102 (Low/Medium Power)

FC-102: 200-240V (T2)				
Power rating	Enclosure Type			
[kW]	IP20 (*1)	IP21 (*2)	IP55 (*3)	IP66 (*4)
1.1	A2	A2 (*5)	A4/ A5	
1.5				
2.2				
3.0	A3	A3 (*5)	A5	
3.7				
4.0	N/A			
5.5	B3	B1		
7.5				
11				
15	B4	B2		
18.5				
22	C3	C1		
30				
37	C4	C2		
45				
55	N/A			
75				
90				



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page
4 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date
23 July 2014

Quote this reference on all future communications
TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® HVAC Drive Series FC-102 (Low/Medium Power)

FC-102: 380-480V (T4) & 380-500V (T5)				
Power rating	Enclosure Type			
[kW]	IP20 (*1)	IP21 (*2)	IP55 (*3)	IP66 (*4)
1.1	A2	A2(*5)	A4/A5	
1.5				
2.2				
3.0				
3.7	N/A			
4.0	A2	A2(*5)	A4/A5	
5.5	A3	A3(*5)	A5	
7.5				
11	B3	B1		
15				
18.5				
22	B4	B2		
30				
37				
45	C3	C1		
55				
75	C4	C2		
90				



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page
5 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® HVAC Drive Series FC-102 (Low/Medium Power)

FC-102: 525-690V (T7)							
Power rating	Enclosure Type						
[kW]	IP20 (*1)	IP21 (*2)	IP55 (*3)	IP66 (*4)			
1.1	A3	N/A					
1.5							
2.2		B2					
3.0							
4.0							
5.5							
7.5							
11	B4						
15							
18.5							
22							
30							
37							
45	C3	C2					
55							
75	D3h						
90							



Lloyd's
Register

Lloyd's Register EMEA's

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page
6 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date
23 July 2014

Quote this reference on all future communications
TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® HVAC Drive Series FC-102 (Low/Medium Power)

(*1) IP20/Panel mount. All IP20 versions can be upgraded to IP21 with optional kit

(*2) IP21/NEMA Type 1

(*3) IP55/NEMA Type 12

(*4) IP66/NEMA Type 4X

(*5) IP20/Panel with IP21 upgrade kit

H1; H2; H3; H4 RFI comply with IACS E10 requirements except radiated and conducted emissions.

H5 RFI complies with IACS E10 requirements except radiated and conducted emissions.

Ruggedized boards, selection "R" in character 20, or H5 in character 16-17 must be selected

Limitations: Converters which exceed the limits for radiated and conducted emissions of IACS E10 can be installed in "special power distribution zone" according to IEC60533. For installations in "general power distribution zone" measures must be taken to attenuate the effects on the distribution system. Planned EMC measures according to IEC60533 shall be assessed prior to installation on board.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page
7 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® AQUA Drive Series FC-202 (Low/Medium Power)

FC-202: 200-240V (T2)				
Power rating	Enclosure Type			
[kW]	IP20 (*1)	IP21 (*2)	IP55 (*3)	IP66 (*4)
0.25	A2	A2 (*5)	A4/ A5	
0.37				
0.55				
0.75				
1.1				
1.5				
2.2				
3.0	A3	A3(*5)	A5	
3.7				
4.0	N/A			
5.5	B3	B1		
7.5				
11				
15	B4	B2		
18.5				
22	C3	C1		
30				
37	C4	C2		
45				



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page
8 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® AQUA Drive Series FC-202 (Low/Medium Power)

FC-202: 380-480V (T4) & 380-500V (T5)					
Power rating	Enclosure Type				
[kW]	IP20 (*1)	IP21 (*2)	IP55 (*3)	IP66 (*4)	
0.37	A2	A2(*5)	A4/A5		
0.55					
0.75					
1.1					
1.5					
2.2					
3.0					
4.0	A3	A3(*5)	A5		
5.5					
7.5					
11	B3	B1			
15					
18.5					
22	B4	B2			
30					
37					
45	C3	C1			
55					
75	C4	C2			
90		C2	N/A		



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhage-technical-support@lr.org

Page
9 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® AQUA Drive Series FC-202 (Low/Medium Power)

FC-202:		525-690V (T7)		
Power rating	Enclosure Type			
[kW]	IP20 (*1)	IP21 (*2)	IP55 (*3)	IP66 (*4)
1.1	A3	N/A		
1.5				
2.2				
3.0				
4.0				
5.5				
7.5				
11	B4	B2		
15				
18.5				
22				
30				
37	C3			
45				
55	D3h	C2		
75				
90				

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

10 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® AQUA Drive Series FC-202 (Low/Medium Power)

(*1) IP20/Panel mount. All IP20 versions can be upgraded to IP21 with optional kit

(*2) IP21/NEMA Type 1

(*3) IP55/NEMA Type 12

(*4) IP66/NEMA Type 4X

(*5) IP20/Panel with IP21 upgrade kit

H1; H2; H3; H4 RFI comply with IACS E10 requirements except radiated and conducted emissions

H5 RFI complies with IACS E10 requirements except radiated and conducted emissions.

Limitations: Converters which exceed the limits for radiated and conducted emissions of IACS E10 can be installed in "special power distribution zone" according to IEC60533. For installations in "general power distribution zone" measures must be taken to attenuate the effects on the distribution system Planned EMC measures according to IEC60533 shall be assessed prior to installation on board.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhage-technical-support@lr.org

Page

11 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® Automation Drive Series FC-301/302 (Low/Medium Power)

FC-301/302: 200-240V (T2)				
Power rating	Enclosure Type			
[kW]	IP20 (*1)	IP21 (*2)	IP55 (*3)	IP66 (*4)
0.25	A2	A2(*5)	A4/ A5	
0.37				
0.55				
0.75				
1.1				
1.5				
2.2				
3.0	A3	A3(*5)	A5	
3.7				
5.5	B3	B1		
7.5				
11	B4	B2		
15				
18.5	C3	C1		
22				
30	C4	C2		
37				

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

12 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® Automation Drive Series FC-301/302 (Low/Medium Power)

FC-301/302: 380-480V (T4) & 380-500V (T5)				
Power rating	Enclosure Type			
[kW]	IP20 (*1)	IP21 (*2)	IP55 (*3)	IP66 (*4)
0.37	A2	A2(*5)	A4/ A5	
0.55				
0.75				
1.1				
1.5				
2.2				
3.0				
4.0				
5.5	A3	A3(*5)	A5	
7.5				
11	B3	B1		
15				
18.5	B4	B2		
22				
30		C1		
37	C3			
45				
55	C4	C2		
75				

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

13 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® Automation Drive Series FC-301/302 (Low/Medium Power)

FC-301/302: 525-690V (T7)							
Power rating	Enclosure Type						
[kW]	IP20 (*1)	IP21 (*2)	IP55 (*3)	IP66 (*4)			
1.1	A3	Not Available					
1.5							
2.2		B2					
3.0							
4.0							
5.5							
7.5							
11	B4	C2					
15							
18.5							
22							
30							
37	C3	C2					
45							
55	D3h						
75							



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

14 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® Automation Drive Series FC-301/302 (Low/Medium Power)

(*1) IP20/Panel mount. All IP20 versions can be upgraded to IP21 with optional kit

(*2) IP21/NEMA Type 1

(*3) IP55/NEMA Type 12

(*4) IP66/NEMA Type 4X

(*5) IP20/Panel with IP21 upgrade kit

H1; H2; H3; H4 RFI comply with IACS E10 requirements except radiated and conducted emissions

H5 RFI complies with IACS E10 requirements except radiated and conducted emissions.

Ruggedized boards, selection "R" in character 20, or H5 in character 16-17 must be selected

Limitations: Converters which exceed the limits for radiated and conducted emissions of IACS E10 can be installed in "special power distribution zone" according to IEC60533. For installations in "general power distribution zone" measures must be taken to attenuate the effects on the distribution system. Planned EMC measures according to IEC60533 shall be assessed prior to installation on board.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

15 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: Series FC-102, FC-202, FC-301/302 (Low/Medium Power)

Selection types for Type Codes for FC-102, FC-202, FC-301/302

1	4	7	10	23	24-39 (SW +options)
---	---	---	----	----	---------------------------

Basic string definitions:

Product Group (character 1-3)

FC- : Adjustable Frequency Converters

VLT series (character 4-6)

102 : VLT HVAC Drive – Advanced version

202 : VLT AQUA Drive – Advanced version

301 : VLT Automation Drive – Standard version

302 : VLT Automation Drive – Advanced version

Power size (character 7-10)

PK25 : 0.25 kW / 0.33 HP

P75K : 75 kW / 100 HP

P90K : 90 kW / 125 HP

N75K : 75 kW / 100 HP (D3h)

N90K : 90 kW / 125 HP (D3h)

Voltage: (character 11-12)

T2 : Three phase 200-240 V_{AC}

T4 : Three phase 380-480 V_{AC}

T5 : Three phase 380-500 V_{AC}

T7 : Three Phase 525-690 V_{AC}

Enclosure (character 13-15)

E20 : IP20 / Chassis

E21 : IP21 / Type 1

E55 : IP55 / Type 12

E66 : IP66 / Type 4X



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

16 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: Series FC-102, FC-202, FC-301/302 (Low/Medium Power)

Selection types for Type Codes for FC-102, FC-202, FC-301/302 (Low/Medium Power) (continued)

Hardware (character 16-23)

Hardware, RFI filter (character 16-17) – As follows:

- H6: RFI for Maritime use. H6 RFI complies with IACS E10 requirements except radiated and conducted emissions
- H5: RFI for Maritime use. H5 RFI complies with IACS E10 requirements except radiated and conducted emissions
- H4: RFI for Maritime use. H4 RFI complies with IACS E10 requirements except radiated and conducted emissions
- H2: RFI Class A2 (C3)

Hardware, Brake & Stop (character 18)

Hardware, Display (character 19)

Hardware, Coating (character 20) – As follows:

- C: Coated PCB;
- R: Coated PCB + Ruggedized

Hardware, Mains options (character 21)

Hardware, adaptation A (character 22)

Hardware, adaptation B (character 23)

Software (character 24-28)

Options – A (character 29-30)

Options – B (character 31-32)

Options – C (character 33-37)

Options – D (character 38-39)



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page
17 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: Series FC-102, FC-202, FC-301/302 (Low/Medium Power)

Brand Labelling and Customer Specific Definitions

Brand labelling and customer specific drives are following the type codes except the characters 1-6 for product group and VLT series. Character 1-6 are used for customer specific definitions.

Basic string definitions for brand labelling and customer specific drives:

Product Group and VLT series (character 1-6)

<u>Model #</u>	<u>Description</u>
AF-600	Equals to FC-102
AKD102	
ADS102	
IVS102	
TR-200	
ITT102	
CUE202	Equals to FC-202
FC-311	Equals to FC-301
LD-302	Equals to FC-302
IR-302	
IRV302	
CD-302	
MWU302	
CDS302	
DV-302	
3G3DV	
LB-302	
AFE302	
AF-650	
FCK302	
FC-312	

Product: Frequency Converters

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

18 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Model: VLT® HVAC Drive Series FC-102 (High Power)

FC-102: 380-480V (T4)				
Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
110	D3h	NA	D1h/D5h/D6h	
132				
160				
200	D4h		D2h/D7h/D8h	
250				
315				
110	NA	D3	D1	
132		D4	D2	
160				
200				
250		E2	E1	
315				
355				
400		NA	F1/F3	
450				
500				
560				
630				
710				
800		NA	F2/F4	
1M0				

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page
19 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date
23 July 2014

Quote this reference on all future communications
TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® HVAC Drive Series FC-102 (High Power)

FC-102: 525-690V (T7)				
Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
75	D3h	NA	D1h/D5h/D6h	
90				
110				
132				
160				
200	D4h		D2h/D7h/D8h	
250				
315				
400				
45	NA		D3	D1
55				
75				
90				
110				
132				
160				
200		D4	D2	
250				
315				
400				
450		E2	E1	
500				
560				
630		NA	F1/F3	
710				
800			F2/F4	
900				
1M0				
1M2				
1M4				

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

20 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® HVAC Drive Series FC-102 (High Power)

FC-102: 380-480V (T4)			
Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
315	NA	F8/F9	
355			
400			
450			
500			
560		F10/F11	
630			
710			
800			
1M0		F12/F13	

FC-102: 525-690V (T7)			
Power rating [kW]	Enclosure type		
	IP00(*1)	IP21 (*2)	IP54 (*3)
450	NA	F8/F9	
500			
560			
630			
710			
800		F10/F11	
900			
1M0			
1M2		F12/F13	
1M4			



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhage-technical-support@lr.org

Page

21 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® HVAC Drive Series FC-102 (High Power)

FC-102: 380-480V (T4)			
Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
160	NA	D11/D13/D1n	
200		D11/D13/D2n	
250		E7/E9	
315		F17/F18	
355			
400			
450			
500			
560			
630			
710			

(*1) IP00/IP20/Panel mount.

(*2) IP21/NEMA Type 1

(*3) IP54/NEMA Type 12

Limitations: Converters which exceed the limits for radiated and conducted emissions of IACS E10 can be installed in "special power distribution zone" according to IEC60533. For installations in "general power distribution zone" measures must be taken to attenuate the effects on the distribution system. Planned EMC measures according to IEC60533 shall be assessed prior to installation on board.

Ruggedized boards, selection "R" in character 20, must be selected for D1h – D8h and D1n – D2n.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

22 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® HVAC Drive Series FC-102 (High Power)

Selection of Type Codes for FC-100

----- (character 24 – 39 software + options)
1 4 7 10 11 23

Basic string definitions:

Product Group (character 1-3)

FC- : Adjustable Frequency Converters

VLT series (character 4-6)

102 VLT HVAC Drive – Advanced version

Power size (character 7-10)

P110: 110 kW / 150 HP

N110: 110 kW/ 150 HP

Voltage: (character 11-12)

T4 : Three phase 380-480 VAC

T7 : Three Phase 525-690 VAC

Enclosure (character 13-15)

E00 : IP00 / Chassis

E20 : IP20 / Chassis

E2S: IP20 / Chassis (medium power D-Frame)

E21 : IP21 / Type 1

E2D: IP21 / Type 1 (medium power D-Frame)

H21: IP21 / Type 1 with heater

E54 : IP54/ Type 12

H54.: IP54 / Type 12 with heater

E5H : Hybrid IP54

E2M : IP20 / Type 1 with mains shield

E5M : IP54 / Type 12 with mains shield

E5D : IP54 / Type 12 (medium power D-Frame)

Hardware (character 16-23)

Hardware, RFI filter (character 16-17)

H2: 6 Pulse Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

H4: 6 Pulse Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhage-technical-support@lr.org

Page

23 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® HVAC Drive Series FC-102 (High Power)

B2: 12 Pulse Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions) "

B4: 12 Pulse Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

N2: Low Harmonic Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

N4: Low Harmonic Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

Hardware, Brake & Stop (character 18)

Hardware, Display (character 19)

Hardware, Coating (character 20)

Hardware, Mains options (character 21)

Hardware, adaptation A (character 22)

Hardware, adaptation B (character 23)

Software (character 24-28)

Options - A (character 29-30)

Options - B (character 31-32)

Options - C (character 33-37)

Options - D (character 38-39)

Brand labelling and customer specific definitions

Brand labelling and customer specific drives are following the type codes except the characters 1-6 for product group and VLT series. Character 1-6 are used for customer specific definitions.

Basic string definitions for brand labelling and customer specific drives:

Product Group and VLT series (character 1-6)

AF-600	Same as FC-102
AKD102	
FC-103	
ADS102	
IVS102	
TR-200	
ITT102	



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

24 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® AQUA Drive Series FC-202 (High Power)

FC-202: 380-480V (T4)				
Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
110	D3h	NA	D1h/D5h/D6h	
132				
160				
200	D4h		D2h/D7h/D8h	
250				
315				
110	NA	D3	D1	
132		D4	D2	
160				
200				
250		E2	E1	
315				
355				
400		NA	F1/F3	
450				
500				
560			F2/F4	
630				
710				
800				
1M0				



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

25 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® AQUA Drive Series FC-202 (High Power)

FC-202: 525-690V (T7)				
Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
75	D3h	NA	D1h/D5h/D6h	
90				
110				
132				
160				
200	D4h		D2h/D7h/D8h	
250				
315				
400				
45				
55				
75				
90				
110				
132				
160	D4	D2		
200				
250				
315				
400	E2	E1		
450				
500				
560				
630	NA	F1/F3		
710				
800		F2/F4		
900				
1M0				
1M2				
1M4				

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page
26 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® AQUA Drive Series FC-202 (High Power)

FC-202: 380-480V (T4)			
Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
315	NA	F8/F9	
355			
400			
450			
500			
560		F10/F11	
630			
710			
800		F12/F13	
1M0			

FC-202: 525-690V (T7)			
Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
450	NA	F8/F9	
500			
560			
630			
710			
800		F10/F11	
900			
1M0			
1M2		F12/F13	
1M4			

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

27 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® AQUA Drive Series FC-202 (High Power)

FC-202: 380-480V (T4)			
Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
160	NA	D11/D13/D1n	
200		D11/D13/D2n	
250			
315		E7/E9	
355			
400			
450		F17/F18	
500			
560			
630			
710			

(*1) IP00/IP20/Panel mount.

(*2) IP21/NEMA Type 1

(*3) IP54/NEMA Type 12

Limitations: Converters which exceed the limits for radiated and conducted emissions of IACS E10 can be installed in "special power distribution zone" according to IEC60533. For installations in "general power distribution zone" measures must be taken to attenuate the effects on the distribution system Planned EMC measures according to IEC60533 shall be assessed prior to installation on board.

Ruggedized boards, selection "R" in character 20, must be selected for D1h - D8h and D1n - D2n.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

28 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® AQUA Drive Series FC-202 (High Power)

Selection types for Type Codes for FC-200

1 4 7 10 11 (character 24 - 39 software + options)
23

Basic string definitions:

Product Group (character 1-3)

FC- : Adjustable Frequency Converters

VLT series (character 4-6)

202 VLT AQUA Drive - Advanced version

Power size (character 7-10)

P110: 110 KW / 150 HP

N110: 110 KW / 150 HP

Voltage: (character 11-12)

T4 : Three phase 380-480 VAC

T7 : Three Phase 525-690 VAC

Enclosure (character 13-15)

E00 : IP00 / Chassis

E20: IP20 / Chassis

E2S: IP20 / Chassis (medium power D-Frame)

E21 : IP21 / Type 1

E2D: IP21 / Type 1 (medium power D-Frame)

H21: IP21 / Type 1 with heater

E54 : IP54 / Type 12

H54: IP54 / Type 12 with heater

E5H : Hybrid IP54

E2M: IP21 / Type 1 with mains shield

E5M: IP54 / Type 12 with mains shield

E5D : IP54 / Type 12 (medium power D-Frame)

Hardware (character 16-23)

Hardware, RFI filter (character 16-17)

H2: 6 Pulse Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

H4: 6 Pulse Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhage-technical-support@lr.org

Page

29 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® AQUA Drive Series FC-202 (High Power)

B2: 12 Pulse Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions) "

B4: 12 Pulse Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

N2: Low Harmonic Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

N4: Low Harmonic Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

Hardware, Brake & Stop (character 18)

Hardware, Display (character 19)

Hardware, Coating and ruggedized (character 20)

Hardware, Mains options (character 21)

Hardware, adaptation A (character 22)

Hardware, adaptation B (character 23)

Software (character 24-28)

Options - A (character 29-30)

Options - B (character 31-32)

Options - C (character 33-37)

Options - D (character 38-39)

Brand labelling and customer specific definitions

Brand labelling and customer specific drives are following the type codes except the characters 1-6 for product group and VLT series. Character 1-6 are used for customer specific definitions.

Basic string definitions for brand labelling and customer specific drives:

Product Group and VLT series (character 1-6)

CUE202	Same as FC-
FC-322	202



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

30 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® Automation Drive Series FC-302 (High Power)

FC-302: 380-500V (T5)					
Power rating [kW]	Enclosure type				
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)	
90	D3h	NA	D1h/D5h/D6h		
110					
132					
160			D4h	D2h/D7h/D8h	
200					
250					
90	NA	D3	D1		
110		D4	D2		
132					
160					
200		E2	E1		
250					
315					
355		NA	F1/F3		
400					
450					
500			NA	F2/F4	
560					
630					
710					
800					

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhage-technical-support@lr.org

Page

31 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® Automation Drive Series FC-302 (High Power)

FC-302: 525-690V (T7)				
Power rating [kW]	Enclosure type			
	IP20 (*1)	IP00 (*1)	IP21 (*2)	IP54 (*3)
55	D3h	NA	D1h/D5h/D6h	
75				
90				
110				
132				
160	D4h		D2h/D7h/D8h	
200				
250				
315				
37				
45				
55				
75				
90				
110	D4	D2		
132				
160				
200				
250				
315	E2	E1		
355				
400				
500				
560				NA
630				
710	F2/F4			
800				
900				
1M0				
1M2				

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

32 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® Automation Drive Series FC-302 (High Power)

FC-302: 380-500V (T5)			
Power rating [kW]	Enclosure type		
	IP00(*1)	IP21 (*2)	IP54 (*3)
250	NA	F8/F9	
315			
355			
400			
450			
500		F10/F11	
560			
630			
710		F12/F13	
800			

FC-302: 525-690V (T7)			
Power rating [kW]	Enclosure type		
	IP00(*1)	IP21 (*2)	IP54 (*3)
355	NA	F8/F9	
400			
500			
560			
630		F10/F11	
710			
800			
900		F12/F13	
1M0			
1M2			

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

33 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® Automation Drive Series FC-302 (High Power)

FC-302: 380-500V (T5)			
Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
132	NA	D11	
160			
200			
250			
315		E7	
355			
400			
450			
500		F17	
560			
630			

FC-302: 380-500V (T5)			
Power rating [kW]	Enclosure type		
	IP00 (*1)	IP21 (*2)	IP54 (*3)
132	NA	D11/D13/D1n	
160		D11/D13/D2n	
200			
250		E7/E9	
315			
355			
400			
450		F17/F18	
500			
560			
630			

(*1) IP00/IP20 Panel mount.

(*2) IP21/NEMA Type 1

(*3) IP54/NEMA Type 12

Limitations: Converters which exceed the limits for radiated and conducted emissions of IACS E10 can be installed in "special power distribution zone" according to IEC60533. For installations in "general power distribution zone" measures must be taken to attenuate the effects on the distribution system Planned EMC measures according to IEC60533 shall be assessed prior to installation on board.

Ruggedized boards, selection "R" in character 20, must be selected for D1h – D8h and D1n – D2n.

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

This is a copy of an electronic document. In the event of any conflict or ambiguity between the copy and the electronic document, which is retained and published by Lloyd's Register, the original electronic and certified version shall always prevail.



Copenhagen Tech. Support Office
Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881
E-mail: copenhagen-technical-support@lr.org

Page 34 of 38
Document number TA10/70021(E2)
Issue number 02

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Model: VLT® Automation Drive Series FC-302 (High Power)

Selection types for Type Codes for FC-300

----- (character 24 - 39 software + options)

Basic string definitions:

Product Group (character 1-3)

FC- : Adjustable Frequency Converters

VLT series (character 4-6)

302 : VLT Automation Drive - Advanced version

Power size (character 7-10)

P110: 110 KW / 150 HP

N110: 110 KW / 150 HP

Voltage: (character 11-12)

T4 : Three phase 380-480 VAC

T5 : Three phase 380-500 V AC

T7 : Three Phase 525-690 VAC

Enclosure (character 13-15)

E00 : IP00 / Chassis

E20: IP20 / Chassis

E2S: IP20 / Chassis (medium power D-Frame)

E21 : IP21 / Type 1

E2D: IP21 / Type 1 (medium power D-Frame)

H21: IP21 / Type 1 with heater

E54 : IP54/ Type 12

H54:: IP54 / Type 12 with heater

E5H : Hybrid IP54

E2M: IP21 / Type 1 with mains shield

E5M: IP54 / Type 12 with mains shield

E5D : IP54 / Type 12 (medium power D-Frame)

Hardware (character 16-23)

Hardware, RFI filter (character 16-17)

H2: 6 Pulse Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

H4: 6 Pulse Drive RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office
Strandvejen 104A, DK-2900 - Hellerup
Telephone +45 3296 1800 Fax +45 3296 1881
E-mail: copenhage-technical-support@lr.org

Page
35 of 38

Document number
TA10/70021(E2)

Issue number
02

DESIGN APPRAISAL DOCUMENT

Date 23 July 2014	Quote this reference on all future communications TA/I104948/1301042/PEH/jmp
----------------------	---

Product: Frequency Converters

Model: VLT® Automation Drive Series FC-302 (High Power)

B2: 12 Pulse Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions) "

B4: 12 Pulse Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

N2: Low Harmonic Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

N4: Low Harmonic Drive with RFI for Maritime (complies with IACS E10 requirements except radiated and conducted emissions)

Hardware, Brake & Stop (character 18)

Hardware, Display (character 19)

Hardware, Coating and Ruggedized (character 20)

Hardware, Mains options (character 21)

Hardware, adaptation A (character 22)

Hardware, adaptation B (character 23)

Software (character 24-28)

Options - A (character 29-30)

Options - B (character 31-32)

Options - C (character 33-37)

Options - D (character 38-39)



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

36 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Product: Frequency Converters

Model: VLT® Automation Drive Series FC-302 (High Power)

Brand labelling and customer specific definitions

Brand labelling and customer specific drives are following the type codes except the characters 1-6 for product group and VLT series. Character 1-6 are used for customer specific definitions.

Basic string definitions for brand labelling and customer specific drives:

Product Group and VLT series (character 1-6)

LD-302	Same as FC-302
IR-302	
IRV302	
CD-302	
MWU302	
CDS302	
DV-302	
3G3DV	
LB-302	
AFE302	
AF-650	
FCK302	



E-mail: copenhagen-technical-support@lr.org



Lloyd's
Register

Lloyd's Register EMEAs

Copenhagen Tech. Support Office

Strandvejen 104A, DK-2900 - Hellerup

Telephone +45 3296 1800 Fax +45 3296 1881

E-mail: copenhagen-technical-support@lr.org

Page

38 of 38

Document number

TA10/70021(E2)

Issue number

02

DESIGN APPRAISAL DOCUMENT

Date

23 July 2014

Quote this reference on all future communications

TA/I104948/1301042/PEH/jmp

Model: VLT® Active Filter AAF006 (High Power)

E21 : IP21 / Type 1

E54 : IP54/ Type 12

E2M : IP21 / Type 1 with mains shield

E5M : IP54 / Type 12 with mains shield

Hardware (character 16-23)

Hardware, RFI filter (character 16-17)

HX: Active Filter complies with IACS E10 requirements except radiated and conducted emissions

Hardware, Not Used X

Hardware, Display (character 19)

Hardware, Coating and Ruggedized (character 20)

Hardware, Mains options (character 21)

Hardware, Reserved for Future (character 22)

Hardware, Reserved for Future (character 23)

Software (character 24-28)

Options - A (character 29-30)

Options - B (character 31-32)

Options - C (character 33-37)

Options - D (character 38-39)