

O-RINGS, INVERTER ASSEMBLY

100310-2



Installation and servicing of Danfoss Turbocor® compressors by qualified and product trained personnel only. Follow these instructions and sound refrigeration/electrical/servicing practices relating to installation, commissioning, maintenance, and service.

Consult the appropriate
Danfoss LLC Service Manual
on www.turbocoroem.com
for detailed service
instructions.

Never power the compressor without the top covers in place and secured.

Removing the mains input cover will expose you to hazardous voltages. Ensure the mains input power is off and locked out before removing the cover.

Before removing the top cover, wait at least 20 minutes after isolating AC power to allow the highvoltage capacitors to discharge.

Always wear appropriately rated safety equipment when from compressor in working around equipment and/or components energized with high voltage.

This equipment contains hazardous voltages that can cause serious injury or death.

Recover all refrigerant accordance with local codes and ensure pressure is fully vented before the removal of refrigerant containing components.

1 - Introduction

Please refer to our service manual for the removal and installation procedures.

To access the manual, you may scan the applicable QR code below or you may go to our DTC website at www.turbocoroem.com. At the bottom of the page there is a Section named "Categories" that includes various menus including one for Manuals.

Refer to the applicable QR code below to download the TT/TG Series Service Manual.







2 - Kit Contents

Note: Any part numbers included in the kit contents are internal part numbers only. Please refer to our Spare Parts Manuals for any kit part numbers.

QTY	Part(s) Description	Picture(s)
2	O-RING – 901859	0
1	O-RING – 902751	0
1	O-RING – 901865	
20	SCREW, M6X30, SOCKET HEAD CAP – 902820	
20	WASHER, M6 FLAT – 902804	0
2	SCREW M6X20 SOCKET HEAD CAP – 902819	
1	LUBRICATION-SUPER-O-LUBE-2G	

3 - List of Changes

Revision	Date	Description of Change	
	10/31/2024	Removed obsolete kit (100310) from top of document	
В		Added two O-rings to the kit contents	
		Updated format	

Danfoss LLC can accept no responsibility for possible errors in catalogues, brochures, and other printed material. Danfoss LLC reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without subsequential changes being necessary in specifications already agreed.

All trademarks in this material are property of the respective companies. Danfoss and the Danfoss logotype are trademarks of Danfoss A/S. All rights reserved.