

Design Guide

# iC2-Micro Frequency Converters





## Contents

<b>1</b>	<b>Introduction and Safety</b>	<b>7</b>
1.1	Purpose of this Design Guide	7
1.2	Additional Resources	7
1.3	Planning and Design Support Materials	7
1.4	Version History	7
1.5	Safety Symbols	7
1.6	Medical Devices	8
1.7	General Safety Considerations	8
1.8	Qualified Personnel	9
<b>2</b>	<b>Approvals and Certifications</b>	<b>10</b>
2.1	Product Approvals and Certifications	10
2.2	Standards	11
2.3	Export Control Regulation	11
<b>3</b>	<b>iC2-Micro Frequency Converters</b>	<b>12</b>
3.1	Intended Use	12
3.2	Block Diagram	12
3.3	Ecodesign for Power Drive Systems	13
3.3.1	Power Losses and Efficiency	13
3.4	Power Hardware	14
3.5	Control and Interfaces	15
3.5.1	Control Terminals	15
3.5.2	RJ45 Port and RS485 Termination Switch	16
3.5.3	Control Panel and Control Panel 2.0 OP2	16
3.5.4	Control Panel Keys and Indicators	17
3.5.5	Sliding Door on the Terminal Cover	19
3.6	Application Software	20
3.6.1	Overview	20
3.6.2	Basic Functions	21
3.6.3	IO Control and Readouts	22
3.6.4	Motor Control Features	22
3.6.5	Braking of Load	23
3.6.6	Protection Features	24
3.6.7	Monitoring Features	24
3.6.8	Software Tools	24
3.7	Brake Functions	25

3.7.1	Mechanical Holding Brake	25
3.7.2	Dynamic Braking	25
3.7.3	Brake Resistor Selection	25
3.7.3.1	Introduction	25
3.7.3.2	Brake Resistance Calculation	26
3.7.3.3	Danfoss Recommended Brake Resistance Calculation	26
3.7.4	Control with Brake Function	27
<b>4</b>	<b>Specifications</b>	<b>28</b>
4.1	Electrical Data	28
4.1.1	Mains Supply 1x200–240 V AC	28
4.1.2	Mains Supply 3x380–480 V AC	28
4.2	General Technical Data	29
4.2.1	Protection and Features	29
4.2.2	Grid Side	29
4.2.3	Motor Output and Motor Data	30
4.2.4	Torque Characteristics	30
4.2.5	Control I/O	30
4.2.5.1	Digital and Pulse Input	30
4.2.5.2	Digital and Pulse Output	31
4.2.5.3	Analog Input	31
4.2.5.4	Analog Output	32
4.2.5.5	Relay Output	32
4.2.5.6	Auxiliary Voltages	33
4.2.6	RS485 Serial Communication	33
4.2.7	Ambient Conditions	33
4.2.7.1	Ambient Conditions during Storage	33
4.2.7.2	Ambient Conditions during Transport	34
4.2.7.3	Ambient Conditions during Operation	34
4.3	Fuses and Circuit Breakers	34
4.4	Power Connectors	35
4.5	Acoustic Noise	36
4.6	EMC Compliance Levels	37
4.6.1	Emission Requirements	37
4.6.2	EMC Immunity Requirements	38
4.7	EMC Compatibility and Motor Cable Length	39
4.8	dU/dt Conditions	39
4.9	Derating	40

4.9.1	Manual Derating	40
4.9.2	Automatic Derating	42
<b>5</b>	<b>Exterior Dimensions</b>	<b>43</b>
5.1	IP20/Open Type Enclosure Sizes and Dimensions	43
5.2	IP21/UL Type 1 Enclosure Sizes and Dimensions	44
5.3	NEMA 1 Enclosure Sizes and Dimensions	45
<b>6</b>	<b>Mechanical Installation Considerations</b>	<b>46</b>
6.1	Contents of the Shipment	46
6.2	Product Labels	46
6.2.1	Product Labels on Drives	46
6.2.2	Package Labels	47
6.3	Recommended Disposal	48
6.4	Storage until Installation	48
6.4.1	Reforming the Capacitors	48
6.4.2	Safe Transportation and Storage	49
6.5	Prerequisites for Installation	49
6.5.1	Operating Environment	50
6.6	Maintenance Considerations	50
6.6.1	Regular Maintenance	51
6.6.2	Maintenance Schedule	51
6.6.3	Service Access	51
6.6.4	Heat Sink and Fan Maintenance and Service	51
6.7	Mechanical Installation	52
6.7.1	Mounting Considerations	52
6.7.2	Mounting Locations	52
6.7.3	Mounting Directions	52
6.7.4	Recommended Screws and Bolts	53
6.7.5	Drilling Patterns	53
6.7.6	Placement of the Drive in the Installation	54
6.7.7	Cooling	54
6.7.8	Recommended Space for Service Access	55
<b>7</b>	<b>Electrical Installation Considerations</b>	<b>57</b>
7.1	Electrical Installation Precautions	57
7.2	Wiring Diagram	58
7.3	Grid Type and Protection	59
7.3.1	Grid Types	59

7.3.2	Currents on Protective Earth and Potential Equalization/Leakage Currents	59
7.3.3	PE Current Measurement	59
7.3.4	Residual Current Device (RCD) Protection	61
7.3.5	Isolation Monitoring Devices	61
7.4	EMC-compliant Installation Guidelines	61
7.4.1	Power Cables and Grounding	63
7.4.2	Control Cables	64
7.5	Galvanic Isolation	64
7.6	Ground Leakage Current	65
7.7	Motor Installation Considerations	66
7.7.1	Supported Motor Types	67
7.7.2	Motor Insulation	67
7.7.3	Bearing Currents	67
7.7.4	Motor Thermal Protection	68
7.8	Extreme Running Conditions	69
7.9	Power Cable Considerations	69
7.9.1	Torque Requirements	70
7.10	Electrical Installation	70
7.10.1	Mains, Motor, and Grounding Connection	70
7.10.2	Connecting the Motor	71
7.10.3	Connecting AC Mains	72
7.10.4	Control Terminal Types	72
7.10.5	Control Wire Sizes and Stripping Lengths	73
7.10.6	Cable Shield Connection	74
7.10.7	Load Sharing/Brake	75
<b>8</b>	<b>How to Order</b>	<b>77</b>
8.1	Model Code	77
8.2	Ordering Accessories and Spare Parts	77
8.3	Ordering Brake Resistors	79
8.3.1	Introduction	79
8.3.2	Ordering Brake Resistors 10%	79
8.3.3	Ordering Brake Resistors 40%	80



# 1 Introduction and Safety

## 1.1 Purpose of this Design Guide

This design guide is intended for qualified personnel, such as:

- Project and systems engineers.
- Design consultants.
- Application and product specialists.

The design guide provides technical information to understand the capabilities of the iC2-Micro Frequency Converters for integration into motor control and monitoring systems. Its purpose is to provide design considerations and planning data for integration of the drive into a system. It caters for selection of drives and options for a diversity of applications and installations. Reviewing the detailed product information in the design stage enables developing a well-conceived system with optimal functionality and efficiency.

This guide is targeted at a worldwide audience. Therefore, wherever occurring, both SI and imperial units are shown.

## 1.2 Additional Resources

Additional resources are available to help understand the features, safely install, and operate the iC2-Micro Frequency Converters:

- The operating guide, which provides information about the installation, commissioning, and maintenance of the drive.
- The application guide, which provides information on how to program and includes complete parameter descriptions.
- Facts Worth Knowing about AC Drives, available for download at [www.danfoss.com](http://www.danfoss.com).
- Other supplemental publications, drawings, and guides are available at [www.danfoss.com](http://www.danfoss.com).

Latest versions of Danfoss product documentation are available for download at <http://drives.danfoss.com/downloads/portal/>.

## 1.3 Planning and Design Support Materials

Danfoss provides access to a consolidated product environment that can support throughout the product lifecycle.

### Documents

The operating guide, application guide, and design guide for iC2-Micro Frequency Converters are available for download at [www.danfoss.com](http://www.danfoss.com). It is also possible to order printed guides.

### Drawings

For each drive, 2D and 3D drawings, and wiring diagrams are available in standard file formats.

### Software

Configuration files for iC2-Micro Frequency Converters are available. MyDrive® Suite provides tools that support the entire lifecycle of the drive, from system design to service. MyDrive® Suite is available at <https://suite.mydrive.danfoss.com/>.

### Configurator

The product configurator helps in the product selection. When the process has been completed, the product configurator provides a list of relevant documentation and accessories.

## 1.4 Version History

This guide is regularly reviewed and updated. All suggestions for improvement are welcome.

The original language of this guide is English.

Table 1: Version History

Version	Remarks
AJ402315027937, version 0101	For enclosure sizes MA01c/MA02c/MA01a/MA02a release. <sup>(1)</sup>

<sup>1</sup> Data for MA03a to MA05a will be available in next release.

## 1.5 Safety Symbols

The following symbols are used in this guide:

<b>⚠ D A N G E R ⚠</b>
Indicates a hazardous situation which, if not avoided, will result in death or serious injury.

### ⚠ WARNING ⚠

Indicates a hazardous situation which, if not avoided, could result in death or serious injury.

### ⚠ CAUTION ⚠

Indicates a hazardous situation which, if not avoided, could result in minor or moderate injury.

### NOTICE

Indicates information considered important, but not hazard-related (for example, messages relating to property damage).

## 1.6 Medical Devices

### ⚠ WARNING ⚠

#### PROTECTION OF PERSONS AGAINST ELECTROMAGNETIC FIELDS FOR FREQUENCIES FROM 0 HZ UP TO 300 GHZ

AC drives and filters may produce strong electromagnetic interference that may affect the functionality of pacemakers and other implanted medical devices.

## 1.7 General Safety Considerations

When installing or operating the AC drive, pay attention to the safety information given in the instructions. For more information about safety guidelines for installation and operation, refer to the drive's operating guide.

### Safe Operation Guidelines

- The drive is not suitable as the only safety device in the system. Make sure that additional monitoring and protection devices on drives, motors, and accessories are installed according to the regional safety guidelines and accident prevention regulations.
- Before activating any automatic fault reset functions or change limit values, make sure that no dangerous situations can occur after restart. If the auto reset function is activated, the motor starts automatically after an automatic fault reset.
- Keep all doors and covers closed and terminal boxes screwed on during operation of the drive and when mains is connected.
- Drive components and accessories can still be live and connected to mains, even after the operation indicators are no longer illuminated.

### ⚠ WARNING ⚠

#### LACK OF SAFETY AWARENESS

This guide gives important information on preventing injury and damage to the equipment or the system. Ignoring this information can lead to death, serious injury, or severe damage to the equipment.

- Make sure to fully understand the dangers and safety measures present in the application.
- Before performing any electrical work on the drive, lock out and tag out all power sources to the drive.

### ⚠ WARNING ⚠

#### HAZARDOUS VOLTAGE

AC drives contain hazardous voltage when connected to the AC mains or connected on the DC terminals. Failure to perform installation, start-up, and maintenance by qualified personnel can result in death or serious injury.

- Only qualified personnel must perform installation, start-up, and maintenance.



## ⚠ WARNING ⚠

### DISCHARGE TIME

The drive contains DC-link capacitors, which can remain charged even when the drive is not powered. High voltage can be present even when the warning indicator lights are off.

- Stop the motor, disconnect AC mains, permanent magnet type motors, and remove DC-link supplies, including battery back-ups, UPS, and DC-link connections to other drives.
- Wait for the capacitors to discharge fully and measure it before performing any service or repair work.
- The minimum waiting time is specified in the table *Discharge time*.

Table 2: Discharge Time

Enclosure size	Voltage [V AC]	Power range [kW (hp)]	Minimum waiting time (minutes)
MA01c	1x200–240	0.37–0.75 (0.5–1.0)	4
MA02c	1x200–240	1.5 (2.0)	4
MA02a	1x200–240	2.2 (3.0)	4
MA01a	3x380–480	0.37–1.5 (0.5–2.0)	4
MA02a	3x380–480	2.2–4.0 (3.0–5.5)	4
MA03a	3x380–480	5.5–7.5 (7.5–10)	4
MA04a	3x380–480	11–15 (15–20)	15
MA05a	3x380–480	18.5–22 (25–30)	15

## ⚠ CAUTION ⚠

### INTERNAL FAILURE HAZARD

An internal failure in the drive can result in serious injury when the drive is not properly closed.

- Ensure that all safety covers are in place and securely fastened before applying power.

## ⚠ CAUTION ⚠

### HOT SURFACES

Some drives contain metal components that are still hot even after the drive has been powered off. Failure to observe the high temperature symbol (yellow triangle) on the drive can result in serious burns.

- Be aware that internal components may be extremely hot even after the drive has been powered off.
- Do not touch exterior areas that are marked by the high temperature symbol (yellow triangle). These areas are hot while the drive is in use and immediately after being powered off.

## 1.8 Qualified Personnel

To allow trouble-free and safe operation of the unit, only qualified personnel with proven skills are allowed to transport, store, assemble, install, program, commission, maintain, and decommission this equipment.

Persons with proven skills:

- Are qualified electrical engineers, or persons who have received training from qualified electrical engineers and are suitably experienced to operate devices, systems, plant, and machinery in accordance with pertinent laws and regulations.
- Are familiar with the basic regulations concerning health and safety/accident prevention.
- Have read and understood the safety guidelines given in all guides provided with the unit, especially the instructions given in the operating guide of the drive.
- Have good knowledge of the generic and specialist standards applicable to the specific application.

## 2 Approvals and Certifications

### 2.1 Product Approvals and Certifications

iC2-Micro Frequency Converters comply with the required standards and directives. For detailed information on which approvals and certifications a product has, see the product type label, and [www.danfoss.com](http://www.danfoss.com).

Certificates and Declarations of Conformity are available on request or at [www.danfoss.com](http://www.danfoss.com).

Table 3: Approvals and Certifications Applicable to Drives








Approval	Description
	The drive complies with relevant directives and their related standards for the extended Single Market in the European Economic Area. For more information, see <a href="#">Table 4</a> .
	The Underwriters Laboratory (UL) mark indicates the safety of products and their environmental claims based on standardized testing. The drive complies with UL 61800-5-1. For UL file number, see the product label.
	The CSA/cUL approval is for drives of voltage rated at 600 V or lower. Compliance with the relevant UL/CSA standard makes sure that safety design together with relevant information and markings, ensures that when the drive is installed and maintained according to the provided operating or installation guide, the equipment meets the UL standards for electrical and thermal safety. This mark shows that the product complies with all required engineering specifications and testing. A certificate of compliance is provided on request.
	The drive complies with relevant regulation and their related standards for Great Britain. <b>UKCA contact information:</b> Danfoss, 22 Wycombe End, HP9 1NB, Great Britain
	The RCM Mark label indicates compliance with the applicable technical standards for Electromagnetic Compatibility (EMC). An RCM Mark label is required for placing electrical and electronic devices on the market in Australia and New Zealand. The RCM Mark regulatory arrangements only deal with conducted and radiated emission. For drives, the emission limits specified in EN/IEC 61800-3 apply. A declaration of conformity can be provided on request.
	The drive complies with relevant directives and their related standards for the Morocco market. Download the French product guides from <a href="https://www.danfoss.com/en/service-and-support/">https://www.danfoss.com/en/service-and-support/</a> .
	The Korea Certification (KC) Mark indicates that the product conforms to relevant Korean standards.

Table 4: EU Directives Applicable to Drives

EU Directive	Description
Low Voltage Directive (2014/35/EU)	The aim of the Low Voltage Directive is to protect persons, domestic animals and property against dangers caused by the electrical equipment, when operating electrical equipment that is installed and maintained correctly, in its intended application. The directive applies to all electrical equipment in the 50–1000 V AC and the 75–1500 V DC voltage ranges.
EMC Directive (2014/30/EU)	The purpose of the EMC (electromagnetic compatibility) Directive is to reduce electromagnetic interference and enhance immunity of electrical equipment and installations. The basic protection requirement of the EMC Directive states that devices that generate electromagnetic interference (EMI), or whose operation could be affected by EMI, must be designed to limit the generation of electromagnetic interference and shall have a suitable degree of immunity to EMI when properly installed, maintained, and used as intended.

EU Directive	Description
	Electrical equipment devices used alone or as part of a system must bear the CE mark. Systems do not require the CE mark, but must comply with the basic protection requirements of the EMC Directive.
Machinery Directive (2006/42/EC)	The aim of the Machinery Directive is to ensure personal safety and avoid property damage to mechanical equipment used in its intended application. The Machinery Directive applies to a machine consisting of an aggregate of interconnected components or devices of which at least 1 is capable of mechanical movement. Drives with an integrated functional safety function must comply with the Machinery Directive. Drives without a functional safety function do not fall under the Machinery Directive. If a drive is integrated into a machinery system, Danfoss can provide information on safety aspects relating to the drive. When drives are used in machines with at least 1 moving part, the machine manufacturer must provide a declaration stating compliance with all relevant statutes and safety measures.
ErP Directive (2009/125/EC)	The ErP Directive is the European Ecodesign Directive for energy-related products. The directive sets ecodesign requirements for energy-related products, including drives, and aims at reducing the energy consumption and environmental impact of products by establishing minimum energy-efficiency standards.
RoHS Directive	The Restriction of Hazardous Substances (RoHS) Directive is an EU directive that restricts the use of hazardous materials in the manufacturing of electronic and electrical products. Read more on <a href="http://www.danfoss.com">www.danfoss.com</a> .
Waste Electrical and Electronic Equipment Directive (2012/19/EU)	The Waste Electrical and Electronic Equipment Directive (WEEE Directive) sets collection, recycling and recovery targets for all types of electrical goods.

## 2.2 Standards

Installation must be in accordance with national regulations, for example NEC NFPA 70, or IEC 60364 series of standards.

The following standards are recommended as guidelines for the installation and operation of drives:

- **EN IEC 61800-2:2015 Adjustable speed electrical power drive systems - Part 2:** General requirements - Rating specifications for low voltage adjustable speed AC power drive systems.
- **EN IEC 61800-3:2018 Adjustable speed electrical power drive systems - Part 3:** EMC requirements and specific test methods.
- **EN IEC 61800-5-1:2017 Adjustable speed electrical power drive systems - Part 5-1:** Safety requirements - Electrical, thermal, and energy.
- **EN IEC 61800-9-2:2017 Adjustable speed electrical power drive systems - Part 9-2:** Ecodesign for power drive systems, motor starters, power electronics and their driven applications - Energy efficiency indicators for power drive systems and motor starters.

Declarations of conformity are available at [www.danfoss.com/en/service-and-support/documentation/](http://www.danfoss.com/en/service-and-support/documentation/).

## 2.3 Export Control Regulation

AC drives can be subject to regional and/or national export control regulations. Both the EU and US have regulations for so-called dual-use products (products for both military and non-military use), which currently includes AC drives with a capacity to operate from 600 Hz upwards. These products can still be sold, but it requires a set of measures, for example a license, or an end-user statement.

The US also has regulations for AC drives with a capacity to operate 300–600 Hz with restrictions on sales for certain countries. US regulations apply to all products manufactured in the US, exported from or via the US, or with a US content of more than 25%, or 10% for some countries.

An ECCN number is used to classify all AC drives that are subject to export control regulations. The ECCN number is provided in the documentation accompanying the AC drive. If the AC drive is re-exported, it is the responsibility of the exporter to ensure compliance with the relevant export control regulations.

For further information, contact Danfoss Drives Global or the local sales office.

### 3 iC2-Micro Frequency Converters

#### 3.1 Intended Use

The drive is an electronic motor controller intended for:

- Regulation of motor speed in response to system feedback or to remote commands from external controllers. A power drive system consists of the drive and the motor.
- System and motor status surveillance.

The drive can also be used for motor overload protection.

Depending on the configuration, the drive can be used in standalone applications or form part of a larger appliance or installation.

The drive is allowed for use in residential, industrial, and commercial environments in accordance with local laws and standards.

### N O T I C E

In a residential environment, this product can cause radio interference, in which case supplementary mitigation measures can be required.

#### Foreseeable misuse

Do not use the drive in applications which are non-compliant with specified operating conditions and environments. Ensure compliance with the conditions specified in *chapter Specifications*.

#### 3.2 Block Diagram




Illustration 1: Block Diagram of iC2-Micro Frequency Converters

Table 5: Functions of Each Component

Area	Component	Functions
1	Mains input	AC mains supply to the drive.
2	RFI filter	RFI filter is used to meet the regulatory requirements of electromagnetic compatibility.
3	Rectifier	The rectifier bridge converts the AC input to DC current to supply inverter power.
4	DC bus	Intermediate DC bus circuit handles the DC current.
5	DC reactor <sup>(1)</sup>	<ul style="list-style-type: none"> <li>• Filters the DC-link current.</li> <li>• Provides mains transient protection.</li> <li>• Reduces the root mean square (RMS) current.</li> <li>• Raises the power factor reflected back to the line.</li> <li>• Reduces harmonics on the AC input.</li> </ul>
6	Capacitor bank	<ul style="list-style-type: none"> <li>• Stores the DC power.</li> <li>• Provides ride-through protection for short power losses.</li> </ul>
7	Brake chopper <sup>(2)</sup>	Brake chopper is used in the DC link to control DC voltage when the load feeds energy back.

Area	Component	Functions
8	Inverter	Converts the DC into a controlled PWM AC waveform for a controlled variable output to the motor.
9	Output to motor	Regulated 3-phase output power to the motor.
10	Control circuitry	<ul style="list-style-type: none"> <li>Input power, internal processing, output, and motor current are monitored to provide efficient operation and control.</li> <li>User interface and external commands are monitored and performed.</li> <li>Status output and control can be provided.</li> </ul>

<sup>1</sup> DC reactor is only applicable to MA05a.


<sup>2</sup> Brake chopper is not applicable to MA01a.

### 3.3 Ecodesign for Power Drive Systems

Energy-efficiency of the overall system is important and compliance with relevant legislation is required in the extended single market in the European Economic Area.

Frequency converters are classified by efficiency classes IE0 to IE2 according to IEC 61800-9-2 and EN 50598-2. According to the standard, power losses are measured as percentages of the rated apparent output power at 8 load points as shown in [Illustration 2](#). Together with information about other elements of the system, this information can be used to calculate a system level efficiency (IES).

Elements causing losses are described in [3.3.1 Power Losses and Efficiency](#).



**Illustration 2: Operating Point According to IEC 61800-9-2 (EN 50598)**

The frequency converter is labeled with the efficiency class and the power losses at 100% rated torque-producing current and 90% rated motor stator frequency.

[MyDrive® ecoSmart™](#) can be used to:

- Look up part load data as defined in IEC 61800-9-2.
- Calculate the efficiency class and part load efficiency for the frequency converter and the Power Drive System.
- Create a report documenting part load loss data and IE and IES efficiency class.

#### 3.3.1 Power Losses and Efficiency

Elements causing power loss in the system are shown in [Illustration 3](#).




Illustration 3: Drive System Design

The following components can cause losses in the system:

- Mains supply cable.
- External input filter (if installed).
- Frequency converter, including built-in filters.
- External output filter (if installed).
- Motor cable.
- Motor.

The frequency converter itself only provides a part of the total losses of the system.

#### Mains supply cable

Losses in the mains supply cable are mainly caused by the ohmic resistance of the cable. To keep the losses at a minimum, the cable length should be kept short and sized properly to the rated current.

#### External input filter

Externally added input filters add to the losses in the system. Line reactors used to balance the load between multiple drives in a load sharing setup typically have a voltage drop of approximately 1%, causing up to 1% losses at full load.

Dedicated harmonic filters typically have losses of 2–5%.

#### Frequency converter

The loss of the frequency converter is load-dependent. Specific classifications and power loss data are shown on the product label, and details can be seen in [MyDrive® ecoSmart™](#).

#### External output filter

Externally connected output filters add losses to the system:

- Sine-wave filters suppress the PWM pattern of the output frequency, resulting in a sine wave output. The resulting loss is load dependent and can be up to 1–1.5% of maximum power. Using a sine-wave filter can in installations with long motor cables result in a better overall efficiency.
- dU/dt filters limits the voltage rise time of the PWM pattern. As a result, the filters introduce loss in the system – Loss is load dependent and can be up to 0.5-1% of maximum power.
- Common mode cores mitigate high frequency noise in the motor cable. As a result, limited loss is added to the system.

#### Motor cable

Losses in the motor cable are mainly caused by ohmic losses, but due to the switching frequency of the frequency converter, losses are also caused by capacitive coupling to ground. Losses due to capacitive coupling can be reduced by carefully selecting the motor cable and keeping the cable length as short as possible. If a sine-wave filter is used on the frequency converter output, the loss caused by capacitive load is lower.

#### Motor

Motor losses depend on the motor type and efficiency category selected. IEC60034-30-1 defines the different efficiency classes from IE1 to IE4.

## 3.4 Power Hardware

iC2-Micro Frequency Converters are designed to fit a wide variety of installation locations. The units are available in different protection ratings, making them suitable for installation in cabinets, directly on machines, in dedicated control rooms and freely installed.

- IP20/Open Type is designed for installation in enclosed cabinets and similar setups.
- IP21/UL Type 1 (IP21/Type 1 conversion kit as an option) is designed for indoor installations.



iC2-Micro Frequency Converters are suitable for use in a wide temperature range. The standard operating temperature range is from -10 °C to +50 °C (14 °F to +122 °F). With derating, the operating temperature range is from -20 °C to +55 °C (-4 °F to +131 °F). iC2-Micro Frequency Converters are designed for operation in altitudes up to 2000 m (6562 ft). Derating should be considered for altitudes above 1000 m (3280 ft).

The motor output of the iC2-Micro Frequency Converters is protected against short circuit, ground fault, and overload. Thermal monitoring is also provided to protect the motor. Unlimited switching on output enables using a contactor or disconnects between the drive and the motor.

Integrated filters optimize EMC performance, reduce harmonics on the grid, and match with output requirements. Built-in EMC filters can be configured to fit the EMC-related installation requirements. The offering covers:

- Drives without filter (C4 compliant variants).
- Drives with filters for use in industrial networks (C2 compliant variants) and domestic installations (C1 compliant variants).

### 3.5 Control and Interfaces

#### 3.5.1 Control Terminals

- All control cable terminals are located underneath the terminal cover in front of the drive.
- See the back of the terminal cover for outlines of control terminals and switches.

## NOTICE

Remove the terminal cover with a screwdriver, see [Illustration 4](#).




Illustration 4: Removing Terminal Cover

All control terminals of iC2-Micro Frequency Converters are shown in [Illustration 5](#).




Illustration 5: Overview of Control Terminals

### 3.5.2 RJ45 Port and RS485 Termination Switch

The drive has an RJ45 port which complies with Modbus 485 protocol. The RJ45 port is used for connecting:

- External control panel (not available currently).
- PC tool (MyDrive® Insight) via an adapter option (not available currently).
- Offline configuration tool for parameter settings when the drive is not powered on (not available currently).




Illustration 6: RJ45 Port and RS485 Termination Switch

1	RJ45 port
2	RS485 termination switch (ON=RS485 terminated, OFF=Open)

#### NOTICE

The RJ45 port supports up to 3 m (9.8 ft) of shielded CAT5e cable which is **NOT** used to directly connect the drive to a PC. Failure to follow this notice causes damage to the PC.

#### NOTICE

- RS485 termination switch should be set to ON if the drive is at the end of the fieldbus.
- Do not operate RS485 termination switch when the drive is powered on.




Illustration 7: Pin Definition of RJ45

1	5 V power supply	5	RS485_N
2	5 V power supply	6	GND
3	GND	7	Reserved
4	RS485_P	8	Reserved

### 3.5.3 Control Panel and Control Panel 2.0 OP2

The drive has 2 types of control panels as follows:

- **Control Panel:** It is inbuilt and by default delivered with the drive. The control panel keys and indicators are described in [3.5.4 Control Panel Keys and Indicators](#).
- **Control Panel 2.0 OP2:** An optional (accessory) control panel which provides better user experience. This type of control panel enables to easily set up the drive via parameters, monitor drive status, and visualization of event notifications.

A more detailed overview of Control Panel 2.0 OP2 is as follows:

- 2.03" monochromatic user interface.
- Visual LEDs to identify drive status.
- Controls the drive and easily switch between local and remote operations.
- Multilingual display which contributes to show parameters, selections, and status more clearly.
- Parameter display supports alphanumeric, special characters, integers, floating points, choice lists, and commands to configure application data.
- Parameter settings of the drive can be copied to other drives for easy commissioning.
- Installation on a cabinet door using a mounting kit option.

**NOTICE**

Control Panel 2.0 OP2 is not available currently.

### 3.5.4 Control Panel Keys and Indicators




Illustration 8: Control Panel

1	Status indicators	9	Start
2	Operating indicators	10	Back
3	Home/Menu	11	Remote/Local
4	Left	12	OK
5	Stop/Reset	13	Potentiometer
6	Up	14	Status indicators
7	Down	15	Main display
8	Run indicator		

Table 6: Operation Keys and Potentiometer

Name	Function
Home/Menu	Toggles between main menu and status view. Long press to access the shortcut menu for quickly reading and editing parameters. <sup>(1)</sup>
Up/Down	Switches status/parameter group/parameter numbers, and tunes the parameter values.
Left	Moves the cursor 1 bit to the left.
Back	Navigates to the previous step in the menu structure or cancels the setting during tuning parameter values.
OK	Confirms the operation.
Remote/Local	Toggles between the remote mode and local mode.
Start	Starts the drive in local mode.
Stop/Reset	Stops the drive in local mode.
	Resets the drive to clear a fault.
Potentiometer	Changes the reference value when the reference value is selected as potentiometer.

<sup>1</sup> The shortcut menu is not available currently.

Table 7: Status Indicator Lights

Name	Function
MON	On: The main display is showing the drive status.
PGM	On: The drive is in programming status.
TOR	On: The drive is in torque mode.
	Off: The drive is in speed mode.
LOC	On: The drive is in local mode.
	Off: The drive is in remote mode.
REV	On: The drive is in reverse direction.
	Off: The drive is in forward direction.
ST2	Refer to <a href="#">Table 10</a> .

Table 8: Operating Indicator Lights

Name	Function
WARN	Steadily lit when a warning occurs.
READY	Steadily lit when the drive is ready.
FAULT	Flashes when a fault occurs.

Table 9: Run Indicator Light

Name	Function
RUN	On: The drive is in normal operation.
	Off: The drive has stopped.
	Flash: In the motor-stopping process; or the drive received a <i>RUN</i> command, but no frequency output.

Table 10: Multiple Setups Indicator Light

ST2	Off	On	Flash	Flash quickly
Active setup <sup>(1)</sup>	Setup 1	Setup 2	Setup 1	Setup 2
Programming setup <sup>(2)</sup>	Setup 1	Setup 2	Setup 2	Setup 1

<sup>1</sup> Select active setup in *parameter P6.6.1 Active Setup*.

<sup>2</sup> Select programming setup in *parameter P6.6.2 Programming Setup*.

### 3.5.5 Sliding Door on the Terminal Cover

A sliding door, which is the protective cover of the RJ45 port, is designed on the terminal cover of the drive. When the drive is connected with the Control Panel 2.0 OP2 option which can be installed on the cabinet door, just remove the sliding door to ensure that the terminal cover remains on the drive, so as to ensure safe operation.





Illustration 9: Sliding Door on the Terminal Cover

1	Sliding door
2	Terminal cover

#### Disassembly

1. Remove the terminal cover with a screwdriver, see [3.5.1 Control Terminals](#).

- From the inner side of the terminal cover, press the slot with a screwdriver to release the sliding door and slide it out.




e30bv109.10

Illustration 10: Removing the Sliding Door

**Reassembly**

- Slide the sliding door into the terminal cover.



e30bv110.10

Illustration 11: Installing the Sliding Door

### 3.6 Application Software

#### 3.6.1 Overview

The application software is the default and standard software delivered with the iC2-Micro Frequency Converters. The features are briefly described in the following sections:

- Basic functions.
- Controllers.
- Protection features.
- Software tools.



## 3.6.2 Basic Functions

The application software consists of wide range of basic features which enables the drive to control any application using the iC2-Micro drive.

### 3.6.2.1 Reference Handling

References from multiple sources, matching the needs to control the application, are freely definable.

Reference sources are:

- Analog inputs
- Digital inputs either as pulse input.
- Reference from a field bus
- Internal settings
- Local reference from control panel
- Built-in potentiometer on control pannel

Reference signals can be added generating the reference to the frequency converter. The final reference is scaled from -100% to 100%.

### 3.6.2.2 Two Setups

The frequency converter offers 2 setups. Each setup can be parameterized independently to match various application needs. Switching between setups is possible during operation, allowing fast change over.

### 3.6.2.3 Ramps

Linear, Sine ramp, Sine 2 ramps are supported in the frequency converter. The linear ramps provide a constant acceleration. The Sine ramps provides a non-linear acceleration with soft transition at start and end of the acceleration process.

### 3.6.2.4 Quick Stop

In some situations, it may be required to stop the application in a quick way. For this purpose, the drive supports a specific deceleration ramp time from the synchronous motor speed to 0 RPM.

### 3.6.2.5 Limit Rotation Direction

The rotational direction of the motor can be preset to run in 1 direction only (clockwise or counterclockwise), avoiding unintended rotation direction.

### 3.6.2.6 Motor Phase Switch

If motor phase cables have been installed in an incorrect order during installation, the rotation direction can be changed. This eliminates the need to change the order of motor phases.

### 3.6.2.7 Inching with Jogging Modes

The frequency converter has predefined speed settings for use during commissioning, maintenance, or service. The jogging-mode operation is set at preset speed.

### 3.6.2.8 Frequency Bypass

Specific motor frequencies can be bypassed during operation. The feature helps to minimize and avoid mechanical resonance of the machine, limiting vibration and noise of the system.

### 3.6.2.9 Automatic Restart

In case of a minor fault and trip, the drive can do an automatic restart, eliminating a manual reset of the drive. This enhances automated operation in remotely controlled systems. Make sure that dangerous situations cannot occur when using automatic restart.

### 3.6.2.10 Flying Start

Flying start enables the drive to synchronize to a freely spinning motor, before taking control of the motor. Taking over control of the motor at the actual speed minimizes mechanical stress to the system. For example, the feature is relevant in fan and centrifuge applications.

### 3.6.2.11 Mains Dropout

In case of mains dropout, where the drive cannot continue operation, it is possible to select predefined actions, for example trip, coast, or performing a controlled ramp down.

### 3.6.2.12 Kinetic Backup

Kinetic backup enables the drive to remain in control in case there is sufficient energy in the system, for example, as inertia or when lowering a load. This allows a controlled stop of the machine.

### 3.6.2.13 Resonance Damping

High frequency motor resonance noise can be eliminated through the use of resonance damping. Both automatic and manually selected frequency damping are available.

### 3.6.2.14 Mechanical Brake Control

In applications like simple hoists, palletizers, stereoscopic warehouse, or downhill conveyors, a mechanical brake is used to keep the load at standstill, when the motor is not controlled by the drive or when power is turned off.

The mechanical brake control feature ensures a smooth transition between the mechanical brake and motor holding the load, by controlling the activation and deactivation of the mechanical brake.

### 3.6.2.15 Controllers

The drive has 3 different controllers providing optimized control of the actual application. The controllers cover

- Process control
- Speed control open loop
- Torque control open loop

#### 3.6.2.15.1 Process Controller

The process controller can control a process, for example in a system where a constant pressure, flow, or temperature is needed. A feedback from the application is connected to the drive, providing the actual output value. The controller ensures that the output is matching the reference provided by controlling the motor speed. The reference source and the feedback signals are converted and scaled to the actual values controlled.

#### 3.6.2.15.2 Speed Controller

The open-loop speed control provides accurate control of the motors rotational speed.

In open-loop mode (without external feedback signal of the speed), there is no need for external sensors, making installation and commissioning very easy, and eliminating the risk of defective sensors.

#### 3.6.2.15.3 Torque Controller

A built-in torque controller provides optimized control of torque and supports open-loop control.

### 3.6.3 IO Control and Readouts

Depending on the hardware configuration of the drive, digital and analog inputs, digital and analog outputs, and relay outputs are available. The I/O can be configured and used to control the application from the drive.

All I/O can be used as remote I/O nodes, as they are all addressed by the fieldbus of the drive.

### 3.6.4 Motor Control Features

The motor control covers a wide range of applications, control from the most basic applications to applications requiring high-performance motor control.

#### 3.6.4.1 Motor Types

The drive supports standard available motors like:

- Asynchronous motors
- Permanent magnet motors

#### 3.6.4.2 Load Characteristics

Different load characteristics are supported to match the actual application needs:

- **Variable torque:** Typical load characteristic of fans and centrifugal pumps, where the load is proportional to the square of the speed.
- **Constant torque:** Load characteristic used in machinery where torque is needed across the full speed range. Typical application examples are conveyors, extruders, decanters, compressors, and winches.

### 3.6.4.3 Motor Control Principle

Different control principles can be selected to control the motor, matching the application needs:

- U/f control for special control
- VVC+ control for the general-purpose application needs

### 3.6.4.4 Motor Nameplate and Catalog

Typical motor data for the actual drive are preset from factory, allowing operation of most motors. During commissioning, actual motor data are entered in the settings of the drive, optimizing the motor control.

### 3.6.4.5 Automatic Motor Adaptation (AMA)

Automatic Motor Adaptation (AMA) provides optimization of motor parameters for improved shaft performance. Based on motor nameplate data and measurements of the motor at standstill, key motor parameters are being recalculated and used to fine tune the motor control algorithm.

### 3.6.4.6 Automation Energy Optimization (AEO)

The Automatic Energy Optimizer (AEO) feature optimizes the control with focus on lowering energy consumption at the actual load point.

## 3.6.5 Braking of Load

When braking the motor controlled by the drive, various functions can be used. The specific function is selected based on the application and the needs for how fast it should be stopped.

### 3.6.5.1 Resistor Braking

In applications where fast or continuous braking is required, a drive fit with a brake chopper is typically used. Excess energy generated by the motor during braking of the application will be dissipated in a connected brake resistor. Braking performance depends on the specific drive rating and selected brake resistor.

### 3.6.5.2 Overvoltage Control (OVC)

If braking time is not critical or the load is varying, the overvoltage control (OVC) feature is used to control stopping the application. The drive extends the ramp down time when it is not possible to brake within the defined ramp-down period. The feature should not be used in hoisting applications, high inertia systems, or where continuous braking is required.

### 3.6.5.3 DC Brake

When braking at low speed, the braking of the motor can be improved by using the DC brake feature. It adds a small DC current on top of the AC current, slightly increasing the brake capability.

### 3.6.5.4 AC Brake

In applications with non-cyclic operation of the motor, AC braking can be used to shorten the braking time and is only supported for asynchronous motors. Excess energy is dissipated by increasing losses in the motor during braking.

### 3.6.5.5 DC Hold

DC hold provides a limited holding torque on the rotor at standstill.

### 3.6.5.6 Load Sharing

In some applications, 2 or more drives are controlling the application at the same time. If 1 of the drives is braking a motor, the excess energy can be fed to the DC link of a drive driving a motor, with a reduction of the total energy consumption. This feature is useful in, for examples, decanters and carding machines, where smaller power sized drive operates in generator mode.

## 3.6.6 Protection Features

### 3.6.6.1 Grid Protections

The drive protects against conditions on the power grid that can affect proper operation.

The grid is monitored for phase imbalance and phase loss. If the imbalance exceeds internal limits, a warning is provided and the user can initiate proper actions.

In case of an under- or overvoltage on the grid, the drive will provide a warning and stop operation if the situation remains or exceeds critical limits.

### 3.6.6.2 Drive Protection Features

The drive is monitored and protected during operation.

Inbuilt temperature sensors measure the actual temperature and provide relevant information to protect the drive. If the temperature exceeds its nominal temperature conditions, derating will be applied. If the temperature is outside the allowed operating range, the drive will stop operation.

The motor current is continuously monitored on all 3 phases. In case of a short circuit between 2 phases or a fault to ground, the drive will detect this and immediately turn off. If the output current is exceeding its nominal values during operation for longer periods than allowed, the drive will stop and report overload alarm.

The DC-link voltage of the drive is monitored. If it exceeds critical levels, a warning is issued and the drive will stop. If the situation is not resolved, the drive will issue an alarm.

### 3.6.6.3 Motor Protection Features

The drive provides various features to protect the motor and the application.

The output current measurement provides information to protect the motor. Overcurrent, short circuit, ground faults, and lost motor phase connections can be detected and relevant protections initiated.

Monitoring of speed, current, and torque limits provides an additional protection of the motor and the application.

Locked rotor protection secures that the drive is not starting with a blocked rotor of the motor.

Motor thermal protection is provided either as a calculation of the motor temperature based on the actual load or by the means of external temperature sensors, for example PTC.

### 3.6.6.4 Protection of Externally Connected Components

Externally connected options like brake resistors can be monitored.

Brake resistors are monitored for thermal overload, short circuit, and missing connection.

### 3.6.6.5 Automatic Derating

Automatic derating of the drive allows continued operation even if the nominal operation conditions are exceeded. Typical factors affecting this are temperature, high DC-link voltage, high motor load, or operation close to 0 Hz. Derating is typically applied as a reduction in switching frequency or change in switching pattern, resulting in lower thermal losses.

## 3.6.7 Monitoring Features

The drive offers a wide range of monitoring features providing information of operation conditions, grid conditions, and drive historical data. Access to this information helps out analyzing operational conditions and identification of faults.

### 3.6.7.1 Speed Monitoring

The motor speed can be monitored during operation. If the speed exceeds minimum and maximum limits, the user is notified and can initiate appropriate actions.

### 3.6.7.2 Event Log and Operational Counters

An event log provides access the latest registered faults, providing relevant information for analysis of what occurred in the drive.

Operational counters offer information about the drive usage. Values like operation hours, running hours, kWh used, number of power-ups, overvoltages and overtemperatures are examples of the readouts available.

## 3.6.8 Software Tools

MyDrive® Insight is a software tool for commissioning, engineering, and monitoring drives. MyDrive® Insight can be used to configure the parameters, upgrade software, and set up features.

## 3.7 Brake Functions

### 3.7.1 Mechanical Holding Brake

A mechanical holding brake mounted directly on the motor shaft normally performs static braking.

#### NOTICE

When the holding brake is included in a safety chain, a drive cannot provide a safe control of a mechanical brake.

- Include a redundancy circuitry for the brake control in the total installation.

### 3.7.2 Dynamic Braking

Dynamic braking is established by:


- Resistor brake: A brake IGBT keeps the overvoltage under a certain threshold by directing the brake energy from the motor to the connected brake resistor (*parameter P3.2.1 Enable Brake Chopper = [1] Enable*). Adjust the threshold in *parameter P3.2.2 Brake Chopper Voltage Reduce*, with 70 V range for 3x380–480 V.
- AC brake: The brake energy is distributed in the motor by changing the loss conditions in the motor. The AC brake function cannot be used in applications with high cycling frequency as this overheats the motor (*parameter P3.2.1 Enable Brake Chopper = [1] Enable*).
- DC brake: An overmodulated DC current added to the AC current works as an eddy current brake (*parameter P5.7.3 DC Brake Time ≠ 0 s*).

### 3.7.3 Brake Resistor Selection

#### 3.7.3.1 Introduction

To handle higher demands by generative braking, a brake resistor is necessary. Using a brake resistor ensures that the heat is absorbed in the brake resistor and not in the drive.

If the amount of kinetic energy transferred to the resistor in each braking period is not known, calculate the average power based on the cycle time and braking time. The resistor intermittent duty cycle is an indication of the duty cycle at which the resistor is active. A typical braking cycle is shown in [Illustration 12](#).



**Illustration 12: Typical Braking Cycle**

The intermittent duty cycle for the resistor is calculated as follows:

$$\text{Duty cycle} = t_b / T$$

$t_b$  is the braking time in seconds.

$T$  = cycle time in seconds.

Table 11: Braking at High Overload Torque Level

Power range: 0.37–22 kW (0.5–30 hp) 3x380–480 V	
Cycle time (s)	120
Braking duty cycle at 100% torque	Continuous
Braking duty cycle at overtorque (150/160%)	40%

Danfoss offers brake resistors with duty cycles of 10% and 40%. If a 10% duty cycle is applied, the brake resistors are able to absorb brake power for 10% of the cycle time. The remaining 90% of the cycle time is used for dissipating excess heat.

### N O T I C E

Make sure that the resistor is designed to handle the required braking time.

### 3.7.3.2 Brake Resistance Calculation

The maximum allowed load on the brake resistor is stated as a peak power at a given intermittent duty cycle and can be calculated as:

$$R_{br} [\Omega] = \frac{U_{dc,br}^2 \times 0.83}{P_{peak}}$$

where

$$P_{peak} = P_{motor} \times M_{br} [\%] \times \eta_{motor} \times \eta_{VLT} [W]$$

As shown, the brake resistance depends on the DC-link voltage ( $U_{dc}$ ).

Table 12: Threshold of the Brake Resistance

Size	Brake active $U_{dc,br}$	Warning before cutout	Cutout (trip)
3x380–480 V	770 V	800 V	800 V

The threshold can be adjusted in *parameter P3.2.2 Brake Chopper Voltage Reduce*, with 70 V range.

### N O T I C E

The greater the reduction value, the faster the reaction to a generator overload. Should only be used if there are problems with overvoltage in the DC-link voltage.

### N O T I C E

Make sure that the brake resistor can cope with a voltage of 800 V.

### 3.7.3.3 Danfoss Recommended Brake Resistance Calculation

Danfoss recommends calculating the brake resistance  $R_{rec}$  according to the following formula. The recommended brake resistance guarantees that the drive is able to brake at the highest braking torque ( $M_{br(150\%)}$ ) of 150%.

$$R_{rec} [\Omega] = \frac{U_{dc}^2 \times 100 \times 0.83}{P_{motor} \times M_{br(150\%)} \times \eta_{VLT} \times \eta_{motor}}$$

$\eta_{motor}$  is typically at 0.80 ( $\leq 7.5$  kW/10 hp); 0.85 (11–22 kW/15–30 hp).

$\eta_{VLT}$  is typically at 0.97.

For iC2-Micro Frequency Converters,  $R_{rec}$  at 150% braking torque is written as:

$$480V : R_{rec} = \frac{396349}{P_{motor}} [\Omega]$$

for drives  $\leq 7.5$  kW (10 hp) shaft output.



$$480V : R_{rec} = \frac{397903}{P_{motor}} [\Omega]$$

for drives as 11–22 kW (15–30 hp) shaft output.

### N O T I C E

The resistance of the brake resistor should not be higher than the value recommended by Danfoss. For brake resistors with a higher ohmic value, the 150% braking torque may not be achieved because the drive might cut out for safety reasons. The resistance should be bigger than  $R_{min}$ .

### N O T I C E

If a short circuit in the brake transistor occurs, prevent power dissipation in the brake resistor by using a mains switch or contactor to disconnect the mains for the drive. The drive can control the contactor.

### N O T I C E

Do not touch the brake resistor because it can get hot during braking. To avoid fire risk, place the brake resistor in a secure environment.

### 3.7.4 Control with Brake Function

The brake is protected against short-circuiting of the brake resistor, and the brake transistor is monitored to ensure that short-circuiting of the transistor is detected. A relay/digital output can be used for protecting the brake resistor from overloading caused by a fault in the drive.

In addition, the brake enables readout of the momentary power and the mean power for the latest 120 s. The brake can also monitor the power energizing and make sure that it does not exceed a limit selected in *parameter P3.3.3 Brake Resistor Power Limit*.

### ⚠ W A R N I N G ⚠

Monitoring the brake power is not a safety function. A thermal switch is required to prevent the brake power from exceeding the limit. The brake resistor circuit is not ground leakage protected.

Overvoltage control (OVC) (exclusive brake resistor) can be selected as an alternative brake function in *parameter P2.3.1 Overvoltage Controller Enable*. This function is active for all units. The function ensures that a trip can be avoided if the DC-link voltage increases. This is done by increasing the output frequency to limit the voltage from the DC link. It is a useful function, for example if the ramp-down time is too short to avoid tripping of the drive. In this situation, the ramp-down time is extended.

### N O T I C E

OVC can be activated when running a PM motor (when *parameter P4.2.1.1 Motor Type* is set to [1] PM, Non-salient SPM).

## 4 Specifications

### 4.1 Electrical Data

#### 4.1.1 Mains Supply 1x200–240 V AC

Table 13: Mains Supply 1x200–240 V AC

Normal overload 150% for 1 minute				
Drive	02A2	04A2	06A8	09A6
Typical shaft output [kW]	0.37	0.75	1.5	2.2
Typical shaft output [hp]	0.5	1.0	2.0	3.0
Enclosure protection rating IP20	MA01c	MA01c	MA02c	MA02a
Output current				
Continuous (3x200–240 V AC) [A]	2.2	4.2	6.8	9.6
Intermittent (3x200–240 V AC) [A]	3.3	6.3	10.2	14.4
Maximum cable size				
(Mains, motor) [mm <sup>2</sup> /AWG]	4/10			
Maximum input current				
Continuous (1x200–240 V) [A]	6.1	11.6	18.7	26.4
Intermittent (1x200–240 V) [A]	8.3	15.6	26.4	37
Environment				
Power loss [W] <sup>(1)</sup>	16	31	46	61
Efficiency [%] <sup>(1)</sup>	97.5	97.6	97.6	97.9

<sup>1</sup> The value is measured at 100% rated torque-producing current and 90% rated motor stator frequency according to IEC 61800-9-2 and EN 50598-2.

#### 4.1.2 Mains Supply 3x380–480 V AC

Table 14: Mains Supply 3x380–480 V AC, MA01a–MA02a

Normal overload 150% for 1 minute						
Drive	01A2	02A2	03A7	05A3	07A2	09A0
Typical shaft output [kW]	0.37	0.75	1.5	2.2	3.0	4.0
Typical shaft output [hp]	0.5	1.0	2.0	3.0	4.0	5.5
Enclosure protection rating IP20	MA01a	MA01a	MA01a	MA02a	MA02a	MA02a
Output current						
Continuous (3x380–440 V) [A]	1.2	2.2	3.7	5.3	7.2	9.0
Intermittent (3x380–440 V) [A]	1.8	3.3	5.6	8.0	10.8	13.7
Continuous (3x440–480 V) [A]	1.1	2.1	3.4	4.8	6.3	8.2
Intermittent (3x440–480 V) [A]	1.7	3.2	5.1	7.2	9.5	12.3

Maximum cable size						
(Mains, motor) [mm <sup>2</sup> /AWG]	4/10					
Maximum input current						
Continuous (3x380–440 V) [A]	1.9	3.5	5.9	8.5	11.5	14.4
Intermittent (3x380–440 V) [A]	2.6	4.7	8.7	12.6	16.8	20.2
Continuous (3x440–480 V) [A]	1.7	3.0	5.1	7.3	9.9	12.4
Intermittent (3x440–480 V) [A]	2.3	4.0	7.5	10.8	14.4	17.5
Environment						
Power loss [W] <sup>(1)</sup>	17	25	34	48	58	74
Efficiency [%] <sup>(1)</sup>	97.3	97.8	98.0	98.3	98.5	98.3

<sup>1</sup> The value is measured at 100% rated torque-producing current and 90% rated motor stator frequency according to IEC 61800-9-2 and EN 50598-2.

## 4.2 General Technical Data

### 4.2.1 Protection and Features

- Electronic motor thermal protection against overload.
- Temperature monitoring of the heat sink ensures that the drive trips if there is overtemperature.
- The drive is protected against short circuits between motor terminals U, V, W.
- When a motor phase is missing, the drive trips and issues a fault.
- When a mains phase is missing, the drive trips or issues a warning (depending on the load).
- Monitoring of the DC-link voltage ensures that the drive trips when the DC-link voltage is too low or too high.
- The drive is protected against ground faults on motor terminals U, V, W.

### 4.2.2 Grid Side

Table 15: Mains Supply

Function	Data
Supply voltage	1x200–240 V AC $\pm 10\%$ , -15% at reduced torque performance, depending on motor type.
	3x380–480 V AC $\pm 10\%$ , -15% at reduced torque performance, depending on motor type.
Grid types	TN, TT, IT, Grounded Delta grids. For more information, see <a href="#">7.3.1 Grid Types</a> . For details on the parameters related to grid types, refer to the application guide.
Supply frequency	50/60 Hz $\pm 5\%$
Maximum temporary imbalance between mains phases	3% of rated voltage, depending on grid impedance.
True power factor ( $\lambda$ )	$\geq 0.9$ nominal at rated load
Displacement power factor	near unity ( $>0.98$ )

Function	Data
Switching on input supply from a discharged drive	MA01a–MA03a: Maximum 2 times/min
	MA04a–MA05a: Maximum 1 time/min
Environment	Overvoltage category III/pollution degree 2

### 4.2.3 Motor Output and Motor Data

Table 16: Motor Output (U, V, W)

Function	Data
Output voltage	0–100 % of supply voltage
Output frequency <sup>(1)</sup>	Induction motor <ul style="list-style-type: none"> <li>• 0–200 Hz (VVC+ mode)</li> <li>• 0–500 Hz (U/f mode)</li> </ul> PM motor <ul style="list-style-type: none"> <li>• 0–400 Hz (VVC+ mode)</li> </ul>
Frequency resolution	0.001 Hz
Switching on output	±0.003 Hz

<sup>1</sup> Dependent on voltage, current, and control mode.

### 4.2.4 Torque Characteristics

Table 17: Torque Characteristics

Function	Data
Overload torque	150% for 60 s every 10 min
Overload torque at start	200% for 1 s
Torque rise time (VVC+)	50 ms

### 4.2.5 Control I/O

This chapter covers the general specifications of the control I/O.

The standard configuration for iC2-Micro Frequency Converters is:

- 4 digital inputs.
- 1 digital I/O (digital input or output is selected by user).
- 2 analog inputs (voltage or current).
- 1 analog output (current).
- 1 relay outputs (NC/NO).
- 24 V and 10 V reference for digital and analog I/O.

All control inputs and outputs are PELV galvanic isolated from supply voltage and other high voltage terminals, unless otherwise specified.

#### 4.2.5.1 Digital and Pulse Input

Control inputs and outputs are PELV galvanically isolated from supply voltage and other high voltage terminals, unless otherwise specified.

Table 18: Digital and Pulse Input

Function		Data
Terminal number		T13, T14, T15 <sup>(1)</sup> , T17, and T18 <sup>(2)</sup> .
Digital input	Logic	Selectable PNP or NPN
	Voltage levels	0/24 V
	PNP	<ul style="list-style-type: none"> <li>"0": &lt;5 V DC</li> <li>"1": &gt;11 V DC</li> </ul>
	NPN	<ul style="list-style-type: none"> <li>"0": &gt;19 V DC</li> <li>"1": &lt; 13 V DC</li> </ul>
	Maximum allowed voltage	28 V DC
	Input resistance	Approximately 4 kΩ
Thermistor input	PTC <sup>(3)</sup>	According to DIN 44081/DIN 44082
Pulse input	Pulse frequency range	4 Hz–32 kHz
	Minimum duty cycle	40%
	Accuracy	1% of full scale

<sup>1</sup> T15 is selectable for either digital input, digital output, or pulse output. The default setting is digital input.

<sup>2</sup> T18 can also be used for pulse input.

<sup>3</sup> External insulation of the sensor is required to comply with PELV.

#### 4.2.5.2 Digital and Pulse Output

Control inputs and outputs are PELV galvanically isolated from supply voltage and other high voltage terminals, unless otherwise specified.

Table 19: Digital and Pulse Output

Function		Data
Terminal number		T15 <sup>(1)</sup>
Digital output (24 V)	Voltage level	0/24 V
	Maximum output load (sink/source)	40 mA
	Frequency range - Pulse output	4 Hz–32 kHz
	Maximum load	1 kΩ
	Maximum capacitive load at maximum frequency	10 nF
	Pulse output accuracy	0.1% of full scale
	Resolution of pulse output	10 bit

<sup>1</sup> T15 is selectable for either digital input, digital output, or pulse output. The default setting is digital input.

#### 4.2.5.3 Analog Input

Control inputs and outputs are PELV galvanically isolated from supply voltage and other high voltage terminals, unless otherwise specified.

Table 20: Analog Input

Function	Data
Terminal number	T33 and T34
Input mode	Current or Voltage <sup>(1)</sup>
Voltage mode	<ul style="list-style-type: none"> <li>Voltage range: 0–10 V (scalable)</li> <li>Input impedance: 10 k<math>\Omega</math></li> <li>Maximum voltage: +20 V/-12 V</li> </ul>
Current mode	<ul style="list-style-type: none"> <li>Current range: 0/4-20 mA (scalable)</li> <li>Input impedance: 200 <math>\Omega</math></li> <li>Maximum current: 30 mA</li> </ul>
Resolution	0.1% of full scale
Accuracy	1% of full scale
Bandwidth	100 Hz

<sup>1</sup> The selection is made in the software. For more information, refer to the application guide.

#### 4.2.5.4 Analog Output

Control inputs and outputs are PELV galvanically isolated from supply voltage and other high voltage terminals, unless otherwise specified.

Table 21: Analog Output

Function	Data
Terminal number	T31
Output range: Current	0/4-20 mA
Maximum load resistor to GND	500 $\Omega$
Resolution	0.1% of full scale
Accuracy	1% of full scale

#### 4.2.5.5 Relay Output

Relays provide PELV isolation to supply voltage, other high voltage terminals and low voltage control.

Table 22: Relay Output

Function	Data
Terminal number	01, 02, and 03
Relay configuration	SPDT (NO/NC)
Maximum terminal load (AC-1): Resistive load	250 V AC, 2 A
Maximum terminal load (AC-15): Inductive load @ $\cos\phi=0.4$	250 V AC, 0.2 A

Function	Data
Maximum terminal load (DC-1): Resistive load	30 V DC, 2 A
Maximum terminal load (DC-13): Inductive load	24 V DC, 0.1 A
Minimum load	<ul style="list-style-type: none"> <li>24 V DC, 10 mA</li> <li>24 V AC, 20 mA</li> </ul>

#### 4.2.5.6 Auxiliary Voltages

Auxiliary voltage outputs are used as reference for analog and digital inputs.

Table 23: Auxiliary Voltages

Function	Data	
10 V output	Output voltage	+10.5 V $\pm$ 0.5 V
	Maximum load	25 mA
24 V output	Output voltage	+24 V $\pm$ 20%
	Maximum load	100 mA

#### 4.2.6 RS485 Serial Communication

Table 24: RS485 Serial Communication

Function	Data
Terminal number	68 (P, TX+, RX+), 69 (N, TX-, RX-)
Terminal number	61 common for terminals 68 and 69

For more details on RS485 communication and configuration, refer to the iC2-Micro Frequency Converters Application Guide.

#### 4.2.7 Ambient Conditions

iC2-Micro Frequency Converters are designed for installation and use in weather-protected environments. The available protection ratings are:

- IP20/Open Type.
- IP21/UL Type 1 (IP21/Type 1 conversion kit as option).

The environments used as reference for the design criteria are described in the standards IEC 60721-3-1:2019, IEC 60721-3-2:2018 and, IEC 60721-3-3:2019, unless otherwise specified.

Conditions are given for:

- Storage (See [4.2.7.1 Ambient Conditions during Storage](#))
- Transport (See [4.2.7.2 Ambient Conditions during Transport](#))
- Operation (See [4.2.7.3 Ambient Conditions during Operation](#))

##### 4.2.7.1 Ambient Conditions during Storage

Table 25: Ambient Conditions during Storage

Function	Data
Ambient temperature	-25 °...+65 °C (-13 °...+149 °F)
Climatic condition	1K21, maximum 95% non-condensing
Chemically active substances	1C2



Function	Data
Solid particles (non-conductive particles/dust only)	1S11
Vibration	1M11
Shock	1M11
Biological ambient	1B1

#### 4.2.7.2 Ambient Conditions during Transport

Table 26: Ambient Conditions during Transport

Function	Data
Ambient temperature	-25 °...+70 °C (-13 °...+158 °F)
Climatic condition	2K11, maximum 95% non-condensing
Chemically active substances	2C2
Solid particles (non-conductive particles or dust only)	2S5
Vibration	2M5
Shock	2M4
Biological ambient	2B1

#### 4.2.7.3 Ambient Conditions during Operation

Table 27: Ambient Conditions during Operation

Function	Data
Ambient temperature	-10 °...+50 °C (14 °...+122 °F)
	With derating: -20 °...+55 °C (-4 °...+131 °F)
Climatic condition	3K22, maximum 95% non-condensing <sup>(1)</sup>
Chemically active substances	C3
Solid particles (non-conductive particles/dust)	3S6
Vibration	3M11
Shock	3M11
Biological ambient	3B1
Maximum altitude above sea level	Without derating: 1000 m (3280 ft)
	With derating: 1000–3000 m (3280–9243 ft) with derating of 1%/100 m (328 ft).
	For installation at altitudes above 2000 m (6562 ft), contact Danfoss hotline regarding PELV.

<sup>1</sup> Ensure maximum rate of change of temperature 0.1 °C/min (0.18 °F/min) to avoid condensation.

### 4.3 Fuses and Circuit Breakers

For proper protection of the installation cable and the drive, fuses and/or circuit breakers must be used. If short circuit occurs, fuses and circuit breakers protect the power cable and limit the damage to the drive and components connected to the drive.

When using circuit breakers, be aware of the limitation to the short-circuit capacity of the supply, and follow the installation instructions from the manufacturer. The short-circuit rating must comply with the values given in [Table 28](#).

The recommendations for fuses and circuit breakers must be followed to comply with relevant regulations. If recommendations are not followed, and problems occur, warranty may be affected. For more details, contact Danfoss.

**Table 28: Fuses and Circuit Breakers**

iC2-Micro	Non cabinet				Cabinet			Test cabinet size [Height x Width x Depth] [mm (in)]	Minimum cabinet vol- ume [L]
	UL fuses				CE fuses	UL circuit breaker	CE circuit breaker		
kW (hp)	RK1	T	J	CC	gG	ABB MS165 Maximum trip level	Eaton PKZM4 Maximum trip level		
Standard fault current SCCR	5 kA	5 kA			5 kA	5 kA	5 kA		
High fault current SCCR	–	100 kA			–	65 kA	–		
<b>1x200-240 V</b>									
0.37 (0.5)	25 A				25 A	25 A	25 A	500 x 400 x 260 (19.7 x 15.7 x 10.2)	52
0.75 (1.0)									
1.5 (2.0)	35 A				35 A	32 A	32 A		
2.2 (3.0)	40 A				50 A	42 A	50 A		
<b>3x380-480 V</b>									
0.37 (0.5)	15 A				16 A	16 A	16 A	500 x 400 x 260 (19.7 x 15.7 x 10.2)	52
0.75 (1.0)									
1.5 (2.0)									
2.2 (3.0)	30 A				40 A	32 A	32 A		
3.0 (4.0)									
4.0 (5.5)									

#### 4.4 Power Connectors

To ensure proper operation, observe the cross-section dimensions, stripping length, and tightening torques.

The dimensions apply to both solid and stranded cables. Drives are designed for use of 70 °C (158 °F) rated copper cables. If nothing else is stated, the ambient temperature of the drive matches the cable rating. Aluminum cables can be used from 35 mm<sup>2</sup> onwards. Proper connections must be secured by removing the oxide layer and applying joint compound.

### N O T I C E

Using a cable with the maximum allowed cross-section requires more effort during the installation.

Table 29: Power Cable Sizing

Enclosure size	Terminal	Cross-section [mm <sup>2</sup> (AWG)]	Torque [Nm (lb-in)]	Stripping length [mm (in)]	Connector type	Screw/lug
MA01c	Mains, motor, and DC connection	0.5–4.0 (24–10)	0.7 (6.2)	7–9 (0.28–0.35)	Terminal block	Slot
	Customer relay	0.5–2.5 (24–12)	0.5 (4.4)	6–7 (0.24–0.28)	Terminal block	Slot
MA02c	Mains, motor, and DC connection	0.5–4.0 (24–10)	0.7 (6.2)	7–9 (0.28–0.35)	Terminal block	Slot
	Customer relay	0.5–2.5 (24–12)	0.5 (4.4)	6–7 (0.24–0.28)	Terminal block	Slot
MA01a	Mains and motor	0.5–4.0 (24–10)	0.7 (6.2)	7–9 (0.28–0.35)	Terminal block	Slot
	DC connection	2.1–5.3 (14–10)	–	6–7 (0.24–0.28)	Straight receptacles	–
	Customer relay	0.5–2.5 (24–12)	0.5 (4.4)	6–7 (0.24–0.28)	Terminal block	Slot
MA02a	Mains and motor	0.5–4.0 (24–10)	0.7 (6.2)	7–9 (0.28–0.35)	Terminal block	Slot
	Brake <sup>(1)</sup> and DC connection	2.1–5.3 (14–10)	–	6–7 (0.24–0.28)	Straight receptacles	–
	Customer relay	0.5–2.5 (24–12)	0.5 (4.4)	6–7 (0.24–0.28)	Terminal block	Slot
MA03a	Mains and motor	0.5–4.0 (24–10)	0.7 (6.2)	7–9 (0.28–0.35)	Terminal block	Slot
	Brake and DC connection	2.1–5.3 (14–10)	–	6–7 (0.24–0.28)	Straight receptacles	–
	Customer relay	0.5–2.5 (24–12)	0.5 (4.4)	6–7 (0.24–0.28)	Terminal block	Slot
MA04a	Mains	0.5–16 (22–6)	1.2 (10.6)	12–13 (0.47–0.51)	Terminal block	Slot
	Motor, brake, and DC connection	0.5–16 (20–6)	1.2 (10.6)	12–15 (0.47–0.59)	Terminal block	Slot
	Customer relay	0.5–2.5 (24–12)	0.5 (4.4)	6–7 (0.24–0.28)	Terminal block	Slot
MA05a	Mains	0.5–16 (22–6)	1.2 (10.6)	12–13 (0.47–0.51)	Terminal block	Slot
	Motor, brake, and DC connection	0.5–16 (20–6)	1.2 (10.6)	12–15 (0.47–0.59)	Terminal block	Slot
	Customer relay	0.5–2.5 (24–12)	0.5 (4.4)	6–7 (0.24–0.28)	Terminal block	Slot

<sup>1</sup> For MA02a, only 3x380–480 V drives have brake function.

## 4.5 Acoustic Noise

The acoustic noise from the drive comes from 3 sources:

- DC-link coils.
- Integral fan.
- RFI filter choke.

The typical values measured at a distance of 1 m (3.3 ft) from the unit:

Table 30: Typical Measured Values

Enclosure size	Full fan speed [dBA]	Background noise [dBA]
MA01c	–	–
MA02c	50.3	31.2
MA01a	42.5	31.2
MA02a	57.6	31.2

Test results performed according to ISO 3744 for audible noise magnitude in a controlled environment. Noise tone has been quantified for engineering data record of hardware performance per ISO 1996-2 Annex D.

## 4.6 EMC Compliance Levels

The drives are designed and tested to comply with relevant EMC standards. The performance level depends on the actual drive and selected EMC compliance level.

The EMC compliance levels are tested under the following conditions:

- The drive (with options if relevant).
- Shielded control and communication cables.
- External control with digital I/O and analog control.
- Single motor connected with shielded cable for emission test and unshielded cable for immunity test.
- Load share and brake cables.
- Standard drive settings.

### N O T I C E

According to the EMC Directive, a system is defined as a combination of several types of equipment, finished products, and/or components combined, designed, and/or put together by the same person (system manufacturer) intended to be placed on the market for distribution as a single functional unit for an end user and intended to be installed and operated together to perform a specific task.

The EMC directive applies to products/systems and installations, but in case the installation is built up of CE-marked products/systems, the installation can also be considered compliant with the EMC directive. Installations are not CE-marked.

According to the EMC Directive, Danfoss as a manufacturer of products/systems is responsible for obtaining the essential requirements of the EMC directive and attaching the CE mark. For systems involving load sharing and other DC terminals, Danfoss can only ensure compliance with EMC Directive when combinations of Danfoss products are connected as described in the technical documentation.

If installed in residential environments, and not compliant to class C1, the drive may not provide adequate protection to radio reception in such locations.

- In such cases, supplementary mitigation measures might be required, for example, the use of shielding or increasing the distance between affected products.

### 4.6.1 Emission Requirements

According to the EMC product standard for AC drives, EN/IEC 61800-3, the EMC requirements depend on the intended use of the drive. Four categories are defined in the EMC product standard. The definitions of the 4 categories together with the requirements for mains supply voltage conducted emissions are given in [Table 31](#).

Table 31: Emission Requirements

Compliance Class	Intended use of the drive
C1	Drives installed in the 1 <sup>st</sup> environment (home and office) with a supply voltage less than 1000 V.
C2	Drives installed in the 1 <sup>st</sup> environment (home and office) with a supply voltage less than 1000 V, which are neither plug-in nor movable and are intended for installation and commissioning by a professional.
C3	Drives installed in the 2 <sup>nd</sup> environment (industrial) with a supply voltage lower than 1000 V.
C4	Drives installed in the 2 <sup>nd</sup> environment (industrial) with a supply voltage equal to or above 1000 V or rated current equal to or above 400 A or intended for use in complex systems.

The drives are designed to comply to 1 of the following 4 categories, defined in the EMC product standard, EN/IEC 61800-3.

#### 4.6.2 EMC Immunity Requirements

The immunity requirements for drives depend on the environment in which they are installed. The requirements for the industrial environment are higher than the requirements for the home and office environment. All Danfoss drives comply with the requirements for the industrial environment. Therefore, they also comply with the lower requirements for home and office environment with a large safety margin.

To document immunity against burst transient from electrical phenomena, the following immunity tests have been made on a system consisting of:

- A drive (with options if relevant).
- A shielded control cable.
- A control box with potentiometer, motor cable, and motor.

The tests were performed in accordance with the following basic standards:

- **EN 61000-4-2 (IEC 61000-4-2) Electrostatic discharges (ESD):** Simulation of electrostatic discharges from human beings.
- **EN 61000-4-3 (IEC 61000-4-3) Radiated immunity:** Amplitude modulated simulation of the effects of radar and radio communication equipment and mobile communications equipment.
- **EN 61000-4-4 (IEC 61000-4-4) Burst transients:** Simulation of interference caused by switching a contactor, relay, or similar devices.
- **EN 61000-4-5 (IEC 61000-4-5) Surge transients:** Simulation of transients caused by, for example, lightning that strikes near installations.
- **EN 61000-4-6 (IEC 61000-4-6) Conducted immunity:** Simulation of the effect from radio-transmission equipment joined by connection cables.

The immunity requirements should follow product standard IEC 61800-3. See [Table 32](#) for details.

Table 32: EMC Immunity

Product standard	61800-3				
	ESD	Radiated immunity	Burst	Surge	Conducted immunity
Acceptance criterion	B	A	B	B	A
Mains cable	–	–	2 kV CN	1 kV/2 Ω DM 2 kV/12 Ω CM	10 V <sub>RMS</sub>
Motor cable	–	–	2 kV CCC	–	10 V <sub>RMS</sub>
Brake cable	–	–	2 kV CCC	–	10 V <sub>RMS</sub>
Load sharing cable	–	–	2 kV CCC	–	10 V <sub>RMS</sub>
Relay cable	–	–	2 kV CCC	–	10 V <sub>RMS</sub>

Product standard	61800-3				
Test	ESD	Radiated immunity	Burst	Surge	Conducted immunity
Control cable	–	–	Length >2 m (6.6 ft) 1 kV CCC	Unshielded: 1 kV/42 Ω CM	10 V <sub>RMS</sub>
Standard/fieldbus cable	–	–	Length >2 m (6.6 ft) 1 kV CCC	Unshielded: 1 kV/42 Ω CM	10 V <sub>RMS</sub>
Control panel cable	–	–	Length >2 m (6.6 ft) 1 kV CCC	–	10 V <sub>RMS</sub>
Enclosure	4 kV CD 8 kV AD	10 V/m	–	–	–
<b>Definitions</b>					
CD: Contact discharge AD: Air discharge		DM: Differential mode CM: Common mode		CN: Direct injection through coupling network CCC: Injection through capacitive coupling clamp	

#### 4.7 EMC Compatibility and Motor Cable Length

Based on different EMC filter types, the drive includes 2 variants:

- Drive with built-in EMC filter.
- Drive with non built-in EMC filter.

Table 33: EMC Compatibility Motor Cable Length

Drive with built-in EMC filter	Maximum motor cable length (shielded), @4kHz	
	C1 (Conducted)	C2 (Conducted)
1x200–240 V	5 m (16.4 ft)	–
3x400–480 V	–	15 m (49.2 ft)

Table 34: Maximum Motor Cable Length

Maximum motor cable length (shielded)	Maximum motor cable length (unshielded)
50 m (164 ft)	75 m (246 ft)

- Drive with built-in EMC filter fulfills radiated emission C2 limits.
- Drive with non built-in EMC filter fulfills conducted/radiated emission C4 requirements.
- The drive is designed to operate with optimum performance within the maximum motor cable lengths defined in [Table 34](#).

#### 4.8 dU/dt Conditions

When a transistor in the drive bridge switches, the voltage across the motor increases by a dU/dt ratio depending on the following factors:

- The motor cable type.
- The cross-section of the motor cable.
- The length of the motor cable.
- Whether the motor cable is shielded or not.
- Inductance.

The natural induction causes an overshoot  $U_{PEAK}$  in the motor voltage before it stabilizes itself at a level depending on the voltage in the DC link. The rise time and the peak voltage  $U_{PEAK}$  affect the service life of the motor.

If the peak voltage is too high, motors without phase coil insulation are affected. The longer the motor cable, the higher the rise time and peak voltage.

Switching of the IGBTs causes peak voltage on the motor terminals. The iC2-Micro Frequency Converters comply with IEC 60034-25 regarding motors designed to be controlled by drives. The iC2-Micro Frequency Converters also comply with IEC 60034-17 regarding Norm motors controlled by drives.

The following dU/dt data are measured at the motor terminal side with IEC 50% torque:

**Table 35: dU/dt Data for iC2-Micro Frequency Converters**

Enclosure size	Power [kW (hp)]	Cable length [m (ft)]	Mains voltage [V]	Rise time [ $\mu\text{sec}$ ]	$U_{PEAK}$ [kV]	dU/dt [kV/ $\mu\text{sec}$ ]
MA01c	0.75 (1.0)	5 (16.4)	1x240	0.067	0.438	5.21
MA01c	0.75 (1.0)	50 (164)	1x240	0.286	0.618	1.73
MA02c	1.5 (2.0)	5 (16.4)	1x240	0.132	0.464	2.82
MA02c	1.5 (2.0)	50 (164)	1x240	0.31	0.622	1.62
MA01a	1.5 (2.0)	5 (16.4)	3x400	0.132	0.732	4.46
MA01a	1.5 (2.0)	50 (164)	3x400	0.389	1.056	2.18
MA01a	1.5 (2.0)	5 (16.4)	3x480	0.143	0.848	4.76
MA01a	1.5 (2.0)	50 (164)	3x480	0.417	1.232	2.36
MA02a	2.2 (3.0)	5 (16.4)	1x240	0.078	0.562	5.71
MA02a	2.2 (3.0)	50 (164)	1x240	0.214	0.614	2.29
MA02a	4.0 (5.5)	5 (16.4)	3x400	0.136	0.752	4.47
MA02a	4.0 (5.5)	50 (164)	3x400	0.254	1.048	3.30
MA02a	4.0 (5.5)	5 (16.4)	3x480	0.149	0.896	4.85
MA02a	4.0 (5.5)	50 (164)	3x480	0.305	1.232	3.23

## 4.9 Derating

Consider derating if the drive is challenged under some special conditions. Derating of the drive includes:

- Manual derating.
- Automatic derating.

### 4.9.1 Manual Derating

Manual derating must be considered for:

- Air pressure – for installation at altitudes above 1000 m (3281 ft).
- Motor speed – at continuous operation at low RPM in constant torque applications.
- Ambient temperature – above 40 °C (104 °F), for details, see the following illustrations.






Illustration 13: Derating of Output Current Versus Switching Frequency (MA01c 1x200–240 V AC)




Illustration 14: Derating of Output Current Versus Switching Frequency (MA02c 1x200–240 V AC)




Illustration 15: Derating of Output Current Versus Switching Frequency (MA01a 3x380–480 V AC)




Illustration 16: Derating of Output Current Versus Switching Frequency (MA02a 1x200–240 V AC)




Illustration 17: Derating of Output Current Versus Switching Frequency (MA02a 3x380–480 V AC)

#### 4.9.2 Automatic Derating

To ensure the performance at critical stages, the drive checks for the following critical levels constantly and adjusts the switching frequency automatically.

- Critical high temperature on the heat sink.
- High motor load.
- Low motor speed.
- Protection signals (overvoltage/undervoltage, overcurrent, ground fault, and short circuit) are triggered.

## 5 Exterior Dimensions

### 5.1 IP20/Open Type Enclosure Sizes and Dimensions




Illustration 18: IP20/Open Type Enclosure Sizes and Dimensions


Table 36: IP20/Open Type Enclosure Sizes and Dimensions

Enclosure	Power [kW (hp)]		Height [mm (in)]			Width [mm (in)]		Depth [mm (in)] <sup>(1)</sup>	Mounting holes [mm (in)]
	1x200–240 V	3x380–480 V	A	A1 <sup>(2)</sup>	a	B	b		
MA01c	0.37–0.75 (0.5–1.0)	–	150 (5.9)	216 (8.5)	140.4 (5.5)	70 (2.8)	55 (2.2)	143 (5.6)	4.5 (0.18)
MA02c	1.5 (2.0)	–	176 (6.9)	232.2 (9.1)	150.5 (5.9)	75 (3.0)	59 (2.3)	157 (6.2)	4.5 (0.18)
MA01a	–	0.37–1.5 (0.5– 2.0)	150 (5.9)	202.5 (8.0)	140.4 (5.5)	70 (2.8)	55 (2.2)	158 (6.2)	4.5 (0.18)
MA02a	2.2 (3.0)	2.2–4.0 (3.0– 5.5)	186 (7.3)	240 (9.4)	176.4 (6.9)	75 (3.0)	59 (2.3)	175 (6.9)	4.5 (0.18)

<sup>1</sup> The potentiometer on the local control panel extends 6.5 mm (0.26 in) from the drive.

<sup>2</sup> Including decoupling plate.

## 5.2 IP21/UL Type 1 Enclosure Sizes and Dimensions




e30bv104.10

Illustration 19: IP21/UL Type 1 Enclosure Sizes and Dimensions

Table 37: IP21/UL Type 1 Enclosure Sizes and Dimensions

Enclosure	Power [kW (hp)]		Height [mm (in)]	Top cover width [mm (in)]	Depth [mm (in)]
	1x200–240 V	3x380–480 V			
MA01c	0.37–0.75 (0.5–1.0)	–	242.2 (9.5)	81.5 (3.2)	153.5 (6.0)
MA02c	1.5 (2.0)	–	257 (10.1)	92.4 (3.6)	165 (6.5)
MA01a	–	0.37–1.5 (0.5–2.0)	220.2 (8.7)	73.2 (2.9)	166.5 (6.6)
MA02a	2.2 (3.0)	2.2–4.0 (3.0–5.5)	255 (10.0)	78 (3.0)	184 (7.2)

## 5.3 NEMA 1 Enclosure Sizes and Dimensions



e30bv105.10

Illustration 20: NEMA 1 Enclosure Sizes and Dimensions

Table 38: NEMA 1 Enclosure Sizes and Dimensions

Enclosure	Power [kW (hp)]		Height [mm (in)]	Width [mm (in)]	Depth [mm (in)] <sup>(1)</sup>
	1x200–240 V	3x380–480 V			
MA01c	0.37–0.75 (0.5–1.0)	–	206.2 (8.1)	70 (2.8)	143 (5.6)
MA02c	1.5 (2.0)	–	221 (8.7)	75 (3.0)	157 (6.2)
MA01a	–	0.37–1.5 (0.5–2.0)	195 (7.7)	70 (2.8)	158 (6.2)
MA02a	2.2 (3.0)	2.2–4.0 (3.0–5.5)	231 (9.1)	75 (3.0)	175 (6.9)

<sup>1</sup> The potentiometer on the local control panel extends 6.5 mm (0.26 in) from the drive.

## 6 Mechanical Installation Considerations

### 6.1 Contents of the Shipment

The shipment contains:

- The drive.
- The terminal cover.
- The operating guide, which provides information about installation, commissioning, and maintenance of the drive.

### 6.2 Product Labels

The drive and its package have labels that contain information required for legal or regulatory reasons, a unique identification of each component, and other relevant information.

#### 6.2.1 Product Labels on Drives

The product label on the drive contains information to identify the product, and legal and regulatory information. See [Table 39](#) for the label location of the drive.

Table 39: Location of the Label

Enclosure size	Label location
MA01c	On the side of drive.
MA02c	
MA01a	On the top of drive.
MA02a	




Illustration 21: Example of a Product Label

Design Guide

<p>1 Product name</p> <p>2 Model code: M/C includes 27 characters of the model code.</p> <p>3 P/N and S/N</p> <ul style="list-style-type: none"> <li>• P/N is the code number of the actual product.</li> <li>• S/N contains the serial number.</li> </ul> <p>4 Power rating:</p> <ul style="list-style-type: none"> <li>• The 1<sup>st</sup> line lists the typical motor power rating at the referenced voltages.</li> <li>• The 2<sup>nd</sup> line lists input ratings (voltage range, frequency, and input current at given input voltages).</li> <li>• The 3<sup>rd</sup> line lists output ratings (voltage range, frequency, and rated output currents at the given input voltage).</li> </ul> <p>5 Enclosure: States the protection rating of the drive both as an Ingress Protection rating and an UL compliant rating.</p>	<p>6 Ambient temperature: States the ambient temperature range without derating needed.</p> <p>7 Efficiency class: Efficiency class according to ErP directive. The value given for 90% frequency/100% current working point.</p> <p>8 Company name, address, and website.</p> <p>9 Warnings and compliance information.</p> <p>10 2D code: The 2D code contains information on the drive, and can be read out with MyDrive® tools. The code contains:</p> <ul style="list-style-type: none"> <li>• P/N: Code number.</li> <li>• S/N: Serial number.</li> </ul>
---	---

6.2.2 Package Labels

The package label is placed on the drive packaging and contains information about the drive.




Illustration 22: Example of a Package Label



1	Product name	6	Company name, address.
2	Model code: M/C includes 27 characters of the model code.	7	UKAC address.
3	Power rating: <ul style="list-style-type: none"> <li>The 1<sup>st</sup> line lists the typical motor power rating at the referenced voltages.</li> <li>The 2<sup>nd</sup> line lists input ratings (voltage range, frequency, and input current at given input voltages).</li> <li>The 3<sup>rd</sup> line lists output ratings (voltage range, frequency, and rated output currents at the given input voltage).</li> </ul>	8	Company website.
4	Enclosure: States the protection rating of the drive both as an Ingress Protection rating and an UL compliant rating.	9	Barcode for European Article Number (EAN).
5	2D code with information about the order.	10	Approval marking required on packaging (more approval markings on the drive).


### 6.3 Recommended Disposal

When the drive reaches the end of its service life, its primary components can be recycled.

Before the materials can be removed, the drive must be disassembled. Product parts and materials can be dismantled and separated. Generally, all metals, such as steel, aluminum, copper and its alloys, and precious metals can be recycled as material. Plastics, rubber, and cardboard can be used in energy recovery. Printed circuit boards and large electrolytic capacitors with a diameter of under 25 mm (1 in) need further treatment according to IEC 62635 guidelines. To ease recycling, plastic parts are marked with an appropriate identification code.

Contact the local Danfoss office for further information on environmental aspects and recycling instructions for professional recyclers. End-of-life treatment must follow international and local regulations.

All drives are designed and manufactured in accordance with Danfoss company guidelines on prohibited and restricted substances. A list of these substances is available at [www.danfoss.com](http://www.danfoss.com).

	<p>This symbol on the product indicates that it must not be disposed of as household waste. Do not dispose of equipment containing electrical components together with domestic waste.</p> <p>It must be handed over to the applicable take-back scheme for the recycling of electrical and electronic equipment.</p> <ul style="list-style-type: none"> <li>Dispose of the product through channels provided for this purpose.</li> <li>Comply with all local and currently applicable laws and regulations.</li> </ul>
---	--

### 6.4 Storage until Installation

#### 6.4.1 Reforming the Capacitors

For drives that are in storage and do not have voltage applied, maintenance of the capacitors in the drive may be required.

Reforming is required if the drive has been stored without applying voltage for more than 3 years. Reforming is possible only with drives with DC terminals. See [Table 40](#) for DC-link capacitor maintenance and reforming.

When reforming the capacitors:

- The reforming voltage must be 1.35–1.45 times the rated mains voltage. If the DC-link voltage stays at a low level and does not reach approximately  $1.41 \times U_{\text{mains}}$ , contact the local service agent.
- The supply current draw must not exceed 500 mA.

When the drive is operational, DC-link capacitors that have not been reformed can be damaged.

## Design Guide

Table 40: Drive Storage Duration and Reforming Recommendations

Storage duration	Reforming guideline
Under 2 years	No reforming required. Connect to mains voltage.
2–3 years	Connect to mains voltage and wait a minimum of 30 min before loading the drive.
Over 3 years	Using a DC supply connected directly to the DC-link terminals of the drive, ramp up the voltage 0–100% of DC-bus voltage in increments of 25%, 50%, 75%, and 100% rated voltage under no load for 30 min at each increment. See <a href="#">Illustration 23</a> .




Illustration 23: Reforming Procedure for DC Capacitors

A	Reforming voltage (percentage of rated voltage)
B	Hours

Table 41: DC Bus Voltage Ramp-up Value

AC input voltage	Voltage across the DC link
3x380–480 V AC	650 V DC
1x200–240 V AC	320 V DC

## 6.4.2 Safe Transportation and Storage

Follow all information on transportation, storage, and proper handling given in the product-specific documentation. That includes:

- If the drive is stored before installing it, make sure that the ambient conditions agree to the specifications given in [4.2.7.1 Ambient Conditions during Storage](#).
- If the package is kept in storage for more than 4 months, keep it in controlled conditions:
  - Make sure that the temperature variation is small.
  - Make sure that the humidity is less than 50%.
- Keep the drive in its package until installation. After unpacking, protect the drive from dust, debris, and moisture.

## 6.5 Prerequisites for Installation

To secure the best conditions and operation of the drive in its application, it is recommended to check the following points before selecting a drive:

## Design Guide

- Check the operating environment against ambient conditions. See [4.2.7.3 Ambient Conditions during Operation](#).
- Consider the placement of the drive, and handling during installation. See [5.1 IP20/Open Type Enclosure Sizes and Dimensions](#) for the weights and mechanical dimensions of the drives.
- Consider needs for access to the drive during operation. See [6.7 Mechanical Installation](#).
- Consider needs for maintenance access. See [6.7.8 Recommended Space for Service Access](#).

### 6.5.1 Operating Environment

Make sure that the drive is installed within the specified installation conditions to ensure proper operation and expected lifetime of the product.

Table 42: Operating Environment Specifications

Environment	Specifications
Temperature	The drive must be installed in a location where the operational temperature range is compliant to the specifications of the drive. Consider both temperature at operation and temperature at storage (unpowered drive). If the nominal temperature rating is exceeded, derating must be applied. For more information about derating, see <a href="#">4.2.7 Ambient Conditions</a> and <a href="#">4.9 Derating</a> .
Altitude	Ensure that the drive is installed at the allowed altitude for proper cooling and compliance with isolation spacing. At altitudes above 1000 m (3300 ft), derating of drive performance applies. Derating is to be applied to the maximum output current or maximum operational temperature. Ensure that the drive is rated for the actual application. Maximum altitude depends on power grid configurations and grid voltage. Limitations are stated in <a href="#">4.2 General Technical Data</a> . For more information, see <a href="#">4.2.7 Ambient Conditions</a> and <a href="#">4.9 Derating</a> .
Vibration and shock	Ensure that the drive is installed in a location, where it is not exposed to vibration and shock levels exceeding its specifications. If exposed to higher levels of vibration and shock, using dampers for installation is recommended. Special requirements are fulfilled when the drive is ordered with marine approval. For more information, see <a href="#">4.2.7 Ambient Conditions</a> .
Humidity	The drive must be installed in a location, where the humidity level is compliant to the specifications of the drive. If the installation area does not fulfill the required conditions, alternative measures can be taken by selecting other protective cabinets for installation, built-in heating elements, or a dehumidifier. For more information, see <a href="#">4.2.7 Ambient Conditions</a> .
Dust, fiber, and airborne particles	IP20/Open Type and IP21/UL Type 1 (IP21/Type 1 conversion kit as option) enclosures are not protected against dust, fibers, and other airborne particles, and should be installed in locations where these are not present, or in a dedicated enclosure. Make sure that airborne particles are not clogging the heat sink and fan, because clogging limits the cooling of the drive. The drive detects clogging, and reduces performance or stops operation. Do not install the drive in a location where it is exposed to conductive particles. For more information, see <a href="#">4.2.7 Ambient Conditions</a> . For more information on heat sink and fan maintenance, see <a href="#">6.6.4 Heat Sink and Fan Maintenance and Service</a> .
Gases	When installing the drive, exposure to gases must be observed. The drive is not intended to be installed in a location where it is exposed to explosive gases. If exposed to corrosive gases, relevant precautions must be taken. These precautions include selecting a drive with a higher protection degree, adding protective coating as an optional selection to the drive, or by installing the drive in a protective cabinet. For more information, see <a href="#">4.2.7 Ambient Conditions</a> .

### 6.6 Maintenance Considerations

During the lifetime of the drive, regular maintenance or service actions may be needed, and access to relevant parts of the drive must be ensured.

## ⚠ CAUTION ⚠

### HOT SURFACES

Some drives contain metal components that are still hot even after the drive has been powered off. Failure to observe the high temperature symbol (yellow triangle) on the drive can result in serious burns.

- Be aware that internal components may be extremely hot even after the drive has been powered off.
- Do not touch exterior areas that are marked by the high temperature symbol (yellow triangle). These areas are hot while the drive is in use and immediately after being powered off.

### 6.6.1 Regular Maintenance

Typical cases for maintenance include:

- Checking the I/O signal on the drive.
- Regularly checking the power connections and grounding.
- Reading data or parameterizing by connecting a PC to the drive.

### 6.6.2 Maintenance Schedule

The maintenance schedule of the drive depends on the use and operating environment of the drive.

Table 43: Maintenance Schedule

Maintenance interval	Maintenance task
6–24 months (depending on environment)	<ul style="list-style-type: none"> <li>• Check the tightening torques of the power terminals.</li> <li>• Make sure that the cooling fan operates correctly.</li> <li>• Check for corrosion on terminals and other surfaces.</li> <li>• Clean the heat sink and the cooling channel.</li> </ul>

A maintenance plan for each drive supports the optimum performance and lifetime of the drive. Danfoss offers several service products to, for example, the DrivePro® preventive maintenance service to provide help in determining the correct setup. For more information on DrivePro® services, see [www.danfoss.com](http://www.danfoss.com). For more information, contact Danfoss.

### 6.6.3 Service Access

To ensure planned and extended drive lifetime, Danfoss recommends regular inspection and service actions for the drive, motor, system, and cabinet/enclosure. To prevent breakdown, danger, and damage, examine, for example, the tightness of terminal connections and dust build-up in the drive at regular intervals depending on the operating conditions.

If the Danfoss drive is operated in environments near the limit or beyond design boundaries, maintenance of the drive is required. Replace worn or damaged parts with original spare parts. For service and support, contact the local Danfoss supplier. DrivePro® services extend the lifetime and increase the performance of iC2-Micro Frequency Converters with commissioning and timely scheduled maintenance services. DrivePro® services are tailored to applications and operating conditions.

When planning the installation, proper access for service and maintenance needs must be considered. In general, it is recommended to ensure:

- Access to power cabling and connectors.
- Access to control wiring.
- Access to clean the cooling system (cooling channel and fan filters).
- Access to the port to connect the drive to a PC.

### 6.6.4 Heat Sink and Fan Maintenance and Service

The heat sink fins pick up dust from the cooling air. If the heat sink is not clean, the drive runs into overtemperature warnings and faults. When necessary, clean the heat sink.

The lifespan of the cooling fan in the drive depends on the fan running time, ambient temperature, and dust concentration. Selecting the fan control mode in *parameter P6.5.1 Fan Control Mode* and controlling the fan automatically increases the lifespan of the fan. Fan fault can be predicted by the increase of fan bearing noise. If the drive is running in a critical part of a process, it is recommended to replace the fan once these symptoms occur.

Design Guide

Fans can be removed from the drive for cleaning. Replacement of fans is also available from Danfoss.

- For the ordering numbers of replaceable cooling fans, refer to [8.2 Ordering Accessories and Spare Parts](#).
- For detailed steps on replacing fans, refer to the Fan Replacement Installation Guides for iC2-Micro Frequency Converters.

### 6.7 Mechanical Installation

The drive is mounted primarily on a wall or in an enclosed cabinet. For more details, see [6.7.2 Mounting Locations](#).

#### 6.7.1 Mounting Considerations

When selecting and planning the installation site, observe the following considerations:

- The mounting surface supports the weight of the drive.
- The mounting surface must be non-flammable.
- The drive is installed vertically, but in special cases it can also be mounted in alternate directions. Installing the drive in alternate directions affects the performance of the drive. For more information, see [6.7.3 Mounting Directions](#).
- Proper inlet and outlet spacing secures free airflow over the heat sink to enable proper cooling.
- The drives can be mounted side-by-side to save space in cabinets, or when mounted on walls in control rooms.
- There must be enough space in front of the drive for operating the control panel.
- Ensure proper space for the installation and placement of cables used for connecting the drive.

**! W A R N I N G !**

**SHOCK HAZARD**  
 Touching an uncovered motor, mains, or DC connection plug or terminal can result in death or serious injury.

- All plugs and terminal protection covers for the motor, mains, and DC connections must be installed within the IP20 enclosure to provide an IP20 protection rating. If the plugs and terminal covers are not installed, the protection rating is considered IP00.

- To remove covers or open doors for service access, enough space must be left in front of the drive.

#### 6.7.2 Mounting Locations

The drives are designed for installation in weather-protected environments. For more information, see [4.2.7 Ambient Conditions](#).

When mounting the drive on the wall or in a cabinet, the mounting surface must be solid, flat, and non-flammable.

#### 6.7.3 Mounting Directions

The drive can be mounted vertically or horizontally, depending on the enclosure size. See [Table 44](#) for more information on the effects of mounting direction on drive performance.




Illustration 24: Mounting Directions for Drives

Table 44: Allowed Mounting Directions for IP20/Open Type Rated Drives and Effects of Mounting Direction on Performance

Installation direction	Allowed enclosure size	Effects on performance
A: Vertical installation	MA01c/MA02c/MA01a/ MA02a	None
B: Horizontal installation (Left side downwards)	MA02c/MA01a/MA02a	<ul style="list-style-type: none"> <li>Limited robustness to vibration and shock.</li> <li>Side-by-side mounting not possible.</li> </ul>
C: Horizontal installation (Right side downwards)	–	Not allowed for all enclosure sizes.

## N O T I C E

The IP21/UL Type 1 rated drives are protected against dripping water when installed vertically.

### 6.7.4 Recommended Screws and Bolts

Check the recommended sizes of screws and bolts for mounting the drive in table [Table 45](#).

Table 45: Recommended Screws and Bolts

Protection rating	Enclosure size	Maximum weight [kg (lb)] <sup>(1)</sup>	Recommended screw/bolt	Maximum torque [Nm (in-lb)]
IP20/Open Type	MA01c	1 (2.4)	M4	1.5 (13.3)
	MA02c	1.3 (2.9)	M4	1.5 (13.3)
	MA01a	1.1 (2.4)	M4	1.5 (13.3)
	MA02a	1.6 (3.5)	M4	1.5 (13.3)


<sup>1</sup> Not including decoupling plate.

### 6.7.5 Drilling Patterns

When preparing mounting holes for the installation, use the drilling patterns. The drilling pattern equals the mounting plate of the drive.

The required space for cooling, EMC plates, and other extensions is not included in the drilling patterns.

For total space needed, see the drawings in chapter *Exterior and Terminal Dimensions*.



e30bv096.10

Illustration 25: Drilling Patterns

Table 46: Drilling Pattern Dimensions for Wall-mounted Drives

Enclosure size	Drilling pattern	A1 [mm (in)]	A2 [mm (in)]	A3 [mm (in)]	B1 [mm (in)]	B2 [mm (in)]	B3 [mm (in)]	B4 [mm (in)]	B5 [mm (in)]
MA01c	1	5.5 (0.22)	140.4 (5.53)	4.1 (0.16)	7.5 (0.30)	55 (2.17)	7.5 (0.30)	-	-
MA02c	1	5.5 (0.22)	150.5 (5.93)	4 (0.16)	6.75 (0.27)	59 (2.32)	9.25 (0.36)	-	-
MA01a	1	4.8 (0.19)	140.4 (5.53)	4.8 (0.19)	7.5 (0.30)	55 (2.17)	7.5 (0.30)	-	-
MA02a	1	4.8 (0.19)	176.4 (6.94)	4.8 (0.19)	8 (0.31)	59 (2.32)	8 (0.31)	-	-
MA03a	1	-	-	-	-	-	-	-	-
MA04a	2	-	-	-	-	-	-	-	-
MA05a	2	-	-	-	-	-	-	-	-

### 6.7.6 Placement of the Drive in the Installation

Before mounting the drive, prepare the mounting location with appropriate fasteners so the drive can be positioned safely. Make sure that there is enough space to handle the drive safely during installation.

Lower screws or bolts can be mounted before installation. Position the drive on the lower bolts, and mount the upper screws or bolts. The broken torque for screw holes on the mounting surface must be no less than 1.5 Nm (13.3 in-lb).

### 6.7.7 Cooling

For proper cooling for the drives, ensure that there is sufficient clearance above and below the drive. See [Table 47](#) for details on the required cooling clearances.

For all installations, the temperature of the installation site must be kept within the specified operating temperature range by ventilation or cooling. The quality of the cooling air must comply with the environmental conditions as defined in the technical specifications (dust, airborne particles, chemical substances).




Illustration 26: Minimum Clearance for Cooling

Table 47: Minimum Cooling Clearances for IP20/Open Type Drives

Enclosure size	A [mm (in)]	B [mm (in)]	Cooling type
MA01c	100 (3.9)	<ul style="list-style-type: none"> <li>0 (0) at 40 °C (104 °F).</li> <li>10 (0.39) and above at 50 °C (122 °F).</li> </ul>	Natural air cooling
MA02c	100 (3.9)	0 (0)	Forced air cooling
MA01a	100 (3.9)	0 (0)	Forced air cooling
MA02a	100 (3.9)	0 (0)	Forced air cooling
MA03a	–	–	Forced air cooling
MA04a	–	–	Forced air cooling
MA05a	–	–	Forced air cooling

### 6.7.8 Recommended Space for Service Access

To ensure access to the drive for service and maintenance, it is recommended to reserve sufficient space around the drive. The general recommendations include:

- Enough space in the front of the drive for removing covers, and access to the control board.
- Enough space below the drive to access the cooling channel entry for cleaning or replace fans.



Design Guide




Illustration 27: Recommended Clearance for Service Access

Table 48: Recommended Clearances for Service Access

Enclosure size	Recommended space for access		
	Above (A) [mm (in)]	Below (B) [mm (in)]	Front (C) [mm (in)]
MA01c	100 (3.9) <sup>(1)</sup>	200 (7.9) <sup>(1)</sup>	100 (3.9)
MA02c	100 (3.9) <sup>(1)</sup>	200 (7.9) <sup>(1)</sup>	100 (3.9)
MA01a	100 (3.9) <sup>(1)</sup>	200 (7.9) <sup>(1)</sup>	100 (3.9)
MA02a	100 (3.9) <sup>(1)</sup>	200 (7.9) <sup>(1)</sup>	100 (3.9)

<sup>1</sup> Sufficient space to the cooling duct, exceeding need for cooling. Alternatively, unplug the drive, and remove from the installation for service.

## 7 Electrical Installation Considerations

### 7.1 Electrical Installation Precautions

#### ⚠ W A R N I N G ⚠

##### INDUCED VOLTAGE

Induced voltage from output motor cables that run together can charge equipment capacitors, even with the equipment turned off and locked out/tagged out. Failure to run output motor cables separately, or to use shielded cables, could result in death or serious injury.

- Run output motor cables separately or use shielded cables.
- Simultaneously lock out/tag out all the drives.

#### ⚠ C A U T I O N ⚠

##### THERMISTOR INSULATION

Risk of personal injury or equipment damage.

- To meet PELV insulation requirements, use only thermistors with reinforced or double insulation.

#### N O T I C E

##### EXCESSIVE HEAT AND PROPERTY DAMAGE

Overcurrent can generate excessive heat within the drive. Failure to provide overcurrent protection can result in risk of fire and property damage.

- Additional protective devices such as short circuit protection or motor thermal protection between drive and motor is required for applications with multiple motors.
- Input fusing is required to provide short circuit and overcurrent protection. If fuses are not factory-supplied, the installer must provide them. Refer to the product-specific documentation for fuse specifications.

#### N O T I C E

##### PROPERTY DAMAGE

Protection against motor overload is not included in the default setting. The ETR function provides class 20 motor overload protection. Failure to set the ETR function means that motor overload protection is not provided and property damage can occur if the motor overheats.

- Enable the ETR function. Refer to the application guide for more information.

### 7.2 Wiring Diagram




Illustration 28: Wiring Diagram

<p>1 Single DC choke in MA05a.</p>	<p>4 Select the PNP or NPN mode via <i>parameter P9.4.1.1 Digital I/O mode</i> (PNP=Source, NPN=Sink).</p>
<p>2 Built-in brake chopper is only applicable to drives in the power range of 3x380–480 V 2.2 kW (3.0 hp) and above.</p>	<p>5 Use switch S640 (bus terminal) to enable termination on the RS485 port (terminals 68 and 69).</p>
<p>3 No BR terminals for 1x200–240 V drives and 3x380–480 V 0.37–1.5 kW (0.5–2.0 hp) drives.</p>	

## 7.3 Grid Type and Protection

### 7.3.1 Grid Types

The drive can operate in different network types with rated network supply voltage:

- TN-S
- TN-C
- TN-C-S
- TT
- IT (only supported by C4 version)
- Delta-grounded grids (only supported by C4 version)

For detailed information about the parameters related to grid types, refer to the application guide.

### 7.3.2 Currents on Protective Earth and Potential Equalization/Leakage Currents

A properly dimensioned protective earth (PE) setup is essential for the safety of the drive system protecting against electric shock. The PE connections of the drive installation ensure that the drive system remains safe preventing that single fault currents generate hazardous voltages on accessible conductive parts, such as conductive enclosure parts.

The drive must be installed according to the requirement for PE connection and supplementary protective bonding as specified in EN 60364-5-54:2011 cl. 543 and 544.

For the automatic disconnection in case of a fault at the motor side, it must be ensured that the impedance of the PE connection between drive and motor is sufficiently low to ensure compliance to IEC/EN 60364-4-41:2017 cl. 411 or 415.

The impedance must be verified by initial and periodic test according to IEC/EN 60364-4-41:2017.

Local requirements may apply.

Designing the system according to IEC/EN 61800-5-1:2017 ensures the suitability for the connection of PE and protective bonding of accessible conductive parts according to EN 60364-5-54:2011.

When the drive is used as a component inside specific applications, special requirements for the proper connection to the PE, for example those specified in EN 60204-1:2018 and IEC/EN 61439-1:2021, can apply.

In low-voltage networks currents can arise on the protective conductor (PE) and equipotential bonding conductors as well as structures connected to earth potential as an undesirable effect. Since there are different causes for these currents, it is beneficial to know them in order to avoid them.

A drive setup consists of a mains supply, the drive inverter, its cabling, and a motor with the load side. Due to the behavior of the active and passive components and the electrical setup of the installation, several phenomena may appear resulting in currents on the PE conductor.

- Inductive coupling due to asymmetry in mains cables and/or busbars can cause PE current at the mains frequency and its harmonics
- Inductive coupling due to asymmetry in motor cables can cause PE current at the motor fundamental frequency
- As part of the EMI filter DC-link capacitive decoupling to PE can cause PE currents at 150 Hz/180 Hz
- Voltage distortion/harmonic content on the mains can typically cause PE currents in the 150 Hz–2000 Hz range.
- Common mode currents due to motor cable capacity from motor phases to PE typically result in PE currents at the switching frequency and harmonics typically above 2 kHz.

As mentioned above the PE current is made up of several contributions and depends on various system configurations:

- RFI filtering
- Motor cable length
- Motor cable shielding
- Drive power

### 7.3.3 PE Current Measurement

As the currents have different frequencies, it is not useful to measure an effective value only. Instead, it is required to perform a frequency/FFT measurement. This can be done by using an appropriate oscilloscope or specific measuring equipment. Just analyzing the effective value with a current clamp at the PE connection of the drive leads to insufficient and misleading results.

Design Guide




Illustration 29: Example of FFT Measurement

<p>1 <math>f &lt; 50</math> Hz: Typical for inductive coupling in unsymmetrical cables and conductor.</p> <p>2 <math>f = 150\text{--}2500</math> Hz: Typical harmonic components in grid. <math>f = 150</math> Hz: Common-mode current typical due to rectifier with DC intermediate circuit.</p>	<p>3 <math>f &gt; 2</math> kHz: Typical common-mode current due to capacitive coupling between cable/motor and ground.</p>
---	--

**⚠ WARNING ⚠**

**ELECTRICAL SHOCK HAZARD - LEAKAGE CURRENT HAZARD**

Leakage currents exceed 3.5 mA. Failure to connect the drive properly to protective earth (PE) can result in death or serious injury.

- Ensure reinforced protective earthing conductor according to IEC 60364-5-54 cl. 543.7 or according to local safety regulations for high touch current equipment. The reinforced protective earthing of the drive can be done with:
  - a PE conductor with a cross-section of at least 10 mm<sup>2</sup> (8 AWG) Cu or 16 mm<sup>2</sup> (6 AWG) Al.
  - an extra PE conductor of the same cross-sectional area as the original PE conductor as specified by IEC 60364-5-54 with a minimum cross-sectional area of 2.5 mm<sup>2</sup> (14 AWG) (mechanically protected) or 4 mm<sup>2</sup> (12 AWG) (not mechanically protected).
  - a PE conductor completely enclosed with an enclosure or otherwise protected throughout its length against mechanical damage.
  - a PE conductor part of a multi-conductor power cable with a minimum PE conductor cross-section of 2.5 mm<sup>2</sup> (14 AWG) (permanently connected or pluggable by an industrial connector. The multi-conductor power cable shall be installed with an appropriate strain relief).
- NOTE: In IEC/EN 60364-5-54 cl. 543.7 and some application standards (for example IEC/EN 60204-1), the limit for requiring reinforced protective earthing conductor is 10 mA leakage current.

**⚠ W A R N I N G ⚠****LEAKAGE CURRENT HAZARD**

Leakage currents can exceed 5%. Failure to ground the drive properly can result in death or serious injury.

- Ensure that the minimum size of the ground conductor complies with the local safety regulations for high touch current equipment.

Protective earth (PE) and equipotential bonding are usually connected to one another so that equipotential bonding currents are also distributed over the entire PE system.

PE currents and their impact on the system can be avoided or reduced by using short motor cables, symmetrical cables (especially for current ratings > 50 A), or shielded cables with low capacitance between conductors and PE.

### 7.3.4 Residual Current Device (RCD) Protection

Residual current devices (RCD) may be used to provide additional protection against electrical shock and fire hazards due to fault currents because of insulation faults or high leakage currents. Additional consideration is needed when RCDs are used in front of the drive. RCDs must always be installed according to local regulations.

**⚠ W A R N I N G ⚠****ELECTRICAL SHOCK AND FIRE HAZARD – RCD COMPLIANCE**

The drive can cause a DC fault current in the PE conductor. Failure to use a Type B residual current-operated protective device (RCD) can lead to the RCD not providing the intended protection and therefore can result in death, fire, or other serious hazard.

- When an RCD is used for protection against electrical shock or against fire, only a Type B device is allowed on the supply side.

RCD/RCM devices cannot differentiate between operating and fault currents, and their function can be impaired. RCDs can be triggered even though there is no insulation fault in the installation.

Current measured by a RCD/RCM on mains phases might differ from the measured PE current. This is due to magnetic coupled PE current not being present on mains phases.

The frequency characteristic of Type B RCDs is not completely standardized, and vendor-specific differences are to be expected in the upper frequency range. Consult the documentation of the RCD in question for more information.

### 7.3.5 Isolation Monitoring Devices

When operating on an IT grid, isolation monitoring devices can be used for observing the integrity of the isolation in the motor, motor cabling and the drive.

The typical applications are:

- Preventive detection of degradation of the isolation system.
- Earth fault detection on IT mains.

The isolation monitor is a key component in an IT mains installation. It allows preventive maintenance and warn whenever a ground fault occurs. Several types of isolation monitors exist with different operation principles, for example: DC-voltage injection, DC voltage with alternating polarity injection and current injection. Not all isolation monitors are compatible with drive systems due to capacitances to ground and drives producing common-mode voltages. It is essential that the isolation monitor used in a drive system installation is compatible with drives.

## 7.4 EMC-compliant Installation Guidelines

This chapter gives a general introduction to proper EMC-compliant installation practice.

To obtain an EMC-compliant installation, follow the instructions provided in the operating guide supplied with the drive.

See [Illustration 30](#) for an example on how to ensure a proper EMC-compliant installation.

e-30by100.10




Illustration 30: Example of Proper EMC Installation

1	Programmable logic controller (PLC)	7	Output contactor, and so on.
2	Minimum 16 mm <sup>2</sup> (6 AWG) equalizing cable	8	Grounding rail
3	Control cables	9	Cable insulation stripped
4	Minimum 200 mm (7.9 in) between control cables, motor cables, and mains cables	10	All cable entries in one side of panel
5	Mains supply	11	Motor cable
6	Reinforced protective earth	12	Connecting to motor (3 phases and protective earth)

## Design Guide

## 7.4.1 Power Cables and Grounding

Depending on the installation and the required EMC compliance level, using shielded cables is required for motor, brake, and DC connections. Alternatively, unshielded cables within a metal conduit can also be used.

If a shielded cable is used, it is important to connect the shield through a 360° connection. Connect the shield with the supplied clamps, and avoid pigtails, as they limit the shielding functionality.




Illustration 31: Installation of Cable Shield

## NOTICE

## SHIELDED CABLES

If shielded cables or metal conduits are not used, the unit and the installation do not meet regulatory limits.

If a non-shielded wire is used to connect a brake resistor, it is recommended to twist the wires to reduce the electric noise. Ensure that the cables are as short as possible, to reduce interference level from the entire system, and minimize losses.

## ⚠ WARNING ⚠

## ELECTRICAL SHOCK HAZARD - LEAKAGE CURRENT HAZARD

Leakage currents exceed 3.5 mA. Failure to connect the drive properly to protective earth (PE) can result in death or serious injury.

- Ensure reinforced protective earthing conductor according to IEC 60364-5-54 cl. 543.7 or according to local safety regulations for high touch current equipment. The reinforced protective earthing of the drive can be done with:
  - a PE conductor with a cross-section of at least 10 mm<sup>2</sup> (8 AWG) Cu or 16 mm<sup>2</sup> (6 AWG) Al.
  - an extra PE conductor of the same cross-sectional area as the original PE conductor as specified by IEC 60364-5-54 with a minimum cross-sectional area of 2.5 mm<sup>2</sup> (14 AWG) (mechanically protected) or 4 mm<sup>2</sup> (12 AWG) (not mechanically protected).
  - a PE conductor completely enclosed with an enclosure or otherwise protected throughout its length against mechanical damage.
  - a PE conductor part of a multi-conductor power cable with a minimum PE conductor cross-section of 2.5 mm<sup>2</sup> (14 AWG) (permanently connected or pluggable by an industrial connector. The multi-conductor power cable shall be installed with an appropriate strain relief).
- NOTE: In IEC/EN 60364-5-54 cl. 543.7 and some application standards (for example IEC/EN 60204-1), the limit for requiring reinforced protective earthing conductor is 10 mA leakage current.

Ground the drive according to applicable standards and directives. Use a dedicated ground wire for input power, motor power, and control wiring. Terminate individual ground wires separately, complying with the dimension requirements.

Follow motor manufacturers wiring requirements when connecting to the motors.

Keep the grounding wire as short as possible. Minimum cable cross-section for the ground wires is 10 mm<sup>2</sup> (7 AWG). Alternatively, it is possible to use 2 rated ground wires terminated separately. Do not ground drives to each other in a daisy chain fashion (see [Illustration 32](#)).



## Design Guide




Illustration 32: Grounding Principle

## 7.4.2 Control Cables

Use shielded cables for control wiring and avoid placing control wires next to power cables. Ideally, isolate the control cables from the power cables (mains, motor, brake, and DC) by routing them separately or keep a minimum distance of 200 mm (7.9 in). For optional shielding, both ends of the shielded control cables must have the shield connected.

Keep 24 V signal cables apart from 110 V or 230 V signals from relays, for example.

When the drive is connected to a thermistor, ensure that the wiring is shielded and reinforced/double isolated. A 24 V DC supply voltage is recommended.

For communication purpose and command/control lines, follow the particular protocol standard. For example, Ethernet can use shielded (STP).

## 7.5 Galvanic Isolation

PELV offers protection through extra low voltage. Protection against electric shock is ensured when the electrical supply is of the PELV type and the installation is made as described in local/national regulations on PELV supplies.

All control terminals and relay terminals 01–03 comply with PELV (protective extra low voltage).

Galvanic (ensured) isolation is obtained by fulfilling requirements for higher isolation and by providing the relevant creepage/clearance distances. These requirements are described in the EN 61800-5-1 standard.

The components that make up the electrical isolation, as shown in [Illustration 33](#), also comply with the requirements for higher isolation and the relevant test as described in EN 61800-5-1.

The PELV galvanic isolation can be shown in 3 locations (see [Illustration 33](#)):

To maintain PELV, all connections made to the control terminals must be PELV, for example, the thermistor must be reinforced/double insulated.

Design Guide




Illustration 33: Galvanic Isolation

1	Customer relay	3	Power supply (SMPS) for control card
2	Communication between power card and control card	a	Functional galvanic isolation for the RS485 standard bus interface

**⚠ WARNING ⚠**

Before touching any electrical parts, ensure that other voltage inputs have been disconnected, such as load sharing (linkage of DC link) and the motor connection for kinetic back-up. Observe the discharge time stated in the *chapter Safety* in the operating guide. Failure to follow recommendations could result in death or serious injury.

### 7.6 Ground Leakage Current

Follow national and local codes regarding protective grounding of equipment with a leakage current >3.5 mA. Drive technology implies high frequency switching at high power. This switching generates a leakage current in the ground connection. A fault current in the drive at the output power terminals might contain a DC component, which can charge the filter capacitors and cause a transient ground current. The ground leakage current is made up of several contributions and depends on various system configurations including:

- RFI filtering.
- Shielded motor cables.
- Motor cable length.
- Drive power.

Design Guide




Illustration 34: Influence the Cable Length and Power Size on Leakage Current,  $P_a > P_b$

The leakage current also depends on the line distortion.




Illustration 35: Influence of Line Distortion on Leakage Current

EN/IEC61800-5-1 (Power Drive System Product Standard) requires special care if the leakage current exceeds 3.5 mA. Reinforce grounding with the following protective ground connection requirements:

- Ground wire (terminal 95) of at least 10 mm<sup>2</sup> (8 AWG) cross-section.
- 2 separate ground wires that comply with the dimensioning rules.

See EN/IEC61800-5-1 for further information.

### 7.7 Motor Installation Considerations

When selecting an AC drive, consider the following aspects:

## Design Guide

---

- **Torque limits:** When an AC drive controls a motor, torque limits can be set for that motor. Selecting a frequency converter with an apparent power rating that matches the rated current or power of the motor ensures that the required load can be driven reliably. However, an extra reserve is necessary to enable smooth acceleration of the load and also cater for occasional peak loads.
- **Current ratings** of the drive and the motor. Power rating is only a rough guide.
- Correct **operating voltage**.
- Ensure that the motor withstands the **maximum peak voltage** on the motor terminals.
- **Required speed range:** Operation above nominal motor supply frequency (50 Hz or 60 Hz) is possible only at reduced power. Operation at low frequency and high torque can cause the motor to overheat due to lack of cooling.
- **Derating:** Synchronous motors require derating, typically by 2–3 times, because the power factor, and hence the current, can be high at low frequency.
- **Overload performance:** The drive limits current to 150% of full current quickly. A standard, fixed-speed motor tolerates these overloads.
- **Stopping the motor:** If it is necessary to stop the motor quickly, using a brake resistor should be considered (select braking terminals on iC2-Micro Frequency Converters) to absorb the energy.
- The **direction of rotation** when connected to the frequency converter's output terminals U-V-W follows the specification from NEMA MG1 and IEC 60034-8. Ensure correct direction of rotation in the end application to avoid a potential hazardous situation. If only 1 direction of rotation is required, it is recommended to parameterize the drive to operate in the relevant direction only.

For the basics of protecting the motor insulation and bearings in AC drive systems, see [7.7.2 Motor Insulation](#) and [7.7.3 Bearing Currents](#).

### 7.7.1 Supported Motor Types

The iC2-Micro Frequency Converters are compatible with:

- Asynchronous AC induction motors.
- Synchronous permanent magnet motors.

The drives are motor-independent, and can be connected to any brand of motor. For instructions on how to set up motors, refer to the application guide.

For detailed information about the supported motor types, contact Danfoss.

### 7.7.2 Motor Insulation

Because of rapid switching and reflections in the cables, motors are subject to more voltage stress in the windings when fed by AC drives than with sinusoidal supply voltage.

Regardless of frequency, the AC drive output comprises pulses of approximately the drive DC-bus voltage with a short rise time. The pulse voltage can almost double at the motor terminals, depending on the attenuation and reflection properties of the motor cable and the terminals. This stresses the motor winding insulation and can cause it to break down, resulting in possible sparking.

Depending on voltage and cable length, a filter or reinforced insulation of the motor is required.

### 7.7.3 Bearing Currents

AC drives can cause common mode voltages which induce voltages across motor bearings, leading to current flow through motor bearings. To protect against bearing currents, use either sine-wave filters or common-mode filters.

Due to their operating principle, AC drives produce a series of unwanted secondary effects:

- Motor winding isolation stress
- Bearing stress
- Acoustic switching noise in the motor
- Electromagnetic interference

In most applications, these effects are at an acceptable level, but sometimes these effects must be mitigated. For the mitigation of these effects, filters are installed at the output of the drives. The most commonly known filters are dU/dt filters, sine-wave filters, and common-mode filters.

The steep switching rate of the AC drive output voltage combined with the inherent common-mode voltage produced by the AC drive causes shaft voltage. Motor asymmetries, or the use of asymmetric motor cables especially in high-power applications where the motor current exceeds 100–200 A can also cause shaft voltage.

Table 49: Mitigating Bearing Current Effects with Filters

Type of filter	
dU/dt filters	dU/dt filters reduce the slew rate of the voltage pulses at the drive output to rates which are typically below 500 V/ $\mu$ s. This reduces the stress of the motor winding isolation. The voltage shape remains pulse-width modulated. The optional dU/dt filters also protect the motor insulation system and reduce bearing currents.
Sine-wave filters	A sine-wave filter reduces bearing currents and voltage reflections, and it also reduces motor noise. If an output transformer is used, the sine-wave filter eliminates high frequency components that could stress the transformer. The sine-wave filter also allows the use of considerably longer motor cables.
Common-mode filters	Common-mode filters reduce high frequency common-mode currents between AC drive and motors. High-frequency common-mode filters are a good solution for reducing electric bearing current stress, but the use of such filters does not eliminate the need of an EMC-compliant installation.

### 7.7.4 Motor Thermal Protection

During operation, the motor connected to the drive can be monitored to avoid overheating.

Depending on the criticality of overheating, different monitoring methods can be used:

- Built-in Electronic Thermal Motor monitoring
- Externally connected sensors (PTC according to DIN 44081)

#### Electronic Thermal Relay function

The electronic thermal relay (ETR) function protects the motor from thermal overload without connecting an external device by estimating the motor temperature based on present load and time.

The ETR function meets the relevant requirements of UL 61800-5-1, including the Thermal Memory Retention requirement, and ensures a class 20 protection level.

ETR is an electronic feature that simulates a bimetal relay based on internal measurements. The characteristic is shown in [Illustration 36](#).




Illustration 36: ETR

The X-axis shows the ratio between  $I_{\text{motor}}$  and  $I_{\text{motor nominal}}$ . The Y-axis shows the time in seconds before the ETR cuts off and trips the drive. The curves show the characteristic nominal speed at twice the nominal speed and at 0.2 x the nominal speed. At lower speed, the ETR cuts off at lower heat due to less cooling of the motor. In that way, the motor is protected from being overheated even at low speed. The ETR feature calculates the motor temperature based on actual current and speed. The calculated temperature is visible as a readout parameter in *parameter P4.1.5 Motor Thermal Load*.

#### Externally connected sensors

Monitoring can be done by using analog input or digital inputs on the I/O board or with functional extension options. The sensors must be either double isolated or have reinforced insulation between motor and drive control.

The analog input allows measurement of the temperature by using external sensors.

Using a digital input allows monitoring with a PTC sensor. The PTC must be connected from 24 V DC to the digital input.

For more information on configuring the functionalities, refer to the application guide.

## 7.8 Extreme Running Conditions

### Short circuit (motor phase to phase)

The drive is protected against short circuits by current measurement in each of the 3 motor phases or in the DC link. A short circuit between 2 output phases causes an overcurrent in the drive. The drive is turned off individually when the short-circuit current exceeds the allowed value (Fault 16, short circuit).

### Switching on the output

Switching on the output between the motor and the drive is fully allowed and does not damage the drive. However, fault messages may appear.

### Motor-generated overvoltage

The voltage in the DC link is increased when the motor acts as a generator. This occurs in following cases:

- The load drives the motor (at constant output frequency from the drive).
- If the inertia moment is high during deceleration (ramp-down), the friction is low and the ramp-down time is too short for the energy to be dissipated as a loss in the drive, the motor, and the installation.
- Incorrect slip compensation setting may cause higher DC-link voltage.

The control unit may attempt to correct the ramp if possible (*parameter P2.3.1 Overvoltage Controller Enable*). The drive turns off to protect the transistors and the DC link capacitors when a certain voltage level is reached.

To select the method used for controlling the DC-link voltage level, see *parameter P2.3.1 Overvoltage Controller Enable*, *parameter P3.2.1 Enable Brake Chopper*, and *parameter P4.4.2.1 Enable AC-Brake*.

### Mains drop-out

During a mains drop-out, the drive keeps running until the DC-link voltage drops below the minimum stop level, which is:

- 314 V for 3x380–480 V.
- 180 V for 1x200–240 V.

The mains voltage before the drop-out and the motor load determines how long it takes for the inverter to coast.

### Static overload in VVC+ mode

When the drive is overloaded, the torque limit in *parameter P5.10.1 Motor Torque Limit/parameter P5.10.2 Regenerative Torque Limit* is reached, the control unit reduces the output frequency to reduce the load.

If the overload is excessive, an overcurrent which makes the drive cut out after approximately 5–10 s may occur.

Operation within the torque limit is limited in time (0–60 s) in *parameter P5.10.6 Trip Delay at Torque Limit*.

### Torque limit

The torque limit protects the motor from being overloaded independent of the speed. Torque limit is controlled in *parameter P5.10.1 Motor Torque Limit* and *parameter P5.10.2 Regenerative Torque Limit*. *Parameter P5.10.6 Trip Delay at Torque Limit* controls the time before the torque limit warning trips.

### Current limit

*Parameter P2.7.1 Output Current Limit %* controls the current limit, and *parameter P2.7.5 Trip Delay at Current Limit* controls the time before the current limit warning trips.

### Minimum speed limit

*Parameter P5.8.3 Motor Speed Low Limit [Hz]* sets the minimum output speed that the drive can provide.

### Maximum speed limit

*Parameter P5.8.2 Motor Speed High Limit [Hz]* or *parameter P2.3.14 Max Output Frequency* sets the maximum output speed that the drive can provide.

## 7.9 Power Cable Considerations

When selecting power cables, consider:

- All wiring must comply with local and national regulations regarding cross-section and ambient temperature requirements.
- Drives are designed for use with 70 °C (158 °F) rated copper cables. Unless otherwise stated, the ambient temperature of the drive matches the cable rating.
- Aluminum conductors are not recommended. When using aluminum conductors, ensure that the conductor surface is clean and the oxidation is removed and sealed by a neutral acid-free grease before connecting the conductor. Retighten the terminal screw after 2 days due to the softness of aluminum. It is crucial to keep the connection a gas-tight joint, otherwise the aluminum surface oxidizes again.
- Cable lugs are required for the PE wire.
  - For MA01c–MA02c, recommended cable lug for PE wire is JST 8-4 (solderless terminals ring tongue).

For details on power connector sizing, see [4.4 Power Connectors](#). The dimensions apply to both solid and stranded cables.

Design Guide

### 7.9.1 Torque Requirements

Connections must be tightened with the correct torque, see the following table.

Table 50: Torque Requirements

Enclosure size	Mains and motor [Nm (in-lb)]	DC connection [Nm (in-lb)]	Brake [Nm (in-lb)]	Customer relay [Nm (in-lb)]	Grounding connection [Nm (in-lb)]
MA01c	0.7 (6.2)	0.7 (6.2)	–	0.5 (4.4)	1.5 (13.3)
MA02c	0.7 (6.2)	0.7 (6.2)	–	0.5 (4.4)	1.5 (13.3)
MA01a	0.7 (6.2)	Straight receptacles	–	0.5 (4.4)	1.5 (13.3)
MA02a	0.7 (6.2)	Straight receptacles	–	0.5 (4.4)	1.5 (13.3)
MA03a	0.7 (6.2)	Straight receptacles	–	0.5 (4.4)	1.5 (13.3)
MA04a	1.2 (10.6)	1.2 (10.6)	1.2 (10.6)	0.5 (4.4)	2.0 (17.7)
MA05a	1.2 (10.6)	1.2 (10.6)	1.2 (10.6)	0.5 (4.4)	2.0 (17.7)


### 7.10 Electrical Installation

#### 7.10.1 Mains, Motor, and Grounding Connection

The mains, motor, and grounding connection for single-phase and 3-phase drives are shown in the following illustrations. Actual configurations vary with unit types and optional equipment.

#### NOTICE

In motors without phase insulation, paper, or other insulation reinforcement suitable for operation with voltage supply, use a sine-wave filter on the output of the drive.



e30bv106.10

Illustration 37: Mains, Motor, and Grounding Connection for Single-phase Units (Taking MA02c as an Example)

Design Guide


1	Mains	3	Motor
2	Grounding point A	4	Grounding point B

**NOTICE**

For MA01c and MA02c drives, grounding point A supports 10 mm<sup>2</sup> (7 AWG) cable via a cable shoe, the recommended cable shoe type is *JST copper tubular lug TUB-4*.

**NOTICE**

For MA01c and MA02c drives, decoupling plates are needed if 3 grounding terminals are used.



e30bv107.10

Illustration 38: Mains, Motor, and Grounding Connection for 3-phase Units (Taking MA02a as an Example)

1	Grounding	3	Motor
2	Mains		

7.10.2 Connecting the Motor

**⚠ WARNING ⚠**

**INDUCED VOLTAGE**

Induced voltage from output motor cables that run together can charge equipment capacitors, even with the equipment turned off and locked out/tagged out. Failure to run output motor cables separately, or to use shielded cables, could result in death or serious injury.

- Run output motor cables separately or use shielded cables.
- Simultaneously lock out/tag out all the drives.



Design Guide

- Comply with local and national electrical codes for cable sizes. For maximum cable sizes, see [4.4 Power Connectors](#).
- Follow motor manufacturer wiring requirements.
- Motor wiring knockouts or access panels are provided at the base of IP21/Type 1 units.
- Do not wire a starting or pole-changing device (for example, Dahlander motor or slip ring induction motor) between the drive and the motor.

### 7.10.3 Connecting AC Mains

- Size the wiring based on the input current of the drive. For maximum wire sizes, see [4.4 Power Connectors](#).
- Comply with local and national electrical codes for cable sizes.

Procedure

1. Connect the AC input power cables to terminals N and L for single-phase units, or to terminals L1, L2, and L3 for 3-phase units as shown in the following illustration (see [7.10.1 Mains, Motor, and Grounding Connection](#) for more details).




Illustration 39: Single-phase and 3-phase Wire Connections

2. Depending on the configuration of the equipment, connect the input power to the mains input terminals or the input disconnect.
3. Ground the cable in accordance with the grounding instructions, see [7.4.1 Power Cables and Grounding](#).

### 7.10.4 Control Terminal Types




Illustration 40: Control Terminal Numbers and Locations

1	Control I/O terminals	3	Relay
2	Serial communication		

Table 51: Terminal Descriptions

Terminal	Parameter	Default setting	Description
Digital I/O, pulse I/O			
12	-	+24 V DC	24 V DC supply voltage. Maximum output current is 100 mA.

## Design Guide

Terminal	Parameter	Default setting	Description
13	<i>Parameter P9.4.1.2 Terminal 13 Digital Input</i>	[8] Start	Digital input.
14	<i>Parameter P9.4.1.3 Terminal 14 Digital Input</i>	[10] Reversing	Digital input.
15	<i>Parameter P9.4.1.4 Terminal 15 Digital Input</i>	[1] Reset	Selectable for either digital input, digital output, or pulse output. The default setting is digital input.
	<i>Parameter P9.4.2.2 Terminal 15 Digital Output</i>	[0] No Operation	
	<i>Parameter P9.4.5.1 Terminal 15 Pulse Output</i>	[0] No Operation	
17	<i>Parameter P9.4.1.5 Terminal 17 Digital Input</i>	[14] Jog	Digital input.
18	<i>Parameter P9.4.1.6 Terminal 18 Digital Input</i>	[0] No Operation	Digital input, can also be used for pulse input.
20	–	–	Common for digital and analog inputs.
<b>Analog inputs/outputs</b>			
31	<i>Parameter P9.5.1.1 Terminal 31 Mode</i>	[0] 0–20 mA	Programmable analog output. The analog signal is 0–20 mA or 4–20 mA at a maximum of 500 Ω.
32	–	+10 V DC	10 V DC analog supply voltage. 25 mA maximum commonly used for potentiometer or thermistor.
33	<i>Parameter P9.5.2.1 Terminal 33 Mode</i>	[1] Voltage Mode	Analog input. Selectable between voltage or current mode.
34	<i>Parameter P9.5.3.1 Terminal 34 Mode</i>	[1] Voltage Mode	Analog input. Selectable between voltage or current mode.
35	–	–	Common for digital and analog inputs.
<b>Serial communication</b>			
61	–	–	Integrated RC filter for cable shield. ONLY for connecting the shield when experiencing EMC problems.
68 (+)	<i>Parameter group G10.1 FC Port Settings</i>	–	RS485 interface. A switch is provided for termination resistance.
69 (-)	<i>Parameter group G10.1 FC Port Settings</i>	–	
<b>Relays</b>			
01, 02, 03	<i>Parameter P9.4.3.1 Function Relay</i>	[9] Fault	Form C relay output. These relays are in various locations depending on the drive configuration and size. Usable for AC or DC voltage and resistive or inductive loads.

### 7.10.5 Control Wire Sizes and Stripping Lengths

Connections are made by pushing solid wire into the connector. If flexible (multicore) wire is used, ferrules are recommended. When flexible wire is used without ferrules, the connector is pushed with a small screwdriver as shown in [Illustration 41](#). The maximum size of the screwdriver is 3 mm.

Design Guide




Illustration 41: Inserting Wires into the Connector

1	I/O terminal
2	RS485 terminal

Table 52: Cable Sizing for I/O Terminal

Wire type	Cross-section [mm <sup>2</sup> (AWG)]	Stripping length A [mm (in)]
Solid	0.2–1.5 (24–16)	8.5–9.5 (0.33–0.37)
Flexible with ferrule	0.2–1.5 (24–16)	8.5–9.5 (0.33–0.37)

Table 53: Cable Sizing for RS485 Terminal

Wire type	Cross-section [mm <sup>2</sup> (AWG)]	Stripping length A [mm (in)]
Solid	0.25–1.5 (24–16)	5–6 (0.20–0.24)
Flexible with ferrule	0.25–1.5 (24–16)	5–6 (0.20–0.24)

### 7.10.6 Cable Shield Connection

The cable shield must be completely in contact with the EMC clamp on the EMC plate. Cable isolation must be removed and the cable shield exposed for the entire surface. Avoid pigtails.

Design Guide




Illustration 42: Correct Connection of the Cable Shield

7.10.7 Load Sharing/Brake

Table 54: Connect Terminals

Load sharing	-UDC and +UDC/+BR
Brake	-BR and +UDC/+BR

- For MA01a, MA02a, and MA03a drives, wire with recommended connector (Ultra- Pod Fully Insulated FASTON Receptacles and Tabs, 521366-2, TE connectivity).
- For other enclosure sizes, mount the wires to the related terminal and tighten. For required maximum screwing torque, see the back of the terminal cover.

**NOTICE**

Voltage levels of up to 850 V DC may occur between terminals +UDC/+BR and -UDC. Not short-circuit protected.





Illustration 43: Wiring the Connector for Load Sharing and Brake

Design Guide

1	Connector	3	Wiring completed
2	Wiring the connector		



e30bv090.10


Illustration 44: Connecting to Load Sharing and Brake

NOTICE

**BRAKE FUNCTION OF MA02A**

For MA02a, only 3x380–480 V drives have brake function.

- Do not connect the brake cable to MA02a 1x200–240 V drives.



e30bv102.10

Illustration 45: Brake Function of MA02a (3x380-480 V)

## 8 How to Order

### 8.1 Model Code

The configuration of the drive is reflected in the model code. The model code can be used to identify the specific drive configuration and its inbuilt features.

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27
i	C	2	-	3	0	F	A	3	N	0	4	-	0	1	A	2	E	2	0	F	0	+	A	C	B	C
								1	N	0	2									F	2		A	C	X	X
																				F	4					

e30by086.10

Illustration 46: Model Code

Table 55: Example of a Final Model Code

Description	Position	Function
Product group	1–6	iC2-30
Product category	7–8	FA: Frequency converter, air-cooled
Product type	9–10	<ul style="list-style-type: none"> <li>3N: 3-phase power supply</li> <li>1N: 1-phase power supply</li> </ul>
Mains voltage	11–12	<ul style="list-style-type: none"> <li>04: 380–480 V AC</li> <li>02: 200–240 V AC</li> </ul>
Current rating	14–17	01A2–43A0
Protection rating	18–20	E20: IP20/Open Type
EMC category	21–22	<ul style="list-style-type: none"> <li>F0: C1 category (with integrated EMC filter)</li> <li>F2: C2 category (with integrated EMC filter)</li> <li>F4: C4 category (without integrated EMC filter)</li> </ul>
Integrated brake chopper	Plus code	<ul style="list-style-type: none"> <li>+ACBC: With integrated brake chopper</li> <li>+ACXX: Without integrated brake chopper</li> </ul>

### 8.2 Ordering Accessories and Spare Parts

Table 56: Code Numbers for Ordering Accessories

Category	Part name	Code number
IP21/Type 1 conversion kits	IP21/Type 1 conversion kit, MA01c	132G0188
	IP21/Type 1 conversion kit, MA02c	132G0189
	IP21/Type 1 conversion kit, MA01a	132G0190
	IP21/Type 1 conversion kit, MA02a	132G0191
	IP21/Type 1 conversion kit, MA03a <sup>(1)</sup>	132G0192
	IP21/Type 1 conversion kit, MA04a <sup>(1)</sup>	132G0193
	IP21/Type 1 conversion kit, MA05a <sup>(1)</sup>	132G0194

Category	Part name	Code number
NEMA 1 conversion kits	NEMA 1 conversion kit, MA01c	132G0195
	NEMA 1 conversion kit, MA02c	132G0196
	NEMA 1 conversion kit, MA01a	132G0197
	NEMA 1 conversion kit, MA02a	132G0198
	NEMA 1 conversion kit, MA03a <sup>(1)</sup>	132G0199
	NEMA 1 conversion kit, MA04a <sup>(1)</sup>	132G0200
	NEMA 1 conversion kit, MA05a <sup>(1)</sup>	132G0201
Decoupling plate mounting kits	Decoupling plate mounting kit, MA01c	132G0202
	Decoupling plate mounting kit, MA02c	132G0203
	Decoupling plate mounting kit, MA01a	132G0204
	Decoupling plate mounting kit, MA02/03a	132G0205
	Decoupling plate mounting kit, MA04/05a <sup>(1)</sup>	132G0206
Connectors	Connector for common DC/brake resistor	132G0207
HMI and related accessories	Control panel 2.0 OP2 <sup>(1)</sup>	132G0234
	Surface mounting kit OA2 <sup>(1)</sup>	132G0235
	Flush mounting kit OA2 <sup>(1)</sup>	132G0236
	Control panel cable 1.5 m OA2 <sup>(1)</sup>	132G0237
	Control panel cable 3 m OA2 <sup>(1)</sup>	132G0238

<sup>1</sup> Not available currently.

Table 57: Code Numbers for Ordering Spare Parts

Category	Part name	Code number
Cooling fans	Cooling fan, MA02c	132G0215
	Cooling fan, MA01a	132G0216
	Cooling fan, MA02a	132G0217
	Cooling fan, MA03a <sup>(1)</sup>	132G0218
	Cooling fan, MA04a <sup>(1)</sup>	132G0219
	Cooling fan, MA05a <sup>(1)</sup>	132G0220
Spare parts kits	Spare parts kit, MA01c	132G0221
	Spare parts kit, MA02c	132G0222
	Spare parts kit, MA01a	132G0223
	Spare parts kit, MA02a	132G0224

Category	Part name	Code number
	Spare parts kit, MA03a <sup>(1)</sup>	132G0225
	Spare parts kit, MA04a <sup>(1)</sup>	132G0226
	Spare parts kit, MA05a <sup>(1)</sup>	132G0227

<sup>1</sup> Not available currently.

## 8.3 Ordering Brake Resistors

### 8.3.1 Introduction

Danfoss offers a wide variety of different resistors that are specially designed for our drives. This section lists the ordering numbers for the brake resistors. The resistance of the brake resistor given by ordering number may be bigger than  $R_{rec}$ . In this case, the actual braking torque could be smaller than the highest braking torque which the drive can provide.

### 8.3.2 Ordering Brake Resistors 10%

Table 58: iC2-Micro Frequency Converters - Mains: 3x380–480 V AC, 10% Duty Cycle

Power rating	$P_m$ (HO)	$R_{min}$	$R_{br. nom}$	$R_{rec}$	$P_{br avg}$	Ordering number	Period	Cable cross-section <sup>(1)</sup>	Thermal relay	Maximum brake torque with resistor
3-phase 380–480 V	[kW (hp)]	[ $\Omega$ ]	[ $\Omega$ ]	[ $\Omega$ ]	[kW (hp)]	175Uxxxx	[s]	[mm <sup>2</sup> (AWG)]	[A]	[%]
05A3	2.2 (3.0)	139	163.95	155	0.190 (0.255)	3008	120	1.5 (16)	0.9	131
07A2	3 (4.0)	100	118.86	112	0.262 (0.351)	3300	120	1.5 (16)	1.3	131
09A0	4 (5.0)	74	87.93	83	0.354 (0.475)	3335	120	1.5 (16)	1.9	128

<sup>1</sup> All cabling must comply with national and local regulations on cable cross-sections and ambient temperature.



### 8.3.3 Ordering Brake Resistors 40%

Table 59: iC2-Micro Frequency Converters - Mains: 3x380–480 V AC, 40% Duty Cycle

Power rating	P <sub>m</sub> (HO)	R <sub>min</sub>	R <sub>br. nom</sub>	R <sub>rec</sub>	P <sub>br avg</sub>	Ordering number	Period	Cable cross-section <sup>(1)</sup>	Thermal relay	Maximum brake torque with resistor
3-phase 380–480 V (T4)	[kW (hp)]	[Ω]	[Ω]	[Ω]	[kW (hp)]	175Uxxxx	[s]	[mm <sup>2</sup> (AWG)]	[A]	[%]
05A3	2.2 (3.0)	139	163.95	155	0.807 (1.082)	3312	120	1.5 (16)	2.1	131
07A2	3 (4.0)	100	118.86	112	1.113 (1.491)	3313	120	1.5 (16)	2.7	131
09A0	4 (5.0)	74	87.93	83	1.504 (2.016)	3314	120	1.5 (16)	3.7	128

<sup>1</sup> All cabling must comply with national and local regulations on cable cross-sections and ambient temperature.

## Index

### A

#### AC

Mains.....	12
Input.....	12,72
Waveform.....	13
Brake.....	25

Accessories.....	77
------------------	----

Acoustic noise.....	36
---------------------	----

Additional documentation.....	7
-------------------------------	---

#### Ambient conditions

Storage.....	33
Transport.....	34
Operation.....	34

Analog Input.....	32
-------------------	----

Approvals.....	10
----------------	----

### B

Block diagram.....	12
--------------------	----

Bolts.....	53
------------	----

Brake.....	75
------------	----

Brake chopper.....	12
--------------------	----

Brake function.....	27
---------------------	----

Brake resistor.....	26, 79
---------------------	--------

Built-in EMC filter.....	15, 39
--------------------------	--------

### C

Cable shield connection.....	74
------------------------------	----

Cable size.....	72
-----------------	----

Capacitor bank.....	12
---------------------	----

Capacitor reforming.....	48
--------------------------	----

CE mark.....	10
--------------	----

Certifications.....	10
---------------------	----

Change log.....	7
-----------------	---

Circuit breakers.....	35
-----------------------	----

Commercial environment.....	38
-----------------------------	----

Configurator.....	7
-------------------	---

Contents of the shipment.....	46
-------------------------------	----

Control circuitry.....	13
------------------------	----

Control I/O.....	30
------------------	----

Control Panel.....	17
--------------------	----

Control Panel 2.0 OP2.....	17
----------------------------	----

Control terminals.....	15, 72
------------------------	--------

Control wire sizes.....	73
-------------------------	----

Cooling fan.....	51, 78
------------------	--------

CSA/cUL approval.....	10
-----------------------	----

Current limit.....	69
--------------------	----

### D

#### DC

Current.....	12
Bus.....	12
Reactor.....	12
Brake.....	25

Decoupling plate mounting kit.....	78
------------------------------------	----

Derating.....	15, 40, 40, 42
---------------	----------------

#### Dimensions

IP20/Open Type.....	43
IP21/UL Type 1.....	44
NEMA 1.....	45

Directives.....	10
-----------------	----

Disposal.....	48, 48
---------------	--------

Drawings.....	7
---------------	---

Drilling patterns.....	53
------------------------	----

Drive labels.....	46
-------------------	----

dU/dt.....	39
------------	----

Dynamic braking.....	25
----------------------	----

### E

EAN.....	48
----------	----

Ecodesign.....	13
----------------	----

Electromagnetic interference.....	8
-----------------------------------	---

Electronic thermal relay.....	68
-------------------------------	----

#### EMC

Directive.....	11
----------------	----

Compliance level.....	37
-----------------------	----

Emission requirements.....	38
----------------------------	----

Immunity requirements.....	38
----------------------------	----

Compatibility.....	39
--------------------	----

#### EMC considerations

Power cables.....	63
-------------------	----

Grounding.....	63
----------------	----

Control cables.....	64
---------------------	----

Energy efficiency.....	13
------------------------	----

ErP directive.....	11
--------------------	----

ETR.....	68
----------	----

European Article Number.....	48
------------------------------	----

Export control regulation.....	11
--------------------------------	----

External controller.....	12
--------------------------	----

External sensors.....	68
-----------------------	----

Extreme running condition.....	69
--------------------------------	----

### F

Forced air cooling.....	55
-------------------------	----

Foreseeable misuse.....	12
-------------------------	----

Fuses.....	35
------------	----

### G

General safety considerations.....	8
------------------------------------	---

Grid types.....	59, 59
-----------------	--------

Grounding.....	72
----------------	----

Grounding connection.....	70
---------------------------	----

### H

Heat sink.....	51
----------------	----

### I

Indicator lights.....	18
-----------------------	----

Inertia moment.....	69
---------------------	----

Input power.....	13, 72
------------------	--------

Installation prerequisites.....	50
---------------------------------	----

Integrated filter.....	15
------------------------	----

Intended use.....	12
-------------------	----

Inverter.....	13
---------------	----

IP20/Open Type.....	14, 43, 50
---------------------	------------

IP21/Type 1 conversion kit.....	77
---------------------------------	----

IP21/UL Type 1.....	14, 44, 50
---------------------	------------

### K

KC mark.....	10
--------------	----

Knockout.....	72	Product information.....	7
Korea certification.....	10	Product labels.....	46, 46
		Purpose of the guide.....	7
<b>L</b>			
Labels.....	46	<b>Q</b>	
Leakage current.....	60, 61, 63, 65	Qualified personnel.....	7, 9
Load sharing.....	75		
Low voltage directive.....	10	<b>R</b>	
<b>M</b>			
Machinery directive compliance.....	11	RCM mark compliance.....	10
Mains connection.....	70	Rectifier.....	12
Mains drop-out.....	69	Recycling.....	48
Mains input.....	12	Remote commands.....	12
Mains supply.....	28, 28, 29	Residential environment.....	38
Maintenance considerations.....	50	Resistor brake.....	25
Maximum speed limit.....	69	RFI filter.....	12
Mechanical holding brake.....	25	Rise time.....	40
Medical devices.....	8	RJ45 port.....	16
Minimum clearance for cooling.....	54	RMS.....	12
Minimum speed limit.....	69	RoHS directive.....	11
Model code.....	77	Root mean square current.....	12
Motor		RS485.....	16, 33, 74
Status surveillance.....	12	<b>S</b>	
Overload protection.....	12	Safe operation guidelines.....	8
Current.....	13	Safety instructions.....	8
Thermal protection.....	15	Screws.....	53
Cable length.....	39	Service access.....	51, 55
Voltage.....	40	Shielded cable.....	72
Installation.....	66	Short circuit.....	69
Types.....	67	Sliding door	
Insulation.....	67	Disassembly.....	19
Phase.....	69	Reassembly.....	20
Connection.....	70	Spare parts.....	78
Motor-generated overvoltage.....	69	Spare parts kit.....	78
Mounting		Static overload in VVC+ mode.....	69
Considerations.....	52	Storage.....	49
Locations.....	52	Support material.....	7
Directions.....	52	Switching on the output.....	69
MyDrive® Insight.....	24	Symbols.....	7
<b>N</b>			
Natural air cooling.....	55	System efficiency.....	13
NEMA 1.....	45	System feedback.....	12
NEMA 1 conversion kit.....	78	<b>T</b>	
<b>O</b>			
Operating environment.....	50	Technical data	
Overheating.....	68	Grid.....	29
Overload protection.....	29	Motor output.....	30
<b>P</b>			
Package labels.....	47	Torque characteristics.....	30
PELV.....	64	Digital input.....	30
Potentiometer.....	18	Pulse input.....	30
Power cable considerations.....	69	Digital output.....	31
Power connectors.....	35	Pulse output.....	31
Power drive system.....	13	Analog input.....	31
Power factor.....	12	Analog output.....	32
Power hardware.....	14	Relay output.....	32
Power losses.....	13	Auxiliary voltages.....	33
		Terminal cover.....	15
		Thermal monitoring.....	68
		Torque limit.....	69
		Torque requirements.....	70
		Transportation.....	49
		Type approvals.....	10

---

<b>U</b>		Voltage	
UKCA.....	10	Safety warning.....	8
UL Listing.....	10		
<b>V</b>		<b>W</b>	
Version history.....	7	Wiring diagram.....	7, 58

**Danfoss A/S**  
Ulsnaes 1  
DK-6300 Graasten  
[drives.danfoss.com](http://drives.danfoss.com)

---

Danfoss can accept no responsibility for possible errors in catalogs, brochures, and other printed material. Danfoss reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without subsequential changes being necessary in specifications already agreed. All trademarks in this material are property of the respective companies. Danfoss and the Danfoss logotype are trademarks of Danfoss A/S. All rights reserved.

---

