



Product Service

CERTIFICATE

No. Z10 082282 0007 Rev. 01

Holder of Certificate: Danfoss Drives A/S
Ulsnæs 1
6300 Gråsten
DENMARK

Certification Mark:



Product: Safety components
AC Frequency Converter
Model(s): VLT® Refrigeration Drive Series FC 103

Parameters:

Supply voltage:	200-690VAC
Power output:	1.1–800kW
Safety parameters:	SIL 2 (IEC 61508, EN 61800-5-2) Cat 3, PL d (EN ISO 13849-1)
Safety function:	Safe Torque Off (STO) according to EN 61800-5-2

The report DG92319C and the user manuals in the currently valid revisions are mandatory parts of this certificate.

Tested according to: IEC 61508-1:2010
IEC 61508-2:2010
EN ISO 13849-1:2015
EN 61800-5-2:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: DG92319C
Valid until: 2027-11-02
Date, 2022-11-04

(Matthias Ramold)