



FRAME SIZE A5			
VOLTAGE	HP	KW	
208/230	0.5-5	0.75-3.7	
460/600	0.5-10	0.75-7.5	

UNIT COOLING:

THE UNIT MUST BE INSTALLED VERTICALLY WITH THE MINIMUM FREE SPACE. UL NEMA TYPE 12 UNITS MAY BE MOUNTED SIDE BY SIDE WITH NO MINIMUM CLEARANCE.

- 1) 3X PLACE CONDUITS IN PRE-EXISTING CONDUIT HOLES. IF NOT USED, PLUG HOLES WITH NEMA TYPE 12 HOLE PLUGS.
- 2) FOR NEMA TYPE 12 UNITS USE NEMA TYPE 12 CONDUITS AND HUBS

-NOTICE- THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF THE TRANE COMPANY

DESIGNED BY/DATE: MN 10/17/08	CHANGED BY/DATE: 20105/09	TITLE: DWG, REF, SUBMITTAL, A5-TIER 1
APPROVAL: MN 10/17/08	ENG. APPROVAL BY/DATE: 01/05/09	SHEET: 1 OF 1
LATEST E.C.N. NO.:	E.C.N. PROC. E-ENTRY BY/DATE:	DRAWING NO.: 174N3457
PROJ. E-ENTRY BY/DATE:	PROJ. SCALE:	REV.:
NONE	NONE	