

1. * INDICATES COMPONENTS NOT SUPPLIED BY MANUFACTURER. REFER TO THE INSTALLATION AND OPERATION MANUAL FOR DRIVE FUNCTIONS AND PARAMETER SETTINGS.

3. FEEDER CIRCUIT PROTECTION, INPUT POWER AND MOTOR WRING MUST BE SELECTED IN ACCORDANCE WITH THE N.E.C., ANY APPLICATION LOCAL CODES AND THE LOAD CURRENT RATING.

4. REPLACE JUMPER 'J1' WITH NORMALLY CLOSED SAFETY INTERLOCK CONTACT AS NECESSARY. CONTACT MUST BE RATED 1/4 HP @ 120VAC MINIMUM.

5. PANEL MAY REQUIRE DERATING, CONSULT DRIVE MANUAL OR FACTORY FOR FOLLOWING CONDITIONS:

5.1. HIGHER SWITCHING FREQUENCY THAN DRIVE DEFAULT HIGHER THAN PANEL LISTED AMBIENT TEMPERATURES

5.3. ELEVATION ABOVE 3300 FEET (1000 METERS)

5.4. LONG MOTOR LEAD LENGTHS

6. WHEN MOTOR OVERLOADS SIZES ARE DIFFERENT, MOTOR 1 WILL BE THE LARGER OF THE TWO MOTORS

ARE SET DIFFERENT FROM THE DRIVE DEFAULT SETTINGS. ADDITIONAL PARAMETER SETTINGS MAY BE REQUIRED FOR YOUR APPLICATION.

DRIVE PARAMETER SETTINGS

PARAMETER # NAME		SETTING	VALUE
0-02	0-02 MOTOR SPEED UNIT		HZ
0-03	0-03 REGIONAL SETTINGS		NORTH AMERICA
1-03 TORQUE CHAR. 5-02 TERMINAL 29 TYPE		1	VARIABLE TORQUE
		1	OUTPUT
5-31	TERMINAL 29	5	RUNNING
14-20	RESET MODE	13	INFINITE AUTO REST

THE FOLLOWING TABLE LISTS THE PARAMETERS THAT

В			-NOTICE-	DRN	NAME	N	EMA 3R,480V,2C			THE TRANE COMPANY	
А	SP10119	11/10	THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO	DIM			IN CB ,DRIVE FU			A DIVISION OF AMERICAN STANDARD INC.	
DR	SP10076	09/10	OUTSIDE PARTIES WITHOUT THE WRITTEN	/10 OUTSIDE PARTIES WITHOUT THE WRITTEN APR	APR	MODEL	,3MB	,DUAL MOTOR,1	SIZE A	DWG 1 O	
REV	ECN	DATE	CONSENT OF THE TRANE COMPANY	DTM	WIODEL	TR200	page <u>1</u> of <u>2</u>		Nö. 8	5582845	

WIRE COLOR SCHEME BLACK - LINE VOLTAGE
RED - AC CONTROL
WHITE - AC GROUNDED
CIRCUIT CONDUCTOR
BLUE - DC CONTROL
GREEN - CHASSIS GROUND

TERMINAL IDENTIFICATION

X - DRIVE TERMINAL


X - CUSTOMER TERMINAL


CUSTOMER DRY CONTACT RATINGS

RELAY	CONTACT RATING		
CR1, CR6	5A @ 120VAC 1/10 HP @ 120VAC		
M2, M3	10A @ 120/240VAC		



X INDICATES CONTACT CLOSED						
POSITION						
CONTACT	DRIVE	OFF	BYPASS			
13-14			Χ			
23-24	Χ					





	В		
	Α	SP10119	11/10
DR		SP10076	09/10
	REV	ECN	DATE

THIS DRAWING IS PROPRIETARY AND SHALL NOT
BE COPIED OR ITS CONTENTS DISCLOSED TO
BE COLLED ON THE CONTINUE BIOGEOGED TO
OUTSIDE PARTIES WITHOUT THE WRITTEN
CONSENT OF THE TRANE COMPANY
CONSERT OF THE HOUSE COMPONITY

-NOTICE-

DRN D TM	NAME	,MAI	EMA 3R,480V,2C N CB ,DRIVE FU ,DUAL MOTOR,1	THE TRANE COMPAN A DIVISION OF AMERICAN STANDARD INC		
apr DTM	MODEL	TR200	PAGE <u>2</u> OF <u>2</u>	SIZE	DWG 1 8	5B2845

THE	TRAN	E COM	PANY
АМЕ	A DIVI RICAN S	SION OF	