WIRE COLOR SCHEME
BLACK — LINE VOLTAGE
RED — AC CONTROL
WHITE — AC GROUNDED
CIRCUIT CONDUCTOR
BLUE — DC CONTROL

TERMINAL IDENTIFICATION

X - DRIVE TERMINAL

(X) - CUSTOMER TERMINAL


GREEN - CHASSIS GROUND EARTH GROUND EARTH GROUND AC MOTOR *CUSTOMER SUPPLIED BLK 3L1 L1/R/91 INPUT T1/U/96 F16A 0-\\ 1L2 POWER | T16B| 3L2 | L1/R/91 | L2/S/92 ADJUSTABLE FREQUENCY FEEDER BLK T2 3 PH, 480V, T2/V/97 DRIVE |F16E| 3L3 | L2/3/92 | L3/T/93 CIRCUIT BLK PROTECTION T3/W/98 (AFD) (SEE NOTE 3) CB1 DRIVE INPUT FUSES CIRCUIT BREAKER EARTH GROUND GRN


CUSTOMER DRY CONTACT RATINGS

RELAY

CONTACT RATING

5A © 120VAC
1/10 HP © 120VAC





WARNING!
THE FOLLOWING TABLE LISTS THE PARAMETERS THAT
ARE SET DIFFERENT FROM THE DRIVE DEFAULT SETTINGS.
ADDITIONAL PARAMETER SETTINGS MAY BE REQUIRED

NOTES:

1. * INDICATES COMPONENTS NOT SUPPLIED BY MANUFACTURER.

- 2. REFER TO THE INSTALLATION AND OPERATION MANUAL FOR DRIVE FUNCTIONS AND PARAMETER SETTINGS.
- 3. FEEDER CIRCUIT PROTECTION, INPUT POWER AND MOTOR WIRING MUST BE SELECTED IN ACCORDANCE WITH THE N.E.C., ANY APPLICATION LOCAL CODES AND THE LOAD CURRENT RATING.
- 4. REPLACE JUMPER 'J1' WITH NORMALLY CLOSED SAFETY INTERLOCK CONTACT AS NECESSARY.
- 5. PANEL MAY REQUIRE DERATING, CONSULT DRIVE MANUAL OR FACTORY FOR FOLLOWING CONDITIONS:

LIOTIOE

- 5.1. HIGHER SWITCHING FREQUENCY THAN DRIVE DEFAULT
- 5.2. HIGHER THAN PANEL LISTED AMBIENT TEMPERATURES
- 5.3. ELEVATION ABOVE 3300 FEET (1000 METERS)
- 5.4. LONG MOTOR LEAD LENGTHS

DRIVE PARAMETER SETTINGS

PARAMETER #	NAME	SETTING	VALUE HZ NORTH AMERICA AUTO ENERGY OPTIM VT			
0-02	MOTOR SPEED UNIT	1				
0-03	REGIONAL SETTINGS	1				
1-03	TORQUE CHAR.	3				
5-02	TERMINAL 29 TYPE	1	OUTPUT			
5-31	TERMINAL 29	5	RUNNING			
14-20	RESET MODE	13	INFINITE AUTO REST			

FOR YOUR APPLICATION.

B A	SP10119	11/10	-NOTICE- THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF THE TRANE COMPANY	DRN NAME NEMA 3R,480V,NB D7M ,MAIN CB ,DRIVE FUSE						THE TRANE COMPANY A DIVISION OF AMERICAN STANDARD INC.
DR	SP10076	09/10		APR D TM	,SINGLE MOTOR,4 FAN			DWG 1 C		
REV	ECN	DATE			TR200	PAGE <u>1</u> OF <u>1</u>	JIZE A	NO. 18584452		